

**Report 10381
Addendum 1
8 February 1996**

**Earth Observing System (EOS)/
Advanced Microwave Sounding Unit-A (AMSU-A)
Stress Analysis Report, A1 Module**

**Contract No: NAS5-32314
CDRL: 113-A1**

Submitted to:

**National Aeronautics and Space Administration
Goddard Space Flight Center
Greenbelt, Maryland 20771**

Submitted by:

**Aerojet
1100 West Hollyvale Street
Azusa, California 91702**

TABLE OF CONTENTS

Section		Page
1	INTRODUCTION.....	1-1
1.1	Identification	1-1
1.2	Purpose and Objectives	1-1
1.3	Document Status and Schedule.....	1-1
2	SUMMARY OF RESULTS AND CONCLUSIONS	2-2
3	REFERENCE DOCUMENTS.....	3-1
4	METHOD OF ANALYSIS.....	4-1
4.1	Finite Element Model.....	4-1
4.2	Boundary Conditions.....	4-1
4.3	Load Application.....	4-1
5	RESULTS	5-1
5.1	Natural Frequencies	5-1
5.2	Random Vibration with $Q = 7.1$	5-1
5.3	Panel Flange Beindign Stresses.....	5-2
5.4	Summary Tables.....	5-2
5.4.1	Panel Flange Bending Stresses and Attachment Screw Stresses per Random Vibration Loads.....	5-15
5.4.2	Lower Baseplate Mounting Bolts and Pins Stresses per 15 G Static Design Loads	5-124
5.4.3	Thread Shear Stresses in Attachment Hardware per Random Vibration Loads	5-148
5.4.4	Large Masses Attachment Screw Stresses per Random Vibration Loads	5-192
5.4.5	Lower Baseplate Stresses per Random Vibration Loads	5-254

TABLES

Table		Page
1	AMSU-A Margins of Safety, Summary of Static Minimum Margins.....	5-4
2	AMSU-A Margins of Safety, 15 g's in X - Direction	5-5
3	AMSU-A Margins of Safety, 15 g's in Y - Direction	5-6
4	AMSU-A Margins of Safety, 15 g's in Z - Direction.....	5-7
5	AMSU-A Margins of Safety, Summary of Random Vibration Minimum Margins.....	5-8
6	AMSU-A Margins of Safety, Random Vibration in X - Direction	5-9
7	AMSU-A Margins of Safety, Random Vibration in Y - Direction	5-10
8	AMSU-A Margins of Safety, Random Vibration in Z - Direction.....	5-11
34	Fatigue Evaluation - Random VIB Stresses $Q = 7.1$ Qualification Level - 2MIN/AXIS.....	5-13
54	A1-EOS Panel Flange Bending Stress Summary - Random Vibration Loads	5-16
55	A1-EOS Panel Flange Attachment Screw Stress Summary - Random Vibration Loads	5-17
56	A1-EOS Lower Baseplate Mounting Bolts Margins of Safety	5-125
56	A1-EOS Lower Baseplate Mounting Bolts Margins of Safety	5-126
56	A1-EOS Lower Baseplate Mounting Bolts Margins of Safety	5-127
56	A1-EOS Lower Baseplate Shear Pins Shear Tearout Margins of Safety.....	5-128
56	A1-EOS Lower Baseplate Mounting Bolts Member Compression Margins of Safety	5-129
57	AMSU EOS-A1 Thread Shear Per Random Vibration Loads.....	5-149
57	AMSU EOS-A1 Thread Shear Per Random Vibration Loads.....	5-150

TABLE OF CONTENTS (Cont'd)

TABLES (Cont'd)

Table		Page
57	AMSU EOS-A1 Thread Shear Per Random Vibration Loads	5-151
57	AMSU EOS-A1 Thread Shear Per Random Vibration Loads	5-152
57	AMSU EOS-A1 Thread Shear Per Random Vibration Loads	5-153
57	AMSU EOS-A1 Thread Shear Per Random Vibration Loads	5-154
57	AMSU EOS-A1 Thread Shear Per Random Vibration Loads	5-155
57	AMSU EOS-A1 Thread Shear Per Random Vibration Loads	5-156
57	AMSU EOS-A1 Thread Shear Per Random Vibration Loads	5-157
57	AMSU EOS-A1 Thread Shear Per Random Vibration Loads	5-158
58	A1-EOS Large Mass Items Attachment Screw Stress Summary - Random Vibration Loads.....	5-193
59	A1-EOS 1356405 Lower Baseplate Stresses - Random Vibration Loads.....	5-255

FIGURES

Figure		Page
1	AMSU-A1 Axes and Parts Identification	5-287
2	AMSU-A1 External Parts Identification.....	5-288
3	AMSU-A1 Finite Element Model.....	5-289
4	EOS AMSU-A1 1st Non-Rigid Body Modeshape at 109.0 Hz.....	5-290
4 (a)	EOS AMSU-A1 1st Non-Rigid Body Modeshape at 109.0 Hz Lower Cage Cards	5-291
5	EOS AMSU-A1 2nd Non-Rigid Body Modeshape at 109.0 Hz.....	5-292
5 (a)	EOS AMSU-A1 2nd Non-Rigid Body Modeshape at 109.0 Hz Lower Cage Cards	5-293
6	EOS AMSU-A1 3rd Non-Rigid Body Modeshape at 109.6 Hz	5-294
6 (a)	EOS AMSU-A1 3rd Non-Rigid Body Modeshape at 109.6 Hz Lower Cage Cards.....	5-295
7	EOS AMSU-A1 4th Non-Rigid Body Modeshape at 109.7 Hz	5-296
7 (a)	EOS AMSU-A1 4th Non-Rigid Body Modeshape at 109.7 Hz Lower Cage Cards.....	5-297
8	EOS AMSU-A1 5th Non-Rigid Body Modeshape at 116.3 Hz	5-298
9	EOS AMSU-A1 6th Non-Rigid Body Modeshape at 121.4 Hz	5-299
10	EOS AMSU-A1 7th Non-Rigid Body Modeshape at 122.2 Hz.....	5-300
11	EOS AMSU-A1 8th Non-Rigid Body Modeshape at 122.3 Hz	5-301

APPENDIX

Appendix		Page
A	NASTRAN FINITE ELEMENT MODEL	A-1

Section 1

INTRODUCTION

This *Addendum 1* to the *Stress Analysis Report* for the Earth Observing System (EOS) Advanced Microwave Sounding Unit-A (AMSU-A), A1 module, reports the structural margins of safety and natural frequency predictions for the design following the EOS AMSU-A1 Mechanical/Structural Subsystem Critical Design Review (CDR). This report is an addendum to the June 1995 submittal of Aerojet Report 10381. The report has been prepared in accordance with Section 3.4.3 of GSFC 420-05-01, Performance Assurance Requirements for EOS General Instruments.

1.1 Identification

This is *Addendum 1* to the *Stress Analysis Report* for the Earth Observing System (EOS)/Advanced Microwave Sounding Unit -A (AMSU-A), module A1. This report is submitted to fulfill the requirements of Contract NAS 5-32314 CDRL 113, *Stress Analysis Report*, for the EOS AMSU-A1 module. The *Stress Analysis Report* for the A2 module has been submitted under separate cover.

1.2 Purpose and Objectives

The purpose of this analysis is to show that the AMSU-A1 module exhibits positive structural margins of safety when subjected to the design loads given in GSFC 422-11-12-01, General Interface Requirements Document (GIRD) for EOS Common Spacecraft/Instruments EOS PM Project.

In addition, the dynamic analysis results are used to show that the A1 module natural frequencies are above 100 Hz and that the simplified test and analytical model requirements of Section 3.4.3 of GSFC 420-05-01, Performance Assurance Requirements for EOS General Instruments, can be applied to the A1 module.

1.3 Document Status and Schedule

This is the submittal of *Addendum 1* to the *Stress Analysis Report* for the A1 module following the EOS AMSU-A1 Mechanical/Structural Subsystem CDR, held 7 December 1995. *Addendum 1* is meant to be used in conjunction with the June 1995 submittal of the *Stress Analysis Report* for the Earth Observing System (EOS) Advanced Microwave Sounding Unit-A (AMSU-A), A1 module, Report No. 10381.

Section 2

SUMMARY OF RESULTS AND CONCLUSIONS

The updated analysis of *Addendum 1* shows all positive margins of safety for the EOS/AMSU-A1 Unit. Since publication of the June 1995 submittal of the *Stress Analysis Report*, various modifications have been made to the design and analysis. *Addendum 1* analysis reflects these changes. A list of the modifications and added analysis follows:

- (1) The 1356760 Power Control/Monitor Assy was redesigned (new weight 1.62 lb) and modeled in the NASTRAN model, replacing CONM2 point masses (.37 lb).
- (2) The 1331642 Upper Aft Panel was modified to contain two .05 x .50 ribs to help support the Power Control/Monitor Assy. The upper horizontal rib supporting the DC/DC Converter was also notched in three places for assembly purposes.
- (3) The 1356784 Transistor Assembly was added as CONM2 point masses (total weight .50 lb) to the Upper Front Panel.
- (4) Natural frequencies were re-calculated per the above three changes, with the NASTRAN lumped mass option used in place of the coupled mass option. All modes remained above 100 Hz, with the 1st mode now at 109 Hz.
- (5) Mass properties of the EOS/AMSU-A1 Addendum 1 updated configuration show a 109 lb (49.4 kg) unit.
- (6) The random vibration analysis was re-done using a Q of 7.1 to match NOAA test data of the A1 unit. Factors of safety of 1.25 (yield) and 1.4 (ultimate) were used on "3 σ " loads. Minimum margin of safety is now +.31 (was +.07 in Ref 1) at the Upper Right Front Support. In addition, a fatigue evaluation was performed at the June 1995 report most severe location (cumulative usage factor .14 at Upper Right Front Support), with results now showing a cumulative usage factor of .003.
- (7) Analysis is included on panel flange bending stresses resulting from panel tensile loads and offset flange attachment screws. Random vibration loads are used. Stress results required the following design changes:
 - (a) 1331652 Lower Aft Panel - Material change to 2024-T851 aluminum.
MS = +.07 Lower flange to t = .125 - .135 (was .050 - .060)
MS = +.12 Upper flange to t = .070 - .080 (was .050 - .060)
MS = +.16 Right flange to t = .070 - .080 (was .050 - .060)
 - (b) 1331650 Lower Right Panel -
MS = +.06 Lower flange to t = .100 - .110 (was .040 - .060)
 - (c) 1331401 Lower Front Panel -
MS = +.13 Lower flange to t = .090 - .100 (was .040 - .060)
MS = +.14 Upper flange to t = .060 - .070 (was .040 - .060)
 - (d) 1331642 Upper Aft Panel - Material change to 2024-T851 aluminum.
MS = +.11 Lower flange to t = .095 - .105 (was .060 - .070)
 - (e) 1331651 Upper Right Panel - Material change to 6061-T6 aluminum.
MS = +.08 Lower flange to t = .060 - .070 (was .040 - .060)

- (f) 1331447 Lower Right Front Support -
MS = +.18 Lower flange to t = .045 - .055 (was .040 - .060)
- (8) Analysis is included on lower baseplate beam cross-sections at panel attachments. Random vibration loads are used. Stress results required the following design change:
 - (a) 1356405 Lower Baseplate - Membrane under lower aft panel attachment thickened from .075 +/- .010 to .200 +/- .010 MS = +.09.
- (9) To demonstrate the mathematical soundness of the NASTRAN model, the model is subjected to the GSFC 422-11-12-01 Paragraph 11.1.4.i Deliverable Model Validity Check, where a rigid-body or stiffness-equilibrium check is performed. The model is shown to satisfy this check (see Appendix A).
- (10) Analysis added pertaining to the fasteners is as follows:
 - (a) The mounting screws and shear pins of the EOS/AMSU-A1 unit to the spacecraft mounting surface are evaluated for tensile and shear loadings along with thread shear. Loading conditions are the three static design loads, 15g's, independently in the global X, Y, and Z directions. In addition, bearing and shear tearout of the shear pins onto the baseplate are evaluated for the loading assumption of all shear reacted at the shear pins (no shear at mounting bolts). At the mounting bolts, member compression under preload and bearing and shear tearout in the baseplate are also calculated. Minimum overall MS in the mounting fasteners is a +.52 margin in the highest loaded screw under combined tensile and shear load.
 - (b) The fasteners mounting the panels to the baseplates and other panels are analyzed for tensile and shear loading and for thread shear. Thread shear stress calculations also consider the inserts and/or nutplates. Loading conditions are the three random vibration load cases. In addition, the panels' offset flange bending stresses are evaluated per the same random vibration loadings. Minimum MS's are +.06's in the Lower Right Panel lower flange and the Upper Aft Panel side flange, with a MS of +.10 in the screws attaching the Lower Aft Panel to the Lower Baseplate. The following locations are considered:
 - (1) 1331390 Upper Right Front Support
 - (2) 1331652 Lower Aft Panel
 - (3) 1331650 Lower Right Panel
 - (4) 1331352 Upper Front Panel
 - (5) 1331414 Lower Motor Mount Panel
 - (6) 1331389 Upper Motor Mount Panel
 - (7) 1331401 Lower Front Panel
 - (8) 1331642 Upper Aft Panel
 - (9) 1331651 Upper Right Panel
 - (10) 1331447 Lower Right Front Support
 - (c) The attachment hardware mounting the significant mass items to the A1 assembly are analyzed for tensile loads per the loading conditions of random vibration. Superpositioning of finite element model loads, derived from random vibration analysis, with preload effects, and over-turning moment effects is performed on the mounted hardware listed below. Minimum MS is +.68 in the screws attaching the 1331165 Bracket to the 1356409 A1-2 Receiver Assembly.

- (1) 1356010 DC/DC Converter
 - (2) 1331610 Detector Preamp
 - (3) 1356429 Receiver Assembly A1-1 Components
 - (a) 1348360 PLO Assemblies
 - (b) 1336610 Oscillators
 - (c) 1331592 Bracket and Components
 - (d) 1331582 Bracket and Components
 - (e) 1331595 Bracket and Components
 - (4) 1356409 Receiver Assembly A1-2 Components
 - (a) 1331165 Bracket and Components
 - (b) 1331482 Bracket and Components
 - (c) 1331481 Bracket and Components
 - (d) 1336610 Oscillators
- (11) Fastener length changes, required because of panel and baseplate modifications, are reflected on the 1356404 Antenna Subassembly Machined - A1 drawing. Modifications are to (1) the 1331652 Lower Aft Panel attachment to the 1356405 Lower Baseplate, where -9 (if available) or -10 NAS1352N06 fasteners replace the -6 screws, and (2) the 1331642 Upper Aft Panel attachment to the 1331356 Upper Baseplate, where -10 NAS1352N06 fasteners replace -8 screws. All other fastener lengths remain unchanged.
- (12) The following describes added analysis pertaining to the 1336405 Lower Baseplate.
- Baseplate added analysis consists of:
- (1) determining the magnitude of the stresses in the thin shell elements under the lower card cage,
 - (2) hand-calculating the localized stresses in the U-beam cap under the lower front panel, the lower aft panel, and the lower right panel,
 - (3) checking the shear stresses in the grooved section at the base of the integral rib, and
 - (4) calculating shear stresses in the threads for the inserts and nutplates.

All baseplate analysis is performed using the loadings attributed to random vibration. Minimum margins of safety are (1) +4.2 under the lower card cage, (2) +.09 at the lower aft panel, (3) +17 at the grooved section, and (4) +.33 at the internal threads of a baseplate penetration containing an MS51830-103 insert for attachment of the lower right panel to the lower baseplate.

Section 3

REFERENCE DOCUMENTS

The following documents were used in the preparation of this Report:

SPECIFICATIONS	
422-11-12-01 Rev. A January 1994	General Interface Requirements Document (GIRD) for EOS Common Spacecraft/Instruments EOS PM Project
420-05-01 Rev. A 2 Aug. 1991	Earth Observing System (EOS) Performance Assurance Requirements for EOS General Instruments
422-12-12-04 March 1993	Contract Documentation Requirements List for the Advanced Microwave Sounding Unit-A (AMSU-A) EOS PM Project
<i>Aerojet Reports</i>	
Report 9350 21 Dec 1988	Structural Analysis of the AMSU A1 Instrument Final Report
Report 10381 Preliminary Sept 1994	Earth Observing System (EOS)/ Advanced Microwave Sounding Unit-A (AMSU-A) Stress Analysis Report, A1 Module
Report 10381 June 1995	Earth Observing System (EOS)/ Advanced Microwave Sounding Unit-A (AMSU-A) Stress Analysis Report, A1 Module

Section 4

METHOD OF ANALYSIS

4.1 Finite Element Model

The NASTRAN finite element model prepared for EOS AMSU-A1 in the June 1995 report (Report 10381) is modified to a new and more refined model. With the primary changes the modeling of the re-designed Power Control/Monitor and the inclusion of the Transistor Assy mass, the *Addendum 1* model more accurately represents the EOS design (see Figure 3). The *Addendum 1* model statistics are:

6146	Grids
1081	Bar/Beam Elements
5493	Rectangular Plate Elements
523	Triangular Plate Elements
7	Material Types

The total mass of the model is now 49.4 Kg (109.0 pounds). Appendix A presents a detailed description of the NASTRAN finite element model, including the rigid-body validity check.

4.2 Boundary Conditions

The model was constrained along the three orthogonal axes at each of the 20 mounting bolt locations and along the two transverse axes (X and Y in Figure 1) at the 2 dowel pin locations. The constraints were imposed using NASTRAN single point constraint cards.

4.3 Load Application

For the static loads evaluations, the 15g load was uniformly applied over the entire model. Three load cases were run. Each load case represented the 15g load being applied in one of the axes shown in Figure 1.

Similarly for the random vibration loadings, the qualification level 9.97 Grms spectrum was applied along the three orthogonal axes. Three load cases were run. Each load case represented the random spectrum being applied in one of the axes shown in Figure 1. The *Addendum 1* analysis is run with an amplification, Q, of 7.1, corresponding to the highest Q found in NOAA random vibration test results.

Section 5

RESULTS

The previous submittal of the AMSU-A1 EOS Stress Analysis Report (Report 10381) was presented in June 1995, prior to the July 26, 1995 initial Critical Design Review (CDR) on the EOS/AMSU-A1 Mechanical/Structural/Thermal Subsystem. With subsequent comments to the July 1995 presentation addressed, the EOS/AMSU-A1 Mechanical/Structural/Thermal Subsystem final CDR was presented on 7 December 1995. Addendum 1 is written to house the additional analysis performed due to the added scope to the analysis resulting from the action items of the July 1995 and December 1995 CDR's.

5.1 Natural Frequencies

The June 1995 submittal concluded that the minimum natural frequency of the EOS AMSU-A1 unit was 117.6 Hz, with the mode shape involving the flexing of the lower card cage circuit cards. Modes 1 through 4, with mode 4 at 118.6 Hz, all involved lower card cage circuit card and/or cage wall distortion. Mode 5, at 120.6 Hz identified the deformation of the upper aft and top panels.

Pursuant to the June 1995 report release, additional information on the 1356760 Power Control/Monitor (PC/M) Assembly, which mounts on the upper aft panel, became available. This data, a weight increase plus a new detailed design layout, allowed the modeling of the PC/M Assembly into the NASTRAN model (in place of CONM2 point masses). With this addition/modification, along with the addition of the 1356784 Transistor Assy via CONM2 point masses on the Upper Front Panel, the natural frequencies were re-evaluated, with results listed below. In addition, the NASTRAN analysis method option was changed from a coupled mass solution to a more conservative lumped mass solution. The new natural frequencies, per the NASTRAN model post rigid-body equilibrium check, are still above 100 Hz (eliminating the requirement of a detailed deliverable model), with the 1st mode at 108.9 Hz, mode shape lower card cage circuit cards flexing. The 1st mode involving the Upper Aft Panel/Power Control/Monitor is mode 5 at 116.3 Hz.

Mode No.	Natural Frequency Old PC/M (CONM2) No Trans Assy	Natural Frequency New PC/M Modeled W/Trans Assy
1	117.7 Hz	109.0 Hz
2	117.7	109.0
3	118.4	109.6
4	118.7	109.7
5	120.6	116.3
6	126.3	121.4
7	127.1	122.2
8	127.2	122.3
9	148.5	146.6
10	150.0	147.2

Figures 4 through 11 depict the new natural frequencies and modeshapes for the 1st 8 modes.

5.2 Random Vibration with Q = 7.1

Subsequent to the July 1995 presentation, the need was identified to re-evaluate random vibration analysis. The random vibration analysis of the June 1995 report was performed using the NASTRAN code with a type "G" structural damping value of 0.04. The critical damping percentage is 1/2 of this value, or 2%. For large Q, ($Q > 10$), the amplification or quality factor, Q, is approximated by:

$$Q = 1/[2(c/c_c)] \quad c/c_c = \text{fraction of critical damping}$$

With c/c_c equal to 0.02, an amplification, Q , of 25 was used in the NASTRAN model. A Q of 25 was felt to be a conservative value and precluded the use of additional factors of safety in the random vibration analysis. Stresses derived from the NASTRAN solution were multiplied by an additional 3.0 factor to produce " 3σ " values.

The random vibration analysis of *Addendum 1* is re-done using a $Q = 7.14$ (NASTRAN type "G" structural damping value of 0.14), corresponding to the largest Q found in test data of the NOAA A1 unit. To the stresses derived from the NASTRAN random vibration stress output, a 3.0 factor is applied to produce " 3σ " values, plus an additional factor of safety (FS) of 1.25 on yield or 1.4 on ultimate is also employed.

Random vibration analysis in *Addendum 1* is presented similarly to the June 1995 submittal. Per structural component, margins of safety (MS) summary tables are given for each direction of vibration, along with the overall minimum MS table. A fatigue evaluation is performed again at the June 1995 report critical location.

Minimum MS attributed to random vibration " 3σ " loads, per the methods outlined above, is a +.31 at the 1331390 Upper Right Front Support. The fatigue evaluation at the Reference 1 critical location, the Upper Right Front Support, now identifies a cumulative usage factor of only .003, or <1 % of the allowed cycles are utilized.

Addendum 1 Tables 6 through 8 list the NASTRAN model random vibration results.

5.3 Panel Flange Bending Stresses

Addendum 1 analysis is concerned with panel flange bending stresses resulting from panel tensile loads and offset flange attachment screws. Random vibration loads, multiplied by an additional 3.0 factor to produce " 3σ " values, and then used with FS's of 1.25 yield and 1.4 ultimate, are more severe than the static 15g static design loads with FS's, and are thus used in the analysis.

The method employed for evaluation of a flange is to first determine the highest loaded plate finite element adjacent to the flange of interest. The (tensile) force in the panel perpendicular to the flange is the primary load reacted at the bolt in the form of a reacted force and a bending moment. This force is reacted in the flange attachment bolt and the bending moment produces bending in the flange. Both flange attachment bolts and the flanges themselves are evaluated per hand calculation methods. This data is summarized by itself in *Addendum 1*, Table 54, and is utilized in the overall random vibration minimum MS summary (Table 5). Note that no static design load flange bending stress calculations are performed, thus the overall static design load minimum MS summary (Table 1) contains no flange bending hand calculation results. Minimum margin of safety is at the 1331650 Lower Right Panel with $MS = +.06$.

5.4 Summary Tables

Margins of safety results, presented in *Addendum 1*, are the following tables. Tables 1 through 8 and 34 are modified June 1995 report Tables. Table 1 is the overall static loading (15g's in either X, Y, or Z directions) summary table. Tables 2, 3, and 4 present NASTRAN shell and beam results for static loads in the X, Y, and Z directions, respectively.

Table 5 is the overall random vibration ($Q = 7.1$) summary table. Tables 6, 7, and 8 present NASTRAN shell and beam results for random vibration loads in the X, Y, and Z directions, respectively.

Table 34 is a fatigue summary for the June 1995 report critical location at the Upper Right Front Support at element 2633.

Tables 54 through 59 are new Tables of *Addendum 1*. Panel flange bending stresses per random vibration loads are summarized in Table 54, with the results of the attachment screws of the panel flanges in Table 55.

Lower baseplate mounting bolts and associated fastener hardware stresses per static design loads (15g's in either X, Y, or Z directions) are summarized In Table 56.

Thread shear results in the attachment hardware connecting the panels to baseplates and other panels per random vibration loads are found in Table 57.

Large mass item attachment screw stresses per random vibration loads are found in Table 58.

Lower baseplate stresses per random vibration loads are shown in Table 59.

The Earth Observing System (EOS)/Advanced Microwave Sounding Unit-A (AMSU-A), A1 unit is shown in *Addendum 1* to exhibit all positive margins of safety and is therefore suitable for flight.

Hand written analyses on the above subjects follow the summary tables.

TABLE 1
AMSU-A1 MARGINS OF SAFETY
SUMMARY OF STATIC MINIMUM MARGINS

ITEM NO.*	DESCRIPTION	PART NUMBER	MATERIAL/ ALLOY	YIELD (PSI)	ULTIMATE (PSI)	MAXIMUM STRESS (PSI)	MARGINS OF SAFETY	
							YIELD	ULTIMATE
1	BASEPLATE ASSEMBLY, LOWER	1356405-1	ALUM/6061-T651	35000	42000	4925	4.69	5.09
2	PANEL, MOTOR MOUNT LOWER	1331414-1	ALUM/7075-T651	66000	75000	3055	16.28	16.54
3	PANEL, MOTOR MOUNT UPPER	1331389-1	ALUM/7075-T651	66000	75000	1944	26.16	26.56
4	PANEL, FRONT, LOWER	1331401-1	ALUM/6061-T651	35000	42000	4198	5.67	6.15
5	PANEL, AFT, LOWER	1331652-1	ALUM/2024-T851	58000	66000	5346	7.68	7.82
6	BASEPLATE, UPPER	1331356-1	ALUM/6061-T651	35000	42000	5136	4.45	4.84
7	PANEL, FRONT UPPER	1331352-1	ALUM/7075-T651	66000	75000	4706	10.22	10.38
8	PANEL, AFT WALL, UPPER	1331642-3	ALUM/2024-T851	58000	66000	3104	13.95	14.19
9	SHELF, RF, LOWER	1331556-1	BE/SR-200E	50000	70000	3018	12.25	15.57
10	SHELF, RF, UPPER	1331491-1	BE/SR-200E	50000	70000	2182	17.33	21.91
11	SUPPORT PANEL, LOWER RIGHT FRONT	1331447-1	ALUM/6061-T651	35000	42000	3451	7.11	7.69
12	PANEL, SIDEWALL, RIGHT LOWER	1331650-4	ALUM/6061-T6	35000	42000	10092	1.77	1.97
13	PANEL, SUPPORT, RIGHT FRONT UPPER	1331390-1	ALUM/6061-T651	35000	42000	6313	3.44	3.75
14	PANEL, SIDEWALL, RIGHT-UPPER	1331651-1	ALUM/6061-T6	35000	42000	830	32.73	35.14
15	PANEL, TOP	1356866-1	ALUM/6061-T6	35000	42000	627	43.66	46.85
16	PANEL, SIDEWALL, LEFT	1356626-1	ALUM/6061-T6	35000	42000	1363	19.54	21.01
17	MOTOR ROTOR SHAFT	1333645-1	303 CRES A COND	26000	73000	600	33.67	85.90
18	SHIELD, WARMLOAD, LOWER LEFT	1331445-1	ALUM/6061-T6	35000	42000	3085	8.08	8.72
19	SHIELD, WARMLOAD, LOWER RIGHT	1331405-1	ALUM/6061-T6	35000	42000	2633	9.63	10.39
20	SHIELD, WARMLOAD, UPPER LEFT	1331647-1	ALUM/6061-T6	35000	42000	2735	9.24	9.97
21	SHIELD, WARMLOAD, UPPER RIGHT	1331646-1	ALUM/6061-T6	35000	42000	2832	8.89	9.59
22	CARD CAGE ASSY (LOWER)	1331600-1	ALUM/6061-T6	35000	42000	1896	13.77	14.82
23	CARD CAGE ASSY, UPPER	1331162-8	ALUM/6061-T6	35000	42000	3665	6.64	7.19
23	CARD CAGE ASSY, UPPER	1331162-8	ALUM/6061-T4	16000	30000	2057	5.22	9.42
24	CALIBRATION SOURCE ASSY, WL (LOW)	1331380-1	ALUM/6061-T6	35000	42000	896	30.25	32.48
25	CALIBRATION SOURCE ASSY, WL (UP)	1331380-2	ALUM/7075-T6	66000	75000	942	55.05	55.87
26	BEAM SUPPORT	1331406-1	ALUM/7075-T6	66000	75000	4606	10.46	10.63

*SEE FIGURES 1 & 2

TABLE 2
AMSU-A1 MARGINS OF SAFETY
15 g's IN X - DIRECTION

ITEM NO.*	DESCRIPTION	PART NUMBER	MATERIAL/ ALLOY	YIELD (psi)	ULTIMATE (psi)	MAXIMUM STRESS (psi)	MARGINS OF SAFETY	
							YIELD	ULTIMATE
1	BASEPLATE ASSEMBLY, LOWER	1356405-1	ALUM/6061-T651	35000	42000	1728	15.20	16.36
2	PANEL, MOTOR MOUNT LOWER	1331414-1	ALUM/7075-T651	66000	75000	3055	16.28	16.54
3	PANEL, MOTOR MOUNT UPPER	1331389-1	ALUM/7075-T651	66000	75000	1944	26.16	26.56
4	PANEL, FRONT, LOWER	1331401-1	ALUM/6061-T651	35000	42000	2004	12.97	13.97
5	PANEL, AFT, LOWER	1331652-1	ALUM/2024-T851	58000	66000	3284	13.13	13.36
6	BASEPLATE, UPPER	1331356-1	ALUM/6061-T651	35000	42000	3019	8.27	8.94
7	PANEL, FRONT UPPER	1331352-1	ALUM/7075-T651	66000	75000	4072	11.97	12.16
8	PANEL, AFT WALL, UPPER	1331642-3	ALUM/2024-T851	58000	66000	3104	13.95	14.19
9	SHELF, RF, LOWER	1331556-1	BE/SR-200E	50000	70000	3018	12.25	15.57
10	SHELF, RF, UPPER	1331491-1	BE/SR-200E	50000	70000	372	106.53	133.41
11	SUPPORT PANEL, LOWER RIGHT FRONT	1331447-1	ALUM/6061-T651	35000	42000	1436	18.50	19.89
12	PANEL, SIDEWALL, RIGHT LOWER	1331650-4	ALUM/6061-T6	35000	42000	2526	10.08	10.88
13	PANEL, SUPPORT, RIGHT FRONT UPPER	1331390-1	ALUM/6061-T651	35000	42000	3805	6.36	6.88
14	PANEL, SIDEWALL, RIGHT-UPPER	1331651-1	ALUM/6061-T6	35000	42000	830	32.73	35.14
15	PANEL, TOP	1356866-1	ALUM/6061-T6	35000	42000	434	63.52	68.12
16	PANEL, SIDEWALL, LEFT	1356626-1	ALUM/6061-T6	35000	42000	1363	19.54	21.01
17	MOTOR ROTOR SHAFT	1333645-1	303 CRES A COND	26000	73000	82	252.66	634.89
18	SHIELD, WARMLOAD, LOWER LEFT	1331445-1	ALUM/6061-T6	35000	42000	3085	8.08	8.72
19	SHIELD, WARMLOAD, LOWER RIGHT	1331405-1	ALUM/6061-T6	35000	42000	2633	9.63	10.39
20	SHIELD, WARMLOAD, UPPER LEFT	1331647-1	ALUM/6061-T6	35000	42000	2735	9.24	9.97
21	SHIELD, WARMLOAD, UPPER RIGHT	1331646-1	ALUM/6061-T6	35000	42000	2832	8.89	9.59
22	CARD CAGE ASSY (LOWER)	1331600-1	ALUM/6061-T6	35000	42000	456	60.40	64.79
23	CARD CAGE ASSY, UPPER	1331162-8	ALUM/6061-T6	35000	42000	769	35.41	38.01
23	CARD CAGE ASSY, UPPER	1331162-8	ALUM/6061-T4	16000	30000	370	33.59	56.92
24	CALIBRATION SOURCE ASSY, WL (LOW)	1331380-1	ALUM/6061-T6	35000	42000	322	85.96	92.17
25	CALIBRATION SOURCE ASSY, WL (UP)	1331380-2	ALUM/7075-T6	66000	75000	394	133.01	134.97
26	BEAM SUPPORT	1331406-1	ALUM/7075-T6	66000	75000	4606	10.46	10.63

*SEE FIGURES 1 & 2

TABLE 3
AMSU-A1 MARGINS OF SAFETY
15 g's IN Y - DIRECTION

ITEM NO.*	DESCRIPTION	PART NUMBER	MATERIAL/ ALLOY	YIELD (psi)	ULTIMATE (psi)	MAXIMUM STRESS (psi)	MARGINS OF SAFETY	
							YIELD	ULTIMATE
1	BASEPLATE ASSEMBLY, LOWER	1356405-1	ALUM/6061-T651	35000	42000	4925	4.69	5.09
2	PANEL, MOTOR MOUNT LOWER	1331414-1	ALUM/7075-T651	66000	75000	1066	48.53	49.25
3	PANEL, MOTOR MOUNT UPPER	1331389-1	ALUM/7075-T651	66000	75000	1017	50.92	51.68
4	PANEL, FRONT, LOWER	1331401-1	ALUM/6061-T651	35000	42000	4198	5.67	6.15
5	PANEL, AFT, LOWER	1331652-1	ALUM/2024-T851	58000	66000	5346	7.68	7.82
6	BASEPLATE, UPPER	1331356-1	ALUM/6061-T651	35000	42000	5136	4.45	4.84
7	PANEL, FRONT UPPER	1331352-1	ALUM/7075-T651	66000	75000	4706	10.22	10.38
8	PANEL, AFT WALL, UPPER	1331642-3	ALUM/2024-T851	58000	66000	1171	38.62	39.26
9	SHELF, RF, LOWER	1331556-1	BE/SR-200E	50000	70000	1612	23.81	30.02
10	SHELF, RF, UPPER	1331491-1	BE/SR-200E	50000	70000	623	63.21	79.26
11	SUPPORT PANEL, LOWER RIGHT FRONT	1331447-1	ALUM/6061-T651	35000	42000	3451	7.11	7.69
12	PANEL, SIDEWALL, RIGHT LOWER	1331650-4	ALUM/6061-T6	35000	42000	10092	1.77	1.97
13	PANEL, SUPPORT, RIGHT FRONT UPPER	1331390-1	ALUM/6061-T651	35000	42000	6313	3.44	3.75
14	PANEL, SIDEWALL, RIGHT-UPPER	1331651-1	ALUM/6061-T6	35000	42000	703	38.83	41.67
15	PANEL, TOP	1356866-1	ALUM/6061-T6	35000	42000	278	99.72	106.91
16	PANEL, SIDEWALL, LEFT	1356626-1	ALUM/6061-T6	35000	42000	810	33.57	36.04
17	MOTOR ROTOR SHAFT	1333645-1	303 CRES A COND	26000	73000	600	33.67	85.90
18	SHIELD, WARMLOAD, LOWER LEFT	1331445-1	ALUM/6061-T6	35000	42000	2377	10.78	11.62
19	SHIELD, WARMLOAD, LOWER RIGHT	1331405-1	ALUM/6061-T6	35000	42000	847	32.06	34.42
20	SHIELD, WARMLOAD, UPPER LEFT	1331647-1	ALUM/6061-T6	35000	42000	365	75.71	81.19
21	SHIELD, WARMLOAD, UPPER RIGHT	1331646-1	ALUM/6061-T6	35000	42000	601	45.59	48.92
22	CARD CAGE ASSY (LOWER)	1331600-1	ALUM/6061-T6	35000	42000	1896	13.77	14.82
23	CARD CAGE ASSY, UPPER	1331162-8	ALUM/6061-T6	35000	42000	1179	22.75	24.45
24	CALIBRATION SOURCE ASSY, WL (LOW)	1331380-1	ALUM/6061-T6	35000	42000	746	36.53	39.21
25	CALIBRATION SOURCE ASSY, WL (UP)	1331380-2	ALUM/7075-T6	66000	75000	501	104.39	105.93
26	BEAM SUPPORT	1331406-1	ALUM/7075-T6	66000	75000	1044	49.57	50.31

*SEE FIGURES 1 & 2

TABLE 4
AMSU-A1 MARGINS OF SAFETY
15 g's IN Z - DIRECTION

ITEM NO.*	DESCRIPTION	PART NUMBER	MATERIAL/ ALLOY	YIELD (psi)	ULTIMATE (psi)	MAXIMUM STRESS (psi)	MARGINS OF SAFETY	
							YIELD	ULTIMATE
1	BASEPLATE ASSEMBLY, LOWER	1356405-1	ALUM/6061-T651	35000	42000	4310	5.50	5.96
2	PANEL, MOTOR MOUNT LOWER	1331414-1	ALUM/7075-T651	66000	75000	548	95.35	96.76
3	PANEL, MOTOR MOUNT UPPER	1331389-1	ALUM/7075-T651	66000	75000	942	55.05	55.87
4	PANEL, FRONT, LOWER	1331401-1	ALUM/6061-T651	35000	42000	2434	10.50	11.33
5	PANEL, AFT, LOWER	1331652-1	ALUM/2024-T851	58000	66000	3650	11.71	11.92
6	BASEPLATE, UPPER	1331356-1	ALUM/6061-T651	35000	42000	3940	6.11	6.61
7	PANEL, FRONT UPPER	1331352-1	ALUM/7075-T651	66000	75000	2240	22.57	22.92
8	PANEL, AFT WALL, UPPER	1331642-3	ALUM/2024-T851	58000	66000	1406	32.00	32.53
9	SHELF, RF, LOWER	1331556-1	BE/SR-200E	50000	70000	2843	13.07	16.59
10	SHELF, RF, UPPER	1331491-1	BE/SR-200E	50000	70000	2182	17.33	21.91
11	SUPPORT PANEL, LOWER RIGHT FRONT	1331447-1	ALUM/6061-T651	35000	42000	1258	21.26	22.85
12	PANEL, SIDEWALL, RIGHT LOWER	1331650-4	ALUM/6061-T6	35000	42000	5422	4.16	4.53
13	PANEL, SUPPORT, RIGHT FRONT UPPER	1331390-1	ALUM/6061-T651	35000	42000	5075	4.52	4.91
14	PANEL, SIDEWALL, RIGHT-UPPER	1331651-1	ALUM/6061-T6	35000	42000	445	61.92	66.42
15	PANEL, TOP	1356866-1	ALUM/6061-T6	35000	42000	627	43.66	46.85
16	PANEL, SIDEWALL, LEFT	1356626-1	ALUM/6061-T6	35000	42000	816	33.31	35.76
17	MOTOR ROTOR SHAFT	1333645-1	303 CRES A COND	26000	73000	600	33.67	85.90
18	SHIELD, WARMLOAD, LOWER LEFT	1331445-1	ALUM/6061-T6	35000	42000	1939	13.44	14.47
19	SHIELD, WARMLOAD, LOWER RIGHT	1331405-1	ALUM/6061-T6	35000	42000	744	36.63	39.32
20	SHIELD, WARMLOAD, UPPER LEFT	1331647-1	ALUM/6061-T6	35000	42000	2093	12.38	13.33
21	SHIELD, WARMLOAD, UPPER RIGHT	1331646-1	ALUM/6061-T6	35000	42000	602	45.51	48.83
22	CARD CAGE ASSY (LOWER)	1331600-1	ALUM/6061-T6	35000	42000	1588	16.63	17.89
23	CARD CAGE ASSY, UPPER	1331162-8	ALUM/6061-T6	35000	42000	3665	6.64	7.19
23	CARD CAGE ASSY, UPPER	1331162-8	ALUM/6061-T4	16000	30000	2057	5.22	9.42
24	CALIBRATION SOURCE ASSY, WL (LOW)	1331380-1	ALUM/6061-T6	35000	42000	896	30.25	32.48
25	CALIBRATION SOURCE ASSY, WL (UP)	1331380-2	ALUM/7075-T6	66000	75000	942	55.05	55.87
26	BEAM SUPPORT	1331406-1	ALUM/7075-T6	66000	75000	2671	18.77	19.06

*SEE FIGURE 1

TABLE 5

AMSU-A1 MARGINS OF SAFETY

SUMMARY OF RANDOM VIBRATION MINIMUM MARGINS

ITEM NO.*	DESCRIPTION	PART NUMBER	MATERIAL/ ALLOY	YIELD (PSI)	ULTIMATE (PSI)	3 SIGMA STRESS (PSI)	MARGINS OF SAFETY	
							YIELD	ULTIMATE
1	BASEPLATE ASSEMBLY, LOWER	1356405-1	ALUM/6061-T651	35000	42000	25654	0.09	0.17
2	PANEL, MOTOR MOUNT LOWER	1331414-1	ALUM/7075-T651	66000	75000	39937	0.32	0.34
3	PANEL, MOTOR MOUNT UPPER	1331389-1	ALUM/7075-T651	66000	75000	43788	0.21	0.22
4	PANEL, FRONT, LOWER	1331401-1	ALUM/6061-T651	35000	42000	24692	0.13	0.21
5	PANEL, AFT, LOWER	1331652-1	ALUM/2024-T851	58000	66000	43374	0.07	0.09
6	BASEPLATE, UPPER	1331356-1	ALUM/6061-T651	35000	42000	17148	0.63	0.75
7	PANEL, FRONT UPPER	1331352-1	ALUM/7075-T651	66000	75000	43260	0.22	0.24
8	PANEL, AFT WALL, UPPER	1331642-3	ALUM/2024-T851	58000	66000	43774	0.06	0.08
9	SHELF, RF, LOWER	1331556-1	BE/SR-200E	50000	70000	6841	4.85	6.31
10	SHELF, RF, UPPER	1331491-1	BE/SR-200E	50000	70000	7067	4.66	6.08
11	SUPPORT PANEL, LOWER RIGHT FRONT	1331447-1	ALUM/6061-T651	35000	42000	23766	0.18	0.26
12	PANEL, SIDEWALL, RIGHT LOWER	1331650-4	ALUM/6061-T6	35000	42000	26502	0.06	0.13
13	PANEL, SUPPORT, RIGHT FRONT UPPER	1331390-1	ALUM/6061-T651	35000	42000	21390	0.31	0.40
14	PANEL, SIDEWALL, RIGHT-UPPER	1331651-1	ALUM/6061-T6	35000	42000	25894	0.08	0.16
15	PANEL, TOP	1356866-1	ALUM/6061-T6	35000	42000	2215	11.64	12.54
16	PANEL, SIDEWALL, LEFT	1356626-1	ALUM/6061-T6	35000	42000	3432	7.16	7.74
18	SHIELD, WARMLOAD, LOWER LEFT	1331445-1	ALUM/6061-T6	35000	42000	5487	4.10	4.47
19	SHIELD, WARMLOAD, LOWER RIGHT	1331405-1	ALUM/6061-T6	35000	42000	6192	3.52	3.84
20	SHIELD, WARMLOAD, UPPER LEFT	1331647-1	ALUM/6061-T6	35000	42000	7674	2.65	2.91
21	SHIELD, WARMLOAD, UPPER RIGHT	1331646-1	ALUM/6061-T6	35000	42000	8841	2.17	2.39
22	CARD CAGE ASSY (LOWER)	1331600-1	ALUM/6061-T6	35000	42000	6810	3.11	3.41
23	CARD CAGE ASSY, UPPER	1331162-8	ALUM/6061-T6	35000	42000	11730	1.39	1.56
23	CARD CAGE ASSY, UPPER	1331162-8	ALUM/6061-T4	16000	30000	3076	3.16	5.97
24	CALIBRATION SOURCE ASSY, WL (LOW)	1331380-1	ALUM/6061-T6	35000	42000	4729	4.92	5.34
25	CALIBRATION SOURCE ASSY, WL (UP)	1331380-2	ALUM/6061-T6	35000	42000	3537	6.92	7.48
26	BEAM SUPPORT	1331406-1	ALUM/6061-T6	35000	42000	9174	2.05	2.27
27	REFLECTOR ASSY (LOWER)	1355777-1	ALUM/7075-T6	66000	75000	9393	4.62	4.70
28	REFLECTOR ASSY (UPPER)	1355777-1	ALUM/7075-T6	66000	75000	14595	2.62	2.67

*SEE FIGURES 1 & 2

TABLE 6
AMSU-A1 MARGINS OF SAFETY
RANDOM VIBRATION IN X - DIRECTION

ITEM NO.*	DESCRIPTION	PART NUMBER	MATERIAL/ ALLOY	YIELD (psi)	ULTIMATE (psi)	3 SIGMA STRESS (psi)	MARGINS OF SAFETY	
							YIELD	ULTIMATE
1	BASEPLATE ASSEMBLY, LOWER	1356405-1	ALUM/6061-T651	35000	42000	3474	7.06	7.64
2	PANEL, MOTOR MOUNT LOWER	1331414-1	ALUM/7075-T651	66000	75000	9108	4.80	4.88
3	PANEL, MOTOR MOUNT UPPER	1331389-1	ALUM/7075-T651	66000	75000	7155	6.38	6.49
4	PANEL, FRONT, LOWER	1331401-1	ALUM/6061-T651	35000	42000	8328	2.36	2.60
5	PANEL, AFT, LOWER	1331652-1	ALUM/2024-T851	58000	66000	6324	6.34	6.45
6	BASEPLATE, UPPER	1331356-1	ALUM/6061-T651	35000	42000	8112	2.45	2.70
7	PANEL, FRONT UPPER	1331352-1	ALUM/7075-T651	66000	75000	21998	1.40	1.44
8	PANEL, AFT WALL, UPPER	1331642-3	ALUM/2024-T851	58000	66000	5937	6.82	6.94
9	SHELF, RF, LOWER	1331556-1	BE/SR-200E	50000	70000	5630	6.10	7.88
10	SHELF, RF, UPPER	1331491-1	BE/SR-200E	50000	70000	1859	20.52	25.90
11	SUPPORT PANEL, LOWER RIGHT FRONT	1331447-1	ALUM/6061-T651	35000	42000	1254	21.33	22.92
12	PANEL, SIDEWALL, RIGHT LOWER	1331650-4	ALUM/6061-T6	35000	42000	6096	3.59	3.92
13	PANEL, SUPPORT, RIGHT FRONT UPPER	1331390-1	ALUM/6061-T651	35000	42000	10314	1.71	1.91
14	PANEL, SIDEWALL, RIGHT-UPPER	1331651-1	ALUM/6061-T6	35000	42000	3530	6.93	7.50
15	PANEL, TOP	1356866-1	ALUM/6061-T6	35000	42000	1034	26.08	28.01
16	PANEL, SIDEWALL, LEFT	1356626-1	ALUM/6061-T6	35000	42000	3432	7.16	7.74
18	SHIELD, WARMLOAD, LOWER LEFT	1331445-1	ALUM/6061-T6	35000	42000	5487	4.10	4.47
19	SHIELD, WARMLOAD, LOWER RIGHT	1331405-1	ALUM/6061-T6	35000	42000	6192	3.52	3.84
20	SHIELD, WARMLOAD, UPPER LEFT	1331647-1	ALUM/6061-T6	35000	42000	7674	2.65	2.91
21	SHIELD, WARMLOAD, UPPER RIGHT	1331646-1	ALUM/6061-T6	35000	42000	8841	2.17	2.39
22	CARD CAGE ASSY (LOWER)	1331600-1	ALUM/6061-T6	35000	42000	1913	13.64	14.68
23	CARD CAGE ASSY, UPPER	1331162-8	ALUM/6061-T6	35000	42000	4113	5.81	6.29
23	CARD CAGE ASSY, UPPER	1331162-8	ALUM/6061-T4	16000	30000	3076	3.16	5.97
24	CALIBRATION SOURCE ASSY, WL (LOW)	1331380-1	ALUM/6061-T6	35000	42000	1745	15.05	16.19
25	CALIBRATION SOURCE ASSY, WL (UP)	1331380-2	ALUM/6061-T6	35000	42000	3537	6.92	7.48
26	BEAM SUPPORT	1331406-1	ALUM/6061-T6	35000	42000	9174	2.05	2.27
27	REFLECTOR ASSY (LOWER)	1355777-1	ALUM/7075-T6	66000	75000	9393	4.62	4.70
28	REFLECTOR ASSY (UPPER)	1355777-1	ALUM/7075-T6	66000	75000	14595	2.62	2.67

*SEE FIGURES 1 & 2

TABLE 7
AMSU-A1 MARGINS OF SAFETY
RANDOM VIBRATION IN Y - DIRECTION

ITEM NO.*	DESCRIPTION	PART NUMBER	MATERIAL/ ALLOY	YIELD (psi)	ULTIMATE (psi)	3 SIGMA STRESS (psi)	MARGINS OF SAFETY	
							YIELD	ULTIMATE
1	BASEPLATE ASSEMBLY, LOWER	1356405-1	ALUM/6061-T651	35000	42000	9435	1.97	2.18
2	PANEL, MOTOR MOUNT LOWER	1331414-1	ALUM/7075-T651	66000	75000	1989	25.55	25.93
3	PANEL, MOTOR MOUNT UPPER	1331389-1	ALUM/7075-T651	66000	75000	5487	8.62	8.76
4	PANEL, FRONT, LOWER	1331401-1	ALUM/6061-T651	35000	42000	8853	2.16	2.39
5	PANEL, AFT, LOWER	1331652-1	ALUM/2024-T851	58000	66000	10845	3.28	3.35
6	BASEPLATE, UPPER	1331356-1	ALUM/6061-T651	35000	42000	17148	0.63	0.75
7	PANEL, FRONT UPPER	1331352-1	ALUM/7075-T651	66000	75000	14627	2.61	2.66
8	PANEL, AFT WALL, UPPER	1331642-3	ALUM/2024-T851	58000	66000	3939	10.78	10.97
9	SHELF, RF, LOWER	1331556-1	BE/SR-200E	50000	70000	3960	9.10	11.63
10	SHELF, RF, UPPER	1331491-1	BE/SR-200E	50000	70000	2517	14.89	18.86
11	SUPPORT PANEL, LOWER RIGHT FRONT	1331447-1	ALUM/6061-T651	35000	42000	6177	3.53	3.86
12	PANEL, SIDEWALL, RIGHT LOWER	1331650-4	ALUM/6061-T6	35000	42000	19551	0.43	0.53
13	PANEL, SUPPORT, RIGHT FRONT UPPER	1331390-1	ALUM/6061-T651	35000	42000	21390	0.31	0.40
14	PANEL, SIDEWALL, RIGHT-UPPER	1331651-1	ALUM/6061-T6	35000	42000	2557	9.95	10.73
15	PANEL, TOP	1356866-1	ALUM/6061-T6	35000	42000	1125	23.89	25.67
16	PANEL, SIDEWALL, LEFT	1356626-1	ALUM/6061-T6	35000	42000	2047	12.68	13.66
18	SHIELD, WARMLOAD, LOWER LEFT	1331445-1	ALUM/6061-T6	35000	42000	5085	4.51	4.90
19	SHIELD, WARMLOAD, LOWER RIGHT	1331405-1	ALUM/6061-T6	35000	42000	1212	22.10	23.75
20	SHIELD, WARMLOAD, UPPER LEFT	1331647-1	ALUM/6061-T6	35000	42000	5757	3.86	4.21
21	SHIELD, WARMLOAD, UPPER RIGHT	1331646-1	ALUM/6061-T6	35000	42000	8175	2.43	2.67
22	CARD CAGE ASSY (LOWER)	1331600-1	ALUM/6061-T6	35000	42000	5276	4.31	4.69
23	CARD CAGE ASSY, UPPER	1331162-8	ALUM/6061-T6	35000	42000	4554	5.15	5.59
23	CARD CAGE ASSY, UPPER	1331162-8	ALUM/6061-T4	16000	30000	915	12.99	22.42
24	CALIBRATION SOURCE ASSY, WL (LOW)	1331380-1	ALUM/6061-T6	35000	42000	2434	10.50	11.33
25	CALIBRATION SOURCE ASSY, WL (UP)	1331380-2	ALUM/6061-T6	35000	42000	2199	11.73	12.64
26	BEAM SUPPORT	1331406-1	ALUM/6061-T6	35000	42000	4638	5.04	5.47
27	REFLECTOR ASSY (LOWER)	1355777-1	ALUM/7075-T6	66000	75000	4368	11.09	11.26
28	REFLECTOR ASSY (UPPER)	1355777-1	ALUM/7075-T6	66000	75000	8229	5.42	5.51

*SEE FIGURES 1 & 2

TABLE 8
AMSU-A1 MARGINS OF SAFETY
RANDOM VIBRATION IN Z - DIRECTION

ITEM NO.*	DESCRIPTION	PART NUMBER	MATERIAL/ ALLOY	YIELD (psi)	ULTIMATE (psi)	3 SIGMA STRESS (psi)	MARGINS OF SAFETY	
							YIELD	ULTIMATE
1	BASEPLATE ASSEMBLY, LOWER	1356405-1	ALUM/6061-T651	35000	42000	9666	1.90	2.10
2	PANEL, MOTOR MOUNT LOWER	1331414-1	ALUM/7075-T651	66000	75000	1620	31.59	32.07
3	PANEL, MOTOR MOUNT UPPER	1331389-1	ALUM/7075-T651	66000	75000	1992	25.51	25.89
4	PANEL, FRONT, LOWER	1331401-1	ALUM/6061-T651	35000	42000	4539	5.17	5.61
5	PANEL, AFT, LOWER	1331652-1	ALUM/2024-T851	58000	66000	6204	6.48	6.60
6	BASEPLATE, UPPER	1331356-1	ALUM/6061-T651	35000	42000	7146	2.92	3.20
7	PANEL, FRONT UPPER	1331352-1	ALUM/7075-T651	66000	75000	5564	8.49	8.63
8	PANEL, AFT WALL, UPPER	1331642-3	ALUM/2024-T851	58000	66000	2586	16.94	17.23
9	SHELF, RF, LOWER	1331556-1	BE/SR-200E	50000	70000	6841	4.85	6.31
10	SHELF, RF, UPPER	1331491-1	BE/SR-200E	50000	70000	7067	4.66	6.08
11	SUPPORT PANEL, LOWER RIGHT FRONT	1331447-1	ALUM/6061-T651	35000	42000	2541	10.02	10.81
12	PANEL, SIDEWALL, RIGHT LOWER	1331650-4	ALUM/6061-T6	35000	42000	10035	1.79	1.99
13	PANEL, SUPPORT, RIGHT FRONT UPPER	1331390-1	ALUM/6061-T651	35000	42000	9174	2.05	2.27
14	PANEL, SIDEWALL, RIGHT-UPPER	1331651-1	ALUM/6061-T6	35000	42000	926	29.24	31.40
15	PANEL, TOP	1356866-1	ALUM/6061-T6	35000	42000	2215	11.64	12.54
16	PANEL, SIDEWALL, LEFT	1356626-1	ALUM/6061-T6	35000	42000	1852	14.12	15.20
18	SHIELD, WARMLOAD, LOWER LEFT	1331445-1	ALUM/6061-T6	35000	42000	1872	13.96	15.03
19	SHIELD, WARMLOAD, LOWER RIGHT	1331405-1	ALUM/6061-T6	35000	42000	1719	15.29	16.45
20	SHIELD, WARMLOAD, UPPER LEFT	1331647-1	ALUM/6061-T6	35000	42000	4911	4.70	5.11
21	SHIELD, WARMLOAD, UPPER RIGHT	1331646-1	ALUM/6061-T6	35000	42000	2202	11.72	12.62
22	CARD CAGE ASSY (LOWER)	1331600-1	ALUM/6061-T6	35000	42000	6810	3.11	3.41
23	CARD CAGE ASSY, UPPER	1331162-8	ALUM/6061-T6	35000	42000	11730	1.39	1.56
23	CARD CAGE ASSY, UPPER	1331162-8	ALUM/6061-T4	16000	30000	2161	4.92	8.92
24	CALIBRATION SOURCE ASSY, WL (LOW)	1331380-1	ALUM/6061-T6	35000	42000	4729	4.92	5.34
25	CALIBRATION SOURCE ASSY, WL (UP)	1331380-2	ALUM/6061-T6	35000	42000	3137	7.93	8.56
26	BEAM SUPPORT	1331406-1	ALUM/6061-T6	35000	42000	4452	5.29	5.74
27	REFLECTOR ASSY (LOWER)	1355777-1	ALUM/7075-T6	66000	75000	1998	25.43	25.81
28	REFLECTOR ASSY (UPPER)	1355777-1	ALUM/7075-T6	66000	75000	3825	12.80	13.01

*SEE FIGURES 1 & 2

Tables 9 through 33 not re-evaluated in *Addendum 1*.

FATIGUE EVALUATION					TABLE 34
RANDOM VIB STRESSES Q = 7.1					
QUALIFICATION LEVEL - 2 MIN/AXIS					
UPPER RIGHT FRONT					
SUPPORT PANEL					
BAR ELEMENT 2633	X - LOAD	Y - LOAD	Z - LOAD		
STRESS @ 1 SIGMA	3438	7138	3058		
STRESS @ 2 SIGMA	6876	14276	6116		
STRESS @ 3 SIGMA	10314	21414	9174		
EFFECTIVE FREQUENCY	217	184	283		
REQ'D CYCLES/STRESS	X - LOAD	Y - LOAD	Z - LOAD		
CYCLES @ 1 SIGMA	17707.2	15014.4	23092.8		
CYCLES @ 2 SIGMA	7161	6072	9339		
CYCLES @ 3 SIGMA	1171.8	993.6	1528.2		
TOTAL REQ'D CYCLES	26040	22080	33960		
MATERIAL 6061-T6					
MIL-HDBK-5F FIG 3.6.2.2.8, R = -1.0					
ENDUR LIMIT @ 100000000 CYCLES					
FATIGUE SUMMARY	STRESS	REQ'D	ALLOWED	USAGE	
	LEVEL	CYCLES	CYCLES	FACTOR	
X-STRESS @ 3 SIGMA	10314	1171.8	100000000	0.00001	
X-STRESS @ 2 SIGMA	6876	7161	100000000	0.00007	
X-STRESS @ 1 SIGMA	3438	17707.2	100000000	0.00018	
Y-STRESS @ 3 SIGMA	21414	993.6	524552	0.00189	
Y-STRESS @ 2 SIGMA	14276	6072	28348265	0.00021	
Y-STRESS @ 1 SIGMA	7138	15014.4	100000000	0.00015	
Z-STRESS @ 3 SIGMA	9174	1528.2	100000000	0.00002	
Z-STRESS @ 2 SIGMA	6116	9339	100000000	0.00009	
Z-STRESS @ 1 SIGMA	3058	23092.8	100000000	0.00023	
CUMULATIVE USAGE				0.00286	
ALLOWABLE USAGE				0.80000	

Tables 35 through 53 not re-evaluated in *Addendum 1*.

5.4.1 Panel Flange Bending Stresses and Attachment Screw Stresses per Random Vibration Loads

The following pages contain a detailed analysis of panel flange bending stresses and attachment screw stresses per random vibration loads.

TABLE 54 A1-EOS PANEL FLANGE BENDING STRESS SUMMARY - RANDOM VIBRATION LOADS									
COMPONENT	PART NO.	FLANGE	MAT'RL	Fty	MIN t	STRESS	FS	MS	RANGE t
				PSI	IN	PSI			IN
UPPER RIGHT FRONT SUPPORT	1331390	ALL	6061-T6	35000	0.065	19776	1.25	0.42	.065-.075
LOWER AFT PANEL	1331652	LOWER	2024-T851	58000	0.125	43374	1.25	0.07	.125-.135
		UPPER	2024-T851	58000	0.07	41264	1.25	0.12	.070-.080
		RIGHT	2024-T851	58000	0.07	39839	1.25	0.16	.070-.080
LOWER RIGHT PANEL	1331650	LOWER	6061-T6	35000	0.1	26502	1.25	0.06	.100-.110
UPPER FRONT PANEL	1331352	LOWER	7075-T6	66000	0.04	43260	1.25	0.22	.040-.060
		UPPER	7075-T6	66000	0.04	<43260	1.25	>.22	.040-.060
		RIGHT	7075-T6	66000	0.04	22730	1.25	1.32	.040-.060
LOWER MOTOR MT PANEL	1331414	LOWER	7075-T6	66000	0.05	39937	1.25	0.32	.050-.060
		TOP	7076-T6	66000	0.05	15947	1.25	2.31	.050-.060
UPPER MOTOR MT PANEL	1331389	LOWER	7075-T6	66000	0.05	33345	1.25	0.58	.050-.060
		RIGHT	7075-T6	66000	0.05	43788	1.25	0.21	.050-.060
		TOP	7075-T6	66000	0.05	<33345	1.25	>0.58	.050-.060
LOWER FRONT PANEL	1331401	LOWER	6061-T6	35000	0.09	24692	1.25	0.13	.090-.100
		UPPER	6061-T6	35000	0.06	24476	1.25	0.14	.060-.070
UPPER AFT PANEL	1331642	LOWER	2024-T851	58000	0.095	41836	1.25	0.11	.095-.105
		UPPER	2024-T851	58000	0.05	37944	1.25	0.22	.050-.060
		SIDE	2024-T851	58000	0.05	43774	1.25	0.06	.050-.060
UPPER RIGHT PANEL	1331651	LOWER	6061-T6	35000	0.06	25894	1.25	0.08	.060-.070
LOWER RIGHT SUPPORT	1331447	LOWER	6061-T6	35000	0.045	23766	1.25	0.18	.045-.055

TABLE 55 A1-EOS PANEL FLANGE ATTACHMENT SCREW STRESS SUMMARY - RANDOM VIBRATION LOADS											
COMPONENT	PART NO.	TYPE	MATRL	FLANGE	F _{tu} PSI	LENGTH IN	NO. BOLTS	FORCE LB/IN	STRESS PSI	FS	MS
UPPER RIGHT FRONT SUPPORT	1331390	NAS1352N06	ALLOY STEEL	LOWER	160000	6.5	3	86.4	20605	1.4	4.55
		NAS1352N06	ALLOY STEEL	AFT	160000	6.2	3	70.65	16072	1.4	6.11
LOWER AFT PANEL	1331652	NAS1352N06	ALLOY STEEL	LOWER	160000	10.563	8	716.4	104119	1.4	0.10
		NAS1352N06	ALLOY STEEL	UPPER	160000	8.498	6	213.39	33267	1.4	2.44
		NAS1352N06	ALLOY STEEL	RIGHT	160000	8.77	7	206.82	28521	1.4	3.01
LOWER RIGHT PANEL	1331650	NAS1352N06	ALLOY STEEL	LOWER	160000	19.29	15	317.64	44963	1.4	1.54
UPPER FRONT PANEL	1331352	NAS1352N06	ALLOY STEEL	LOWER	160000	10.575	7	73.227	12177	1.4	8.39
		NAS1352N06	ALLOY STEEL	UPPER	160000	10.575	7	<73.227	<12.177	1.4	>8.39
		NAS1352N06	ALLOY STEEL	RIGHT	160000	11.5	8	37.665	5960	1.4	18.18
LOWER MOTOR MT PANEL	1331414	NAS1352N06	ALLOY STEEL	LOWER	160000	10.562	6	89.52	17346	1.4	5.59
UPPER MOTOR MT PANEL	1331389	NAS1352N06	ALLOY STEEL	LOWER	160000	10.563	6	76.713	14866	1.4	6.69
		NAS1352N06	ALLOY STEEL	RIGHT	160000	6.245	3	99.525	22804	1.4	4.01
		NAS1352N06	ALLOY STEEL	TOP	160000	10.563	6	<76.713	<14866	1.4	>6.69
LOWER FRONT PANEL	1331401	NAS1352N06	ALLOY STEEL	LOWER	160000	10.563	8	209.49	30446	1.4	2.75
		NAS1352N06	ALLOY STEEL	UPPER	160000	10.288	7	93.741	15165	1.4	6.54
UPPER AFT PANEL	1331642	NAS1352N06	ALLOY STEEL	LOWER	160000	11.7	9	383.49	54875	1.4	1.08
		NAS1352N06	ALLOY STEEL	UPPER	160000	9.8	7	111.12	17124	1.4	5.67
		NAS1352N06	ALLOY STEEL	SIDE	160000	11.6	8	128.721	20544	1.4	4.56
UPPER RIGHT PANEL	1331651	NAS1352N06	ALLOY STEEL	LOWER	160000	8.783	7	128.472	17743	1.4	5.44
LOWER RIGHT SUPPORT	1331447	NAS1352N06	ALLOY STEEL	LOWER	160000	6.5	3	50.532	12051	1.4	8.48

UPPER RIGHT FRONT SUPPORT PANEL LOWER FLANGE

RANDOM Y W/O = 7.1 "1Y" LOADS


EL →	2589	2590	2591	2592	<u>2593</u>	
F _x	4.621	3.734	3.959	3.112	2.596	LB/IN
⇒ F _y	1.098	4.039	1.110	2.190	13.932	"
F _{xy}	4.641	4.917	5.086	4.390	4.710	"
M _x	.02107	.04215	.03439	.0886	.03597	IN-LB/IN
⇒ M _y	.03663	.1092	.1479	.2007	.1321	"
M _{xy}	.00616	.01483	.01294	.00854	.01441	"
V _x	.03292	.01364	.00332	.01937	.01848	LB/IN
⇒ V _y	.05882	.10674	.1473	.1981	.2623	"

$$F_y = 13.932 \text{ LB/IN}$$

$$M_y = .1321 \text{ IN-LB/IN}$$

$$V_y = .2623 \text{ LB/IN}$$


@ EL 2593 CENTROID



$$d = .313$$

$$a = 1.125/2 \text{ TO EL 2593 CENTROID}$$

FLANGE STRESSES



$$F_y = 13.93 \text{ LB/IN}$$

$$M_y = -1321 \text{ IN-LB/IN}$$


$$V_y = .2623 \text{ LB/IN}$$

$$t = .075 \pm .010 \text{ FLANGE}$$

$$d = 1.125/2$$

$$d = .313$$

$$d_2 = .312$$




$$\sum M_z = 0 \quad F_1 (.312) = .2796 + 13.93 (.625)$$

$$F_1 = 28.80 \text{ LB/IN} \quad V_1 = .2623 \text{ LB/IN}$$

$$F_2 = 14.87 \text{ LB/IN}$$

MOMENT
DIAGRAM



FLANGE TENSION (MEMBRANE + BENDING)

$$\textcircled{a} t_{\min} = .065$$

$$S_t = 3.0 \left(\frac{V_1}{.065} + \frac{M_1 (.065/2)}{(.065)^3/12} \right) \quad \text{"3T LOADS"}$$

$$= 3(4 + 6589) = 19776 \text{ PSI}$$

$$MS = \frac{F_{ty}}{1.25 \times S_t} - 1$$

$$= \frac{35000}{(1.25)(19776)} - 1 = +.42$$

$$MS = \frac{F_{tu}}{1.4 \times S_t} - 1$$

$$F_{tu} = 42000 \text{ psi}$$

6061-T651
ALUM

$$= \frac{42000}{1.4(19776)} - 1 = +.52$$

CHECK RANDOM X W/Q=7.1 1T LOADS

EL	2589	2590	2591	2592	2593	
Fy	1.217	1.008	1.254	1.219	7.592	LB/IN
My	.0125	.0411	.0640	.0854	.0576	IN-LB/IN
Vy	.0166	.0412	.0622	.0822	.1161	LB/IN

CHECK RANDOM Z W/Q=7.1 1T LOADS

EL	2589	2590	2591	2592	2593	
Fy	.910	1.334	.739	1.236	6.425	LB/IN
My	.0162	.0485	.0750	.0890	.0552	IN-LB/IN
Vy	.0188	.0481	.0720	.0841	.1053	LB/IN

BOTH RANDOM X & RANDOM Z ARE LESS SEVERE THAN RANDOM Y

$\therefore t = .065$ LOWER FLANGE OK
USING "3T LOADS"

BOLT STRESSES

Report 10381
Addendum 1

AT BOLT LINE

$$F = F_1 = 28.80 \text{ LB/IN}$$
$$V = V_1 = .26 \text{ LB/IN}$$

3 NAS1352NØ6-6 SCREWS IN 6.500 IN

.138-32UNCR-3A HEAT RESISTANT STEEL $F_{tu} = 160 \text{ KSI}$

TOTAL LOAD/BOLT

$$F_B = \frac{6.500}{3} (28.80) = 62.40 \text{ LB}$$

"1 T LOADS"

$$V_B = \frac{6.500}{3} (.26) = .568 \text{ LB}$$

$$S_t = (3) \frac{F_B}{A_s} = (3) \frac{62.40}{.009085} = 20605 \text{ PSI} \quad \text{"3 T STRESS"}$$

$$A_s = \pi/4 (D - .9743/n)^2$$
$$= .009085 \text{ IN}^2$$

$$D = .138$$
$$n = 32$$

$$FS = 1.4$$

$$S_t = 1.4 (20605) = 28847 \text{ PSI}$$

$$r_t = \frac{28847}{160000} = .180$$

$$f_s = \sim 0$$

$$R_t \sim 1.0$$

$$u = \frac{r_t}{R_t} = .180$$

$$MS = \frac{1}{u} - 1 = +4.5$$

WORST LOADED SCREW
UPPER RIGHT SUPPORT
PANEL LOWER FLANGE
"3 T LOADS"

° BOLTS OK ON LOWER FLANGE
USING "3 T LOADS"

UPPER RIGHT FRONT SUPPORT PANEL AFT FLANGE
RANDOM Y W/Q = 7.1 "1" LOADS"


EL →	2589	2594	2599	2604	2609	
⇒ Fx	4.621	.802	.892	6.816	6.555	LB/IN
Fy	1.098	2.716	3.203	2.086	1.288	"
Fxy	4.641	6.023	6.529	7.083	7.736	"
⇒ Mx	.02107	.0570	.0740	.0680	.0317	IN-LB/IN
My	.03663	.0210	.0176	.0258	.0128	"
Mxy	.00616	.0236	.00918	.0117	.0135	"
⇒ Vx	.03292	.0506	.0761	.0681	.0333	LB/IN
Vy	.05388	.0156	.00593	.00680	.0137	"

$$F_x = 6.816 \text{ LB/IN}$$

$$M_x = .0680 \text{ IN-LB/IN}$$

$$V_x = .0681 \text{ LB/IN}$$

@ EL 2604 CENTROID



$$d = .312$$


$$L = .870/2$$

TO ELEM
2604 CENTROID

FLANGE LENGTH 6.200 IN
SCREWS 3

NAS1352N06-6
.138-32UNCA-3A
HEAT-RESISTANT STEEL
W/FTU = 160000 PSI


FLANGE STRESSES



$$\begin{aligned} F_x &= 6.816 \text{ LB/IN} \\ M_x &= .0680 \text{ IN-LB/IN} \\ V_x &= .0681 \text{ LB/IN} \end{aligned}$$

$$t = .065 \text{ MIN FLANGE}$$

$$\begin{aligned} l &= .870/2 \\ a &= .312 \\ d_2 &= .313 \end{aligned}$$




$$\sum m_2 = 0 \quad F_1(.313) = .098 + 6.816(.625)$$

$$F_1 = 13.92 \text{ LB/IN}$$

$$F_2 = 7.11 \text{ LB/IN}$$

$$V_1 = .07 \text{ LB/IN}$$



FLANGE TENSION (MEMB + BEND) @ $t_{min} = .065$

$$S_t = 3 \left[\frac{.07}{.065} + \frac{2.225 (.065/2)}{(.065)^3/12} \right] \quad \text{"3T LOADS"}$$

$$= 3 [1 + 3160]$$

$$= 9482 \text{ PSI}$$

$$MS = \frac{F_{ty}}{1.25 \times S_t} - 1$$

$$F_{ty} = 35000 \text{ PSI}$$

$$= \frac{35000}{1.25(9482)} - 1 = +2.0$$

6061-T6 ALUM
UPPER RIGHT
SUPPORT PANEL
AFT FLANGE
3T LOADS

$$MS = \frac{F_{tu}}{1.4 \times S_t} - 1$$

$$F_{tu} = 42000 \text{ PSI}$$

$$= \frac{42000}{1.4(9482)} - 1 = +2.2$$

6061-T6 ALUM
UPPER RIGHT
SUPPORT PANEL
AFT FLANGE
3T LOADS

$\therefore t = .065$ FLANGES OK
USING "3T LOADS"

CHECK RANDOM X W/Q=7.1 1T LOADS

EL	2589	2594	2599	2604	<u>2609</u>	
F _x	2.509	.741	.914	1.212	11.718	LB/IN
M _x	.0187	.0527	.0706	.0684	.0326	IN-LB/IN
V _x	.0227	.0501	.0658	.0597	.0333	LB/IN

CHECK RANDOM Z W/Q=7.1 1T LOADS

EL	2589	2594	2599	2604	2609	
F _x	1.425	.235	.833	3.688	4.290	LB/IN
M _x	.0166	.0495	.0730	.0626	.0272	IN-LB/IN
V _x	.0200	.0508	.0719	.0608	.0261	LB/IN

RANDOM X W/Q=7.1 @ EL 2609 IS MORE SEVERE THAN RANDOM Y.

CALCULATIONS FOR RANDOM X

FLANGE STRESSES

$$\begin{aligned} F_x &= 11.718 \text{ LB/IN} \\ M_x &= .0326 \text{ IN-LB/IN} \\ V_x &= .0333 \text{ LB/IN} \end{aligned}$$

$$\begin{aligned} F_1 &= [.0326 + (.870/2)(.0333) + 11.718(.625)] / .319 \\ &= 23.55 \text{ LB/IN} \end{aligned}$$

$$F_2 = 11.83 \text{ LB/IN}$$

$$V_1 = .033 \text{ LB/IN}$$

FLANGE TENSION (MEMB + BEND) @ $t_{min} = .065$

$$S_t = 3 \left[\frac{.033}{.065} + \frac{3.703 (.065/2)}{(.065)^{3/12}} \right] \quad 3T \text{ STRESS}$$

$$= 3 [1 + .5259]$$

$$= 15777 \text{ psi}$$

$$MS = \frac{35000}{1.25 \times 15777} - 1 = +.77$$

6061-T6 ALUM
UPPER RIGHT
SUPPORT PANEL
AFT FLANGE
3T STRESS

$$MS = \frac{42000}{1.4 \times 15177} - 1 = +.98$$

3T STRESS

$\therefore t = .065$ AFT FLANGE OK
USING "3T LOADS"

BOLT STRESSES

AT BOLT LINE

$$F = F_1 = 23.55 \text{ LB/IN}$$

$$V = V_1 = .033 \text{ LB/IN}$$

3 SCREWS IN 6.200 IN LENGTH

TOTAL LOAD/SCREW

$$F_B = \frac{6.200}{3} (23.55) = 48.67 \text{ LB}$$

$$V_B = \frac{6.200}{3} (.033) = .07 \text{ LB}$$

"IT LOADS"

$$S_t = (3) \frac{F_B}{A_s} = (3) \frac{48.67}{.009085}$$

"3T STRESS"

$$= 16072 \text{ PSI}$$

$$FS = 1.4$$

$$S_t = 1.4 \times S_t = 22500 \text{ PSI}$$

$$S_s = 1.4 \times S_s \Rightarrow \sim 0$$

$$R_t \sim 1.0$$

$$V_t = \frac{22500}{160000} = .141$$

$$U = \frac{V_t}{R_t} = .141$$

$$MS = \frac{1}{U} - 1 = + 6.1$$

WORST LOADED SCREW
UPPER RIGHT SUPPORT
PANEL AFT FLANGE
"3T LOADS"

∴ BOLTS OK ON AFT FLANGE


USING 3T LOADS

1116	2619	1946	2620	1947	2621	1948	2622	1949	2623	1950
2624 2609 → XEL	1115	1941	2610	1942	2611	1943	2612	1944	2613	2629
2625 2604 → XEL	1114	1936	2605	1937	2606	1938	2607	1939	2608	2630
2626 2599 → XEL	1113	1931	2600	1932	2601	1933	2602	1934	2603	2631
2627 2594 → XEL	1112	1926	2595	1927	2596	1928	2597	1929	2598	2632
2628 2589 → XEL	620 2614	630	2590 → XEL	640	2591 → XEL	650	2592 → XEL	660	2593 → XEL	2633
			2615	640	2616	650	2617	660	2618	670

UPPER RIGHT
FRONT SUPPORT
PANEL

CLEAR
CRASH
GRID

AFT
FLANGE



LOWER FLANGES

LOWER AFT PANEL - LOWER FLANGE
RANDOM Y W/Q=7.1 "1 T LOADS"


EL	575	485	565	
⇒ Fx	118.6	46.61	46.16	LB/IN
Fy	34.32	21.71	21.42	"
Fxy	60.45	27.40	37.79	"
⇒ Mx	.2462	.1311	.2658	IN-LB/IN
My	.0587	.0100	.0917	"
Mxy	.0364	.0159	.0406	"
⇒ Vx	.6860	.1873	.4319	LB/IN
Vy	.4446	.1285	.1806	"

$$F_x = 118.6 \text{ LB/IN}$$

$$M_x = .2462 \text{ IN-LB/IN}$$

$$V_x = .6860 \text{ LB/IN}$$

② EL 575 CENTROID



$$d = .312$$

$$l = 1.131/2 \text{ TO EL 575 CENTROID}$$

FLANGE LENGTH
BOLTS

$$11.188 - .625 = 10.563 \text{ IN}$$

8


NAS1352N06-6

.138-32UNC-3A

HEAT-RESISTANT STEEL

$$W/F_{T_u} = 160000 \text{ PSI}$$

FLANGE STRESSES



$$F_x = 118.6 \text{ LB/IN}$$

$$m_x = .2462 \text{ IN-LB/IN}$$

$$V_x = .686 \text{ LB/IN}$$

$$t = .050 \text{ FLANGE MIN } t$$

$$d = 1.131/2$$


$$d = .312$$

$$d_2 = .313$$

$$\sum M_2 = 0 \quad F_1 (.313) = .634 + 118.6 (.625)$$

$$F_1 = 238.8 \text{ LB/IN} \quad V_1 = .686 \text{ LB/IN}$$

$$F_2 = F_1 - 118.6 = 120.2 \text{ LB/IN}$$



$$m_1 = 37.64 \text{ IN-LB/IN}$$

FLANGE TENSION (MEMBRANE + BENDING)

$$S_t = 3 \left[\frac{V_1}{(.050)} + \frac{m_1 (.050/2)}{\frac{(.050)^3}{12}} \right] \quad \text{"3T LOADS"}$$

$$= 3 [14 + 90330]$$

$$= 271028 \text{ PSI}$$

$$MS = \frac{F_{ty}}{1.25 \times S_t} - 1$$

$$F_{ty} = 35000 \text{ PSI} \quad \begin{array}{l} \text{ALUM} \\ 6061 \\ T651 \end{array}$$

$$= \frac{35000}{(1.25)(271028)} - 1 = -.90 \quad \text{"3T LOADS"}$$

$$MS = \frac{F_{tu}}{1.4 \times S_t} - 1$$

$$F_{tu} = 42000 \text{ PSI}$$

ALUM
6061-T651

$$= \frac{42000}{1.4(271078)} - 1 = -.29$$

CONSIDERABLY OVERSTRESSED

RAISE FLANGE t TO .160, ASSUMING SAME
PLATE ELEMENT LOADS

$$S_t = 3 \left[\frac{.686}{.160} + \frac{37.64(.160/2)}{(.160)^3/12} \right]$$

$$= 3 [4 + 2822]$$

3T LOADS

$$= 26476 \text{ PSI}$$

$$MS = \frac{35000}{1.25(26476)} - 1 = +.06$$

$$t = .160$$

$$MS = \frac{42000}{1.4(26476)} - 1 = +.13$$

$$t = .160$$

\therefore RAISE LOWER FLANGE t TO .160
USING "3T LOADS"

TRY 2024-T851 MAT'RL

$$F_{Ty} = 58000 \text{ psi}$$

$$F_{Tx} = 66000 \text{ psi}$$

RAISE FLANGE t TO .125, WITH 2024-T851

$$S_t = 3 \left[\frac{.686}{.125} + \frac{37.64(6)}{(.125)^2} \right]$$

3T LOADS

$$= 3 [5 + 14453]$$

$$= 43374 \text{ psi}$$

$$MS = \frac{58000}{1.25(43374)} - 1 = +.07$$

$t = .125$

$$MS = \frac{66000}{1.4(43374)} - 1 = +.09$$

$t = .125$

\therefore RAISE LOWER FLANGE t TO .125

USING "3T LOADS" & 2024-T851

BOLT STRESSES

Report 10381
Addendum 1

AT BOLT LINE

$$F = F_1 = 238.8 \text{ LB/IN}$$

$$V = V_1 = .686 \text{ LB/IN}$$

8 BOLTS IN 10.563 IN

TOTAL LOAD/BOLT

$$F_B = \frac{10.563}{8} (238.8) = 315.3 \text{ LB}$$

$$V_B = \frac{10.563}{8} (.686) = .91 \text{ LB}$$

"1T LOADS"

AT 3T LOADS

$$S_t = 3 \frac{F_B}{A_s} = \frac{(3)(315.3)}{(.009085)} = 104119 \text{ PSI}$$

$$S_s = 3 \frac{V_B}{A_s} = 300 \text{ PSI}$$

WITH FS=1.4

$$S_t = 1.4 \times S_t = 145767 \text{ PSI}$$

$$v_t = \frac{145767}{160000} = .911$$

$$S_s \Rightarrow 0$$

$$R_t \sim 1.0$$

$$u = \frac{v_t}{R_t} = .911$$

$$MS = \frac{1}{u} - 1 = +.10$$

WORST LOADED SUBW
LOWER AFT PANEL
LOWER FLANGE
3T LOADS

•• BOLTS OK ON LOWER FLANGE
USING 3T LOADS

CHECK RANDOM X W/Q=7.1 1 T LOADS				
EL	575	485	565	
Fx	52.82	38.07	27.41	LB/IN
Mx	.1612	.1444	.2315	IN-LB/IN
Vx	.5458	.2074	.4429	LB/IN

RANDOM X IS LESS SEVERE THAN RANDOM Y

CHECK RANDOM Z W/Q=7.1 1 T LOADS				
EL	575	485	565	
Fx	52.01	16.81	20.57	LB/IN
Mx	.1332	.0796	.2137	IN-LB/IN
Vx	.5411	.1164	.4207	LB/IN

RANDOM Z IS LESS SEVERE THAN RANDOM Y

LOWER AFT PANEL - UPPER FLANGE

RANDOM Y W/Q=7.1 1 T LOADS

	EL	584	574	494	504	
⇒ Fx		25.68	19.54	15.37	5.31	LB/IN
Fy		4.12	1.75	2.16	3.08	"
Fxy		11.37	16.15	18.90	26.64	"
⇒ Mx		.1125	.1217	.0633	.0698	IN-LB/IN
My		.0369	.0425	.0213	.0219	"
Mxy		.0352	.0228	.0122	.0128	"
⇒ Vx		.4756	.1985	.1114	.1057	LB/IN
Vy		.0768	.0567	.0177	.0401	"


RANDOM X W/Q=7.1 1 T LOADS

	EL	584	574	<u>494</u>	504	
⇒ Fx		29.08	15.16	35.24	12.09	LB/IN
Fy		7.19	3.98	8.71	2.45	"
Fxy		7.96	7.53	4.00	6.80	"
⇒ Mx		.1832	.2635	.1548	.2691	IN-LB/IN
My		.0381	.0773	.0282	.1058	"
Mxy		.0470	.0583	.0426	.0779	"
⇒ Vx		.7046	.4163	.2452	.2856	LB/IN
Vy		.1224	.1897	.0763	.0891	"

RANDOM Z W/Q=7.1 1 T LOADS

	EL	584	574	494	504	
⇒ Fx		18.27	11.92	17.11	6.79	LB/IN
Fy		3.86	2.46	3.88	1.51	"
Fxy		3.84	5.79	5.17	5.91	"
⇒ Mx		.0760	.1518	.0786	.1646	IN-LB/IN
My		.0168	.0504	.0310	.0606	"
Mxy		.0391	.0481	.0256	.0443	"
⇒ Vx		.3119	.1973	.0962	.1630	LB/IN
Vy		.2010	.1088	.0686	.0243	"

BASE UPPER FLANGE ANALYSIS ON EL 494
RANDOM X W/Q=7.1




$$\begin{aligned} F_x &= 35.24 \text{ LB/IN} \\ M_x &= .1548 \text{ IN-LB/IN} \\ V_x &= .2452 \text{ LB/IN} \end{aligned}$$

$$t = .050 \text{ FLANGE MIN } t$$

$$\begin{aligned} l &= .675/2 \\ d &= .312 \\ d_2 &= .313 \end{aligned}$$

6 SCREWS IN 8.498 INCHES




$$\sum M_2 = 0 \quad F_1 (.313) = .238 + 35.24 (.625)$$

$$F_1 = 71.13 \text{ LB/IN}$$

$$F_2 = 35.89 \text{ LB/IN}$$

$$V_1 = .245 \text{ LB/IN}$$

MOMENT
DIAGRAM



FLANGE TENSION (MEMBRANE + BENDING) @ $t = .050$

$$\begin{aligned} S_t &= 3 \left[\frac{.245}{.050} + \frac{11.23 (.050/2)}{(.050)^3/12} \right] \text{ "3 LOADS"} \\ &= 3 [5 + 26952] \\ &= 80871 \text{ PSI} \end{aligned}$$

$$MS = \frac{F_{ty}}{1.25 \times S_t} - 1 = \frac{35000}{1.25(80871)} - 1 = -.65$$

$$MS = \frac{F_{su}}{1.4 \times S_t} - 1 = \frac{42000}{1.4 (80871)} - 1 = -.63$$

6061-T651
ALUM

∴ UPPER FLANGE BAD @ $t = .055$

RAISE FLANGE MIN t TO .085 IN

$$S_t = 3 \left[\frac{.245}{.085} + \frac{6 (11.23)}{(.085)^2} \right]$$

$$= 3 [3 + 9326]$$

3 ∇ LOADS

$$= 27987 \text{ PSI}$$

$$MS = \frac{35000}{1.25 (27987)} - 1 = +.0004$$

$t = .085$

$$MS = \frac{42000}{1.4 (27987)} - 1 = +.07$$

$t = .085$

∴ RAISE UPPER FLANGE t TO .085 MIN

USING 3 ∇ LOADS

TRY 2024-T851

RAISE MIN FLANGE t TO .070, WITH 2024-T851

$$S_t = 3 \left[\frac{.245}{.070} + \frac{6(11.23)}{(.070)^2} \right]$$

$$= 3 [4 + 13751]$$

3T LOADS

$$= 41264 \text{ psi}$$

$$MS = \frac{58000}{1.25(41264)} - 1 = +.12$$

$$t = .070$$

$$MS = \frac{66000}{1.4(41264)} - 1 = +.14$$

$$t = .070$$

∴ RAISE UPPER FLANGE t TO .070

USING 3T LOADS & 2024-T851

BOLT STRESSES

AT BOLT LINE

$$F = F_1 = 71.13 \text{ LB/IN}$$

$$V = V_1 = .245 \text{ LB/IN}$$

6 BOLTS IN 8.498 INCHES

TOTAL FORCE/BOLT

$$F_B = \frac{8.498}{6} (71.13) = 100.7 \text{ LB}$$

$$V_B = \frac{8.498}{6} (.245) = .35 \text{ LB}$$

1 T LOADS

AT 3 T LOADS

$$S_t = 3 \frac{F_B}{A_s} = \frac{3(100.7)}{.009085} = 33267 \text{ PSI}$$

$$S_s = \frac{3V_B}{A_s} = 115 \text{ PSI}$$

WITH $F_S = 1.4$

$$S_t = 1.4 \times S_t = 46573 \text{ PSI}$$

$$r_t = \frac{46573}{160000} = .291$$

$$f_s = 70$$

$$R_t \sim 1.0$$

$$u = \frac{r_t}{R_t} = .291$$

$$MS = \frac{1}{u} - 1 = +2.4$$

WORST LOADED SCREW
LOWER AFT PANEL
UPPER FLANGE
3 T LOADS

∴ BOLTS OK ON UPPER FLANGE

USING 3 T LOADS

LOWER ART PANEL - RIGHT FLANGE

Report 10381
Addendum 1

RANDOM Y $w/Q=7.1$ 1 T LOADS

EL	575	576	584	583	
F _y	34.32	3.051	4.12	1.28	LB/IN
M _y	.0587	.1880	.0369	.0624	IN-LB/IN
V _y	.4446	.4108	.0768	.1904	LB/IN


RANDOM X $w/Q=7.1$ 1 T LOADS

EL	575	576	584	583	
F _y	13.26	.430	7.19	2.31	LB/IN
M _y	.0258	.1484	.0381	.1056	IN-LB/IN
V _y	.0302	.3042	.1224	.3321	LB/IN

RANDOM Z $w/Q=7.1$ 1 T LOADS

EL	575	576	584	583	
F _y	20.48	1.54	3.26	.863	LB/IN
M _y	.0515	.0978	.0168	.0836	IN-LB/IN
V _y	.2260	.2551	.2010	.1588	LB/IN

BASE RIGHT FLANGE ANALYSIS ON EL 575
RANDOM Y $w/Q=7.1$



$$F_y = 34.32 \text{ LB/IN}$$

$$M_y = .0587 \text{ IN-LB/IN}$$

$$V_y = .4446 \text{ LB/IN}$$


$t = .050$ FLANGE MINIMUM

$$d = .312/2$$

$$d = .312$$

$$d_2 = .313$$

7 SCREWS IN 8.77 IN




$$\sum M_z = 0 \quad F_1(.313) = .128 + 34.32(.625)$$

$$F_1 = 68.94 \text{ LB/IN}$$

$$F_2 = 34.62 \text{ LB/IN}$$

$$V_1 = .445 \text{ LB/IN}$$



FLANGE TENSION (MEMBRANE + BENDING) @ $t = .050$

$$\begin{aligned} S_t &= 3 \left[\frac{.445}{.050} + \frac{10.84 (.050/2)}{(.050)^{3/2}} \right] \\ &= 3 [9 + 26016] \\ &= 78075 \text{ PSI} \end{aligned}$$

3T LOADS

$$MS = \frac{F_{tv}}{1.25 \times S_t} - 1$$

$$= \frac{35000}{1.25 (78075)} - 1 = -.64$$

6061-T651
ALUM

$$MS = \frac{F_{tu}}{1.4 \times S_t} - 1$$

$$= \frac{42000}{1.4 (78075)} - 1 = -.62$$

6061-T651
ALUM

RIGHT FLANGE BAD @ $t = .050$

RAISE FLANGE MIN t TO .085 IN

$$S_t = 3 \left[\frac{.445}{.085} + \frac{6(10.84)}{(.085)^2} \right] \quad 3T \text{ LOADS}$$

$$= 27022 \text{ PSI}$$

$$MS = \frac{35000}{1.25(27022)} - 1 = +.04 \quad t = .085$$

$$MS = \frac{42000}{1.4(27022)} - 1 = +.11 \quad t = .085$$

∴ RAISE RIGHT FLANGE t TO .085 MIN
USING 3T LOADS

2024-T851

USE t MIN OF .070 IN

$$S_t = 3 \left[\frac{.445}{.070} + \frac{6(10.84)}{(.070)^2} \right] = 39839 \text{ PSI}$$

$$MS = \frac{58000}{1.25(39839)} - 1 = +.16 \quad t = .070$$

$$MS = \frac{66000}{1.4(39839)} - 1 = +.18 \quad t = .070$$

∴ RAISE RIGHT FLANGE t TO .070 MIN
USING 3T LOADS & 2024-T851

BOLT STRESSES

Report 10381
Addendum 1

AT BOLT LINE

$$F = F_1 = 68.94 \text{ LB/IN}$$

$$V = V_1 = .445 \text{ LB/IN}$$

7 BOLTS IN 8.77 INCHES

TOTAL LOAD/BOLT

$$F_B = \frac{8.77}{7} (68.94) = 86.37 \text{ LB}$$

$$V_B = \frac{8.77}{7} (.445) = .558 \text{ LB}$$

1 T LOADS

AT 3 T LOADS

$$S_t = 3 \frac{F_B}{A_s} = \frac{(3)(86.37)}{.009085} = 28521 \text{ PSI}$$

$$S_s = 3 \frac{V_B}{A_s} = 184 \text{ PSI}$$

WITH FS=1.4

$$S_t = 1.4 \times 28521 = 39929 \text{ PSI}$$

$$r_t = \frac{39929}{160000} = .250$$

$$f_s = 70$$

$$R_t \sim 1.0$$

$$u = \frac{r_t}{R_t} = .250$$

$$MS = \frac{1}{u} - 1 = +3.0$$

WORST LOADED SCREW
LOWER AFT PANEL
RIGHT FLANGE
3 T LOADS

∴ BOLTS OK ON RIGHT FLANGE
USING 3 T LOADS

UPPER FLANGE

LOWER AFT PANEL
QUAD, TRI

LEFT
FLANGE

584	574	564	554	544	534	524	514	504	494
583	573	563	553	543	533	523	513	503	493
582	572	562	552	542	532	522	512	502	492
581	571	561	551	541	531	521	511	501	491
580	570	560	550	540	530	520	510	500	490
579	569	559	549	539	529	519	509	499	489
578	568	558	548	538	528	518	508	498	488
577	567	557	547	537	527	517	507	497	487
576	566	556	546	536	526	516	506	496	486
575	565	555	545	535	525	515	505	495	485

LOWER FLANGE

RIGHT
FLANGE



LOWER RIGHT PANEL - LOWER FLANGE

RANDOM Y W/Q = 7.1 1T LOADS

EL	630	760	
Fx	46.95	38.80	LB/IN
Fy	15.03	3.41	"
Fxy	3.13	4.40	"
Mx	.0463	.0615	IN-LB/IN
My	.0346	.0675	"
Mxy	.0241	.0133	"
Vx	.215	.274	LB/IN
Vy	.457	.115	"

BOTH ELEMENTS HAVE SKEWED "ELEMENT X & Y" DIRECTIONS, ROTATING COMPONENTS TO HAVE "ELEM X" NORMAL TO FLANGE,

EL 630



$$\tan \theta = \frac{\Delta Z}{\Delta X} = \frac{1.131}{.438}$$

$$\theta = 68.8^\circ$$

X_{EL} SKEWED +10.6°





$$\begin{aligned} F_x' &= \frac{F_x + F_y}{2} + \frac{F_x - F_y}{2} \cos 2\gamma + F_{xy} \sin 2\gamma \\ &= \frac{46.95 + 15.03}{2} + \frac{46.95 - 15.03}{2} \cos[2(10.6)] + 3.13 \sin[2(10.6)] \\ &= 47.00 \text{ LB/IN} \end{aligned}$$

LIKEWISE $M_x' = .055 \text{ IN-LB/IN}$

EL 760

$$\begin{aligned} \gamma &= 12.0^\circ \\ \beta &= 32.4^\circ \end{aligned}$$

$$X_{EL} @ 32.4^\circ - \left(\frac{12.0 + 32.4}{2} \right) = 10.2^\circ$$



FOR $\theta = -10.2^\circ$

$$\begin{aligned} F_x' &= \frac{F_x + F_y}{2} + \frac{F_x - F_y}{2} \cos 2\theta + F_{xy} \sin 2\theta \\ &= 36.16 \text{ LB/IN} \end{aligned}$$

$$M_x' = .065 \text{ IN-LB/IN}$$

RANDOM Y $w/Q = 7.1$ 1 T LOADS

EL	630	760	
F_x'	47.00	36.16	LB/IN
M_x'	.055	.065	IN-LB/IN
V_x	.215	.274	LB/IN

RANDOM X $w/Q = 7.1$ 1 T LOADS


EL	630	760	
F_x'	23.65	16.00	LB/IN
M_x'	.0073	.0124	IN-LB/IN
V_x	.0607	.0699	LB/IN

RANDOM Z $w/Q = 7.1$

EL	630	760	1 T LOADS
F_x'	26.47	21.98	LB/IN
M_x'	.0142	.0206	IN-LB/IN
V_x	.137	.0521	LB/IN


$$\begin{aligned} F_x' &= 47.00 \text{ LB/IN} \\ M_x' &= .055 \text{ IN-LB/IN} \\ V_x &= .215 \text{ LB/IN} \end{aligned}$$

FLANGE STRESSES



$$\begin{aligned} l &= 1.331/2 \\ d &= .312 \\ d_2 &= .250 \end{aligned}$$

$$t = .040 \text{ FLANGE MIN } t$$




$$\sum M_2 = 0 \quad F_1 (.250) = 47.00 (.562) + .055$$

$$F_1 = 105.88 \text{ LB/IN}$$

$$F_2 = 58.88 \text{ LB/IN}$$

$$V_1 = .215 \text{ LB/IN}$$



FLANGE TENSION (MEMBER + BEND) @ $t_{\min} = .040$

$$S_t = 3 \left[\frac{V_1}{t} + \frac{6M_1}{t^2} \right] = 3 \left[\frac{.215}{.040} + \frac{6(14.72)}{(.040)^2} \right]$$

$$= 3 [5 + 55200]$$

$$= 165616 \text{ PSI}$$

37 LOADS

MAT'L 6061-T651

$$F_{ty} = 35000 \text{ psi}$$

$$F_{tu} = 42000 \text{ psi}$$

$$MS = \frac{F_{ty}}{1.25 S_t} - 1$$

$$= \frac{35000}{1.25 (165616)} - 1 = -1.83$$

$$MS = \frac{F_{tu}}{1.4 S_t} - 1$$

$$= \frac{42000}{1.4 (165616)} - 1 = -0.82$$

OVERSTRESSED

RAISE FLANGE TO $t = .100$

$$S_t = 3 \left[\frac{.215}{.100} + \frac{6(14.72)}{(.100)^2} \right]$$

$$= 3 [2 + 8832] = 26502 \text{ psi}$$

$$MS = \frac{35000}{1.25 (26502)} - 1 = +.06 \quad t = .100$$

$$MS = \frac{42000}{1.40 (26502)} - 1 = +.13 \quad t = .100$$

∴ RAISE LOWER FLANGE TO $t = .100$ MIN

USING 3σ LOADS

BOLT STRESSES

AT BOLT

Report 10381
Addendum 1

$$F = F_1 = 105.88 \text{ LB/IN}$$

$$V = V_1 = .215 \text{ LB/IN}$$

15 BOLTS IN 19.29 INCHES

TOTAL LOAD / BOLT

$$F_B = 105.88 \left(\frac{19.29}{15} \right) = 136.2 \text{ LB}$$

$$V_B = .215 \left(\frac{19.29}{15} \right) = .28 \text{ LB}$$

1 T LOADS

BOLTS ARE NAS1352N06-6, $F_{tu} = 160000 \text{ psi}$

$$S_t = 3 \frac{F_B}{A_s} = 3 \frac{136.2}{.009085} = 44963 \text{ psi}$$

3 T LOADS

$$S_s = 3 \frac{V_B}{A_s} = 3 \frac{.28}{.009085} = 96 \text{ psi}$$

$$S_t = 1.4 \times 44963 = 62948 \text{ psi}$$

$$r_t = \frac{62948}{160000} = .393$$

$$S_s = 1.4 \times 96 = 134 \text{ psi}$$

$$r_s = \frac{134}{(6)(160000)} = .0014 \approx 0$$

$$R_t \sim 1.0$$

$$u = \frac{r_t}{R_t} = .393$$

$$MS = \frac{1}{u} - 1 = +2.5$$

WORST LOADED BOLT
LOWER RIGHT PANEL
LOWER FLANGE
3 T LOADS

∴ BOLTS OK ON LOWER FLANGE

USING 3 T LOADS

LOWER RIGHT PANEL - QUAD, TRI

639	649	659	669	679	689	699	709	719	729	739	749	759	769
638	648	658	668	678	688	698	708	718	728	738	748	758	768
637	647	657	667	677	687	697	707	717	727	737	747	757	767
636	646	656	666	676	686	696	706	716	726	736	746	756	766
635	645	655	665	675	685	695	705	715	725	735	745	755	765
634	644	654	664	674	684	694	704	714	724	734	744	754	764
633	643	653	663	673	683	693	703	713	723	733	743	753	763
632	642	652	662	672	682	692	702	712	722	732	742	752	762
631	641	651	661	671	681	691	701	711	721	731	741	751	761
630	640	650	660	670	680	690	700	710	720	730	740	750	760

UPPER FRONT PANEL - LOWER FLANGE

Report 10381
Addendum 1

RANDOM Y W/Q = 7.1 1 T LOADS.

EL	1652	1688	1760	1772	
Fx	12.125	12.561	10.33	10.083	LB/IN
Fy	5.468	15.213	5.625	2.575	"
Fxy	25.484	4.632	15.964	16.360	"
Mx	.0323	.0339	.0284	.0143	IN-LB/IN
My	.0213	.0257	.0256	.0155	"
Mxy	.0294	.0174	.0159	.0098	"
Vx	.0525	.0567	.0414	.0201	LB/IN
Vy	.3029	.0785	.0554	.0670	"



RANDOM X W/Q = 7.1 1 T LOADS

EL	1652	1688	1772	
Fx	8.903	4.143	3.228	LB/IN
Fy	2.235	4.422	.633	"
Fxy	6.105	2.256	4.193	"
Mx	.0179	.0405	.0256	IN-LB/IN
My	.0177	.0497	.0330	"
Mxy	.0189	.0223	.0165	"
Vx	.0367	.0688	.0243	LB/IN
Vy	.2350	.1797	.0733	"

RANDOM Z W/Q = 7.1 1 T LOADS

EL	1652	1688	1772	
Fx	5.525	4.268	4.607	LB/IN
Fy	1.698	5.029	1.600	"
Fxy	7.941	1.268	7.040	"
Mx	.0100	.0368	.0180	IN-LB/IN
My	.0094	.0411	.0242	"
Mxy	.0110	.0212	.0113	"
Vx	.0197	.0485	.0187	LB/IN
Vy	.1175	.1513	.0581	"


WORST CONDITION IS RANDOM Y @ EL 1652 WORST LOCATION.
EL 1688 HAS SKEWED "ELEMENT X & Y" DIRECTIONS.
ROTATING COMPONENTS TO HAVE "ELEM X" NORMAL
TO LOWER FLANGE IS LESS SEVERE THAN EL 1652



$$\tan \psi = \frac{\Delta z}{\Delta y} = \frac{1.125}{.746}$$

$$\psi = 56.5^\circ$$

$$90 - \psi = 33.5^\circ$$



$$\theta = -33.5^\circ$$

$$F_x' = \frac{F_x + F_y}{2} + \frac{F_x - F_y}{2} \cos 2\theta + F_{xy} \sin 2\theta$$

$$= 13.887 + (-1.326)(.3907) + (4.032)(-.9205) = 9.657$$

LB/IN

\therefore EL 1652 WORST CASE


EL 1652

$$F_x = 12.125 \text{ LB/IN}$$

$$M_x = .0323 \text{ IN-LB/IN}$$

$$V_x = .0525 \text{ LB/IN}$$

FLANGE STRESSES




$$J = 1.125/2$$

$$d = .312$$

$$d_2 = .313$$

$t = .040$ FLANGE
MINIMUM



$$\sum M_2 = 0$$


$$F_1(.313) = 12.125(.625)$$

$$+ .0618$$

$$= 24.409 \text{ LB/IN}$$

$$F_2 = 12.284 \text{ LB/IN}$$

MOMENT
DIAGRAM



Report 10381
Addendum 1

FLANGE TENSION (MEMB + BEND) @ $t_{min} = .040$

$$S_t = 3 \left[\frac{V_1}{t} + \frac{6M_1}{t^2} \right]$$

$$= 3 \left[\frac{.0525}{.040} + \frac{6(3.845)}{(.040)^2} \right]$$

3 ∇ LOADS

$$= 3 [1 + 14419]$$

$$= 43260 \text{ PSI}$$

MAT'L 7075-T651

$$F_{ty} = 66000 \text{ PSI}$$

$$F_{tu} = 75000 \text{ PSI}$$

$$MS = \frac{F_{ty}}{1.25 \times S_t} - 1 = \frac{66000}{1.25(43260)} - 1 = +.22$$

$$MS = \frac{F_{tu}}{1.4 \times S_t} - 1 = \frac{75000}{1.4(43260)} - 1 = +.24$$

\therefore LOWER FLANGE OK @ $t = .040$

USING 3 ∇ LOADS

BOLT STRESSES

$$\text{AT BOLT } F = F_1 = 24.409 \text{ LB/IN}$$

$$V = V_1 = .0525 \text{ LB/IN}$$

$$7 \text{ BOLTS IN } 11.200 - .625 = 10.575 \text{ IN}$$

TOTAL LOAD/BOLT , 1 ∇ LOADS

$$F_b = \frac{10.575}{7} (24.409) = 36.875 \text{ LB}$$

$$V_b = \frac{10.575}{7} (.0525) = .08 \text{ LB}$$

BOLTS ARE NAS1352 ND6-6, $F_{tu} = 160000 \text{ PSI}$

② 3T LOADS

$$S_t = 3 \frac{F_B}{A_s} = 3 \left(\frac{36,875}{.009085} \right) = 12177 \text{ psi}$$

$$S_s = 3 \frac{V_B}{A_s} = 3 \left(\frac{.08}{.009085} \right) = 27 \text{ psi}$$

3T LOADS

$$w/ FS = 1.4$$

$$S_t = 1.4 \times 12177 = 17048 \text{ psi}$$

$$v_t = \frac{17048}{160000} = .107$$

$$S_s = 1.4 \times 27 = 38 \text{ psi}$$

$$v_s = \frac{38}{(16)(160000)} = .0004 \approx 0$$

$$R_t \sim 1.0$$

$$u = \frac{v_t}{R_t} = .107$$

$$MS = \frac{1}{u} - 1 = + 8.3$$

WORST LOADED BOLT
UPPER FRONT PANEL
LOWER FLANGE

∴ BOLTS OK ON LOWER FLANGE
USING 3T LOADS

UPPER FRONT PANEL - UPPER FLANGE

Report 10381
Addendum 1

RANDOM Y w/Q=7.1 1 T LOADS

EL	1663	1783	
Fx	1.483	1.172	LB/IN
Mx	.0348	.0072	IN-LB/IN
Vx	.0102	.0001	LB/IN

RANDOM X w/Q=7.1 1 T LOADS

EL	1663	1783	
Fx	1.759	.905	LB/IN
Mx	.0101	.0199	IN-LB/IN
Vx	.0282	.0165	LB/IN

RANDOM Z w/Q=7.1 1 T LOADS

EL	1663	1711	1723	1783	
Fx	2.000	2.063	2.086	.820	LB/IN
Mx	.0048	.1248	.1618	.0121	IN-LB/IN
Vx	.0182	.1522	.1611	.0159	LB/IN

WORST LOAD IS FOR RANDOM Z @ EL 1723

COMPARE EL 1723 TO LOWER FLANGE EL 1652

$$EL\ 1723 < EL\ 1652$$

∴ UPPER FLANGE OK @ $t = .50$

$$\begin{aligned} MS &> +.22 && \text{LIMIT} \\ &> +.24 && \text{ULT} \end{aligned}$$

PER 3T LOADS

∴ UPPER FLANGE BOLTS OK

$$MS > 8.3 \quad \text{ULT}$$

PER 3T LOADS

UPPER FRONT PANEL - RIGHT FLANGE

Report 10381
Addendum 1

RANDOM Y W/Q=7.1 1 T LOADS

EL	1652	1653	
Fy	5.468	6.116	LB/IN
My	.0213	.0277	IN-LB/IN
Vy	.3029	.6723	LB/IN

RANDOM X W/Q=7.1 1 T LOADS


EL	1652	1653	1655	1656	
Fy	2.235	2.374	3.592	3.589	LB/IN
My	.0177	.0371	.1664	.2256	IN-LB/IN
Vy	.2350	.5163	1.081	1.711	LB/IN

RANDOM Z W/Q=7.1 1 T LOADS

EL	1652	1653	
Fy	1.698	2.492	LB/IN
My	.0094	.0207	IN-LB/IN
Vy	.1175	.2337	LB/IN

WORST CASE IS EL 1653 RANDOM Y

$$\begin{aligned} F_y &= 6.116 \text{ LB/IN} \\ M_y &= .0277 \text{ IN-LB/IN} \\ V_y &= .6723 \text{ LB/IN} \end{aligned}$$



$$\begin{aligned} l &= .937/2 \\ d &= .312 \\ d_2 &= .313 \end{aligned}$$

FLANGE $b = .040 \text{ IN MIN}$

$$\Sigma M_2 = 0 \quad F_1(.313) = 6.116(.625) + .343$$


Report 10381
Addendum 1

$$F_1 = 12.555 \text{ LB/IN}$$

$$F_2 = 6.439 \text{ LB/IN}$$

$$V_1 = .672 \text{ LB/IN}$$

MOMENT
DIAGRAM



FLANGE TENSION (MEMB + BEND) @ $t = .040$

$$S_t = 3 \left[\frac{V_1}{t} + \frac{6M_1}{t^2} \right]$$

3T LOADS

$$= 3 \left[\frac{.672}{.040} + \frac{6(2.016)}{(.040)^2} \right]$$

$$= 3 [17 + 7560] = 22730 \text{ PSI}$$

$$MS = \frac{F_{tu}}{1.25 \times S_t} - 1$$

$$= \frac{66000}{1.25(22730)} - 1 = +1.3$$

$$MS = \frac{F_{tu}}{1.4 \times S_t} - 1$$

$$= \frac{75000}{1.4(22730)} - 1 = +1.4$$

∴ RIGHT FLANGE OK @ $t = .040$
USING 3T LOADS

BOLT STRESSES

AT BOLT

$$F = F_1 = 12.555 \text{ LB/IN}$$

$$V = V_1 = .672 \text{ LB/IN}$$

$$8 \text{ BOLTS IN } 12.500 - 1.000 = 11.500 \text{ IN}$$

TOTAL LOAD / BOLT

$$F_B = \left(\frac{11,500}{8} \right) (12.555) = 18.05 \text{ LB}$$

$$V_B = \left(\frac{11,500}{8} \right) (.672) = .97 \text{ LB}$$

1 T LOADS

BOLTS ARE NAS1352N06-6, $F_{tu} = 160,000 \text{ psi}$

$$S_t = 3 \frac{F_B}{A_s} = 3 \frac{18.05}{.009085} = 5960 \text{ psi}$$

3 T LOADS

$$S_s = 3 \frac{V_B}{A_s} = 3 \frac{.97}{.009085} = 317 \text{ psi}$$

$$S_t = 1.4 \times 5960 = 8345 \text{ psi}$$

$$r_t = \frac{8345}{160000} = .052$$

$$S_s = 1.4 \times 317 = 443 \text{ psi}$$

$$r_s = \frac{443}{(.6)(160000)} = .005 \approx 0$$

$$R_t \sim 1.0$$


$$u = \frac{r_t}{R_t} = .052$$

$$MS = \frac{1}{u} - 1 = +18$$

WORST LOADED BOLT
UPPER FRONT PANEL
RIGHT FLANGE
3 T LOADS

∴ BOLTS OK ON RIGHT FLANGE
WITH 3T LOADS

UPPER FRONT PANEL
QUAD, TRI



LOWER MOTOR MOUNT PANEL - LOWER FLANGE

RANDOM Y W/Q=7.1 1 T LOADS

EL	2810	<u>2812</u> *	2813	2819	
Fy	4.904	17.18	7.542	4.094	LB/IN
My	.0241	.114	.1022	.0086	IN-LB/IN
Vy	.0490	.0958	.0516	.0229	LB/IN



RANDOM X W/Q=7.1 1 T LOADS

EL	2810	2811	2812*	2813	2817	
Fy	2.608	5.970	15.47	7.311	7.513	LB/IN
My	.0220	.0116	.090	.0735	.0463	IN-LB/IN
Vy	.0536	.1363	.1235	.1165	.1143	LB/IN

RANDOM Z W/Q=7.1 1 T LOADS

EL	2810	2812*	2813	2816	
Fy	2.227	4.82	4.826	4.132	LB/IN
My	.0098	.178	.0913	.1370	IN-LB/IN
Vy	.0184	.1373	.0374	.1197	LB/IN

* EL 2812 HAS SKEWED "ELEMENT X & Y" DIRECTIONS
ROTATING COMPONENTS TO HAVE "ELEM X" NORMAL
TO FLANGE



$$\tan \theta = \frac{\Delta Z}{\Delta Y} = \frac{1.131}{.811}$$

$$\theta = 54.4^\circ$$

$$90 - \theta = 35.6^\circ = \gamma$$



RANDOM Y - EL 2812

$$F_x' = \frac{F_x + F_y}{2} + \frac{F_x - F_y}{2} \cos 2\gamma + F_{xy} \sin 2\gamma$$

$$= \frac{10.83 + 12.66}{2} + \frac{10.83 - 12.66}{2} \cos 71.2^\circ + 6.36 \sin 71.2^\circ$$

$$= 17.18 \text{ LB/IN}$$

$$m_x' = \frac{.0847 + .0453}{2} + \frac{.0847 - .0453}{2} \cos 71.2^\circ + .0384 \sin 71.2^\circ$$

$$= .114 \text{ IN-LB/IN}$$

$$V_x' = V_x = .0958 \text{ LB/IN}$$

RANDOM X - EL 2812

$$F_x' = \frac{7.827 + 14.811}{2} + \frac{7.827 - 14.811}{2} \cos 71.2^\circ + 6.76 \sin 71.2^\circ$$

$$= 15.47 \text{ LB/IN}$$

$$m_x' = \frac{.0605 + .0666}{2} + \frac{.0605 - .0666}{2} \cos 71.2^\circ + .0295 \sin 71.2^\circ$$

$$= .090 \text{ IN-LB/IN}$$

$$V_x' = V_x = .1235 \text{ LB/IN}$$

RANDOM Z - EL 2812

$$F_x' = \frac{3.899 + 3.049}{2} + \frac{3.899 - 3.049}{2} \cos 71.2^\circ + 1.133 \sin 71.2^\circ$$

$$= 4.82 \text{ LB/IN}$$

$$m_x' = \frac{.1242 + .1046}{2} + \frac{.1242 - .1046}{2} \cos 71.2^\circ + .0643 \sin 71.2^\circ$$


$$= .178 \text{ IN-LB/IN}$$

$$V_x' = V_x = .1373 \text{ LB/IN}$$

WORST CASE IS RANDOM Y @ EL 2812

$$\begin{aligned}F_x' &= 17.18 \text{ LB/IN} \\m_x' &= .114 \text{ IN-LB/IN} \\V_x' &= .0958 \text{ LB/IN}\end{aligned}$$

FLANGE STRESSES



$$\begin{aligned}l &= \frac{2}{3}(1.131) = .754 \\d &= .312 \\d_2 &= .438\end{aligned}$$

$t = .050$ FLANGE MINIMUM

$$\sum M_2 = 0 \quad F_1(.438) = 17.18(.750) + .186$$

$$F_1 = 29.84 \text{ LB/IN}$$

$$F_2 = 12.66 \text{ LB/IN}$$

$$V_1 = .096 \text{ LB/IN}$$

MOMENT DIAGRAM



FLANGE TENSION (MEMB + BEND) @ $t = .050$ MIN

$$\begin{aligned}S_t &= 3 \left[\frac{V_1}{t} + \frac{6m_1}{t^2} \right] = 3 \left[\frac{.096}{.050} + \frac{6(5.546)}{(.050)^2} \right] \\&= 3 [2 + 13310] \\&= 39937 \text{ PSI}\end{aligned}$$

3 T LOADS

MAT'L 7075-T651

$$F_{Ty} = 66000 \text{ PSI}$$

$$F_{Tu} = 75000 \text{ PSI}$$

W/Fs = 1.25 LIMIT, 1.4 ULTIMATE

$$MS = \frac{F_{ty}}{1.25 \times S_t} - 1$$

$$= \frac{66000}{1.25(39937)} - 1 = +.32$$

$$MS = \frac{F_{tu}}{1.40 \times S_t} - 1 =$$

$$= \frac{75000}{1.40(39937)} - 1 = +.34$$

∴ LOWER FLANGE OK @ t = .050
USING 3T LOADS

BOLT STRESSES

AT BOLT $F = F_1 = 29.84 \text{ LB/IN}$

$V = V_1 = .096 \text{ LB/IN}$

6 BOLTS IN 10.562 IN

TOTAL LOAD/BOLT @ 1T LOAD

$$F_B = \frac{10.562}{6} (29.84) = 52.53 \text{ LB}$$

$$V_B = \frac{10.562}{6} (.096) = .17 \text{ LB}$$

BOLTS ARE NAS1352N06-6, $F_{tu} = 160000 \text{ PSI}$
@ 3T LOADS

$$S_t = 3 \frac{F_B}{A_s} = 3 \frac{52.53}{.009085} = 17346 \text{ PSI}$$

$$S_s = 3 \frac{V_B}{A_s} = 3 \frac{.17}{.009085} = 56 \text{ PSI}$$

3T LOADS

$$W/FS = 1.4$$

$$S_t = 1.4 \times 17346 = 24284 \text{ PSL}$$

$$r_t = \frac{24284}{160000} = .152$$

$$S_s = 1.4 \times 56 = 79 \text{ PSL}$$

$$r_s = \frac{79}{(6)(160000)} = .0008 \approx 0$$

$$R_t \sim 1.0$$

$$U = \frac{r_t}{R_t} = .152$$

$$MS = \frac{1}{U} - 1 = +5.6$$

WORST LOADED BOLT
LOWER MOTOR MT PANEL
LOWER FLANGE
USING 3T LOADS

°° BOLTS OK ON LOWER FLANGE

USING 3T LOADS

LOWER MOTOR MOUNT PANEL - TOP FLANGE

Report 10381
Addendum 1

THE "TOP FLANGE" IS DEFINED AS THE $t=.055$
THICK FLANGES ABOVE THE MOTOR.

RANDOM Y $w/Q=7.1$ 1 ∇ LOADS

EL	2878	2882	2884	2886	
F_x	1.624				LB/IN
F_y	1.999	.446	1.243	1.094	"
F_{xy}	1.281				"
M_x	.0124				IN-LB/IN
M_y	.0072	.0091	.0225	.0300	"
M_{xy}	.0067				"
V_x	.0339				LB/IN
V_y	.0332	.0241	.0715	.0698	"

RANDOM X $w/Q=7.1$ 1 ∇ LOADS


EL	2878	2882	2884	2886	
F_x	7.493				LB/IN
F_y	3.193	2.626	1.236	5.100	"
F_{xy}	2.547				"
M_x	.0493				IN-LB/IN
M_y	.0160	.0295	.1300	.1771	"
M_{xy}	.0325				"
V_x	.2168				LB/IN
V_y	.1489	.1224	.3743	.5323	"

RANDOM Z $w/Q=7.1$ 1 ∇ LOADS

EL	2878	2882	2884	2886	
F_x	1.141				LB/IN
F_y	1.101	.496	.552	.968	"
F_{xy}	1.295				"
M_x	.0123				IN-LB/IN
M_y	.0057	.0100	.0241	.0327	"
M_{xy}	.0052				"
V_x	.0462	.0076	.0250	.0658	LB/IN
V_y	.0270				"

WORST CONDITION IS RANDOM X @ EL 2878
RIGHT SIDE

AT EL 2878 THE "X_{EL}" DIRECTION IS SLIGHTLY
SKEWED FROM THE I-L SIDE NORMAL



	Y	Z
i	9.021	9.313
j	8.751	9.073
k	7.796	10.221
l	8.646	10.221



$$\angle Aji \quad \tan^{-1} \frac{.240}{.270} = 41.63^\circ$$

$$\angle Bjk \quad \tan^{-1} \frac{1.148}{.105} = 84.77^\circ$$

$$\angle Bjk \quad \tan^{-1} \frac{1.148}{.955} = 50.24^\circ$$

$$\angle Dlk \quad \tan^{-1} \frac{.908}{1.225} = 36.55^\circ$$

$$\angle Dli \quad \tan^{-1} \frac{.908}{.375} = 67.56^\circ$$

$$\perp \text{ TO } i-l \quad \angle = 67.56 - 40 = -22.44^\circ$$


$$\gamma = 180 - 84.77 - 41.63 = 53.60^\circ$$


$$\beta = 41.63 + 36.55 = 78.18^\circ$$

$$\alpha = (53.60 + 78.18) / 2 = 65.89$$

$$X_{EL} @ -(65.89 - 36.55) = -29.34$$

ROTATE X_{EL} 29.34 - 22.44 = 6.9 CW





* Aji: $\tan^{-1} \frac{.240}{.270} = 41.63^\circ$

$$\Delta B, \Delta \tan^{-1} \frac{1.148}{.105} = 84.77^\circ$$

$$4 \text{ B}_3 \text{R} \quad \tan^{-1} \frac{1.148}{.955} = 50.74$$

$$\times \text{BAIR } \tan^{-1} \frac{.908}{1.225} = 36.55$$

$$4 \text{ LQ} \quad \tan^{-1} \frac{.908}{.375} = 67.56$$

1.2 67.56-QD = -22.44

$$x_{EL} = -29.34$$

ROTATE 6.9° CW


$$F_x' = \frac{7.493 + 3.193}{2} + \frac{7.493 - 3.193}{2} \cos(-13.8^\circ) + 2.547 \sin(-13.8^\circ)$$

$$= 4.823 \text{ LB/IN}$$

$$m_x' = .041 \text{ IN-LB/IN}$$

$$V_x' = V_x = .2168 \text{ LB/IN}$$

FLANGE STRESSES




$$l = .2$$

$$d = .312$$

$$d_2 = .438$$

$t = .050$ FLANGE MINIMUM




$$\sum M_2 = 0 \quad F_1 (.438) = 4.823 (.750) + .084$$

$$F_1 = 11.876 \text{ LB/IN}$$

$$F_2 = 5.053 \text{ LB/IN}$$

$$V_1 = .217 \text{ LB/IN}$$

MOMENT
DIAGRAM



FLANGE TENSION (MEMB + BEND) @ $t_{min} = .050$

$$S_t = 3 \left[\frac{V_1}{t} + \frac{6 M_1}{t^2} \right]$$

@ 3T LOADS

$$= 3 \left[\frac{.217}{.050} + \frac{6(2.213)}{(1.050)^2} \right]$$

$$= 3 [4 + 53.1]$$

② 3T L0405

$$= 15946 \text{ psi}$$

w/ FS = 1.25 LIMIT, 1.4 ULT

$$MS = \frac{F_{ty}}{1.25 \times S_t} - 1$$


$$= \frac{66000}{1.25(15946)} - 1 = + 2.3$$

$$MS = \frac{F_{ty}}{1.4 \times S_t} - 1$$

$$= \frac{75000}{1.4(15946)} - 1 = + 2.4$$

∴ TOP FLANGE OK @ t=.050

USING 3T L0405



UPPER MOTOR MOUNT PANEL - LOWER FLANGE

RANDOM Y W/Q=7.1 IT LOADS

EL	2634	2635	2642	
F _y	9.448	13.795	9.675	LB/IN
M _y	.0177	.0217	.0201	IN-LB/IN
V _y	.0847	.0367	.0442	LB/IN


RANDOM X W/Q=7.1 IT LOADS

EL	2634	2635	2642	
F _y	4.000	8.365	14.176	LB/IN
M _y	.0211	.0263	.0166	IN-LB/IN
V _y	.0979	.0572	.0645	LB/IN

RANDOM Z W/Q=7.1 IT LOADS

EL	2634	2635	2642	
F _y	3.611	6.151	7.878	LB/IN
M _y	.0118	.0131	.0148	IN-LB/IN
V _y	.0631	.0451	.0206	LB/IN

WORST CASE IS EL 2635 WHOSE SKEWED "ELEMENT X & Y" DIRECTIONS LEAD TO NORMAL COMPONENTS F_y', M_y', V_y' OF



$$\beta = \tan^{-1} \frac{1.125}{1.640} = 34.45^\circ$$

$$\gamma = \tan^{-1} \frac{1.125}{1.298} = 40.92^\circ$$

$$90 - \gamma = 49.08$$

$$\alpha = \frac{\delta + \beta}{2} = 37.68^\circ$$

$$\theta = 180 - 52.32 - 2(37.68) - 49.08$$

$$= 3.2^\circ \text{ CCW}$$

ROTATE EL 2635 $\theta = 3.2^\circ$

Report 10381
Addendum 1

$$F_y' = \frac{13.795 + 2.476}{2} + \frac{13.795 - 2.476}{2} \cos(2 \times 3.2^\circ) + 8.414 \sin(2 \times 3.2^\circ)$$

$$= 14.698 \text{ LB/IN}$$


$$m_y' = \frac{.0217 + .0278}{2} + \frac{.0217 - .0278}{2} \cos(2 \times 3.2^\circ) + .0219 \sin(2 \times 3.2^\circ)$$

$$= .0242 \text{ IN-LB/IN}$$

$$V_y' = V_y = .0367 \text{ LB/IN}$$


$$\begin{aligned} F_y' &= 14.698 \text{ LB/IN} \\ m_y' &= .0242 \text{ IN-LB/IN} \\ V_y' &= .0367 \text{ LB/IN} \end{aligned}$$

FLANGE STRESSES



$$\begin{aligned} d &= .312 \\ d_2 &= .438 \\ l &= 1.125/2 \end{aligned}$$

FLANGE $t = .050$
MINIMUM



$$\Sigma M_2 = 0$$

$$F_1(.438) = 14.698(.750) + .045$$


Report 10381
Addendum 1

$$F_1 = 25.271 \text{ LB/IN}$$

$$F_2 = 10.573 \text{ LB/IN}$$

$$V_1 = .037 \text{ LB/IN}$$

MOMENT
DIAGRAM



FLANGE TENSION (MEMB + BEND) @ $t = .050$ MIN

$$S_t = 3 \left[\frac{V_1}{t} + \frac{6M_1}{t^2} \right]$$

$$= 3 \left[\frac{.037}{.050} + \frac{6(4.631)}{(.050)^2} \right]$$

3T LOADS

$$= 3 [1 + 11114]$$

$$= 33345 \text{ PSI}$$

MAT'L 7075-T651

$$F_{ty} = 66000 \text{ PSI}$$

$$F_{tu} = 75000 \text{ PSI}$$

W/F 1.25 LIMIT, 1.4 VLT

$$MS = \frac{F_{ty}}{1.25 \times S_t} - 1$$

$$= \frac{66000}{1.25(33345)} - 1 = +.58$$

$$MS = \frac{F_{tu}}{1.4 \times S_t} - 1$$

$$= \frac{75000}{1.4(33345)} - 1 = +.61$$

• • LOWER FLANGE OK @ $t = .050$

USING 3T LOADS

BOLT STRESSES

Report 10381
Addendum 1

AT BOLT

$$F = F_1 = 25.571 \text{ LB/IN}$$

$$V = V_1 = .037 \text{ LB/IN}$$

$$6 \text{ BOLTS IN } 10.563 \text{ IN}$$

TOTAL LOAD / BOLT

$$F_B = \frac{10.563}{6} (25.571) = 45.02 \text{ LB}$$

$$V_B = \frac{10.563}{6} (.037) = .065 \text{ LB}$$

BOLTS ARE NAS 1352ND6, $F_{TU} = 160000 \text{ PSI}$
② 3T LOADS

$$S_t = 3 \frac{F_B}{A_s} = 3 \frac{45.02}{.009085} = 14866 \text{ PSI}$$

$$S_s = 3 \frac{V_B}{A_s} = 3 \frac{.065}{.009085} = 21 \text{ PSI}$$

3T LOADS

$$FS = 1.4$$

$$S_t = 1.4 \times 14866 = 20812 \text{ PSI}$$

$$V_t = \frac{20812}{160000} = .130$$

$$S_s = 1.4 \times 21 = 30 \text{ PSI}$$

$$V_s = \frac{30}{(.6)(160000)} = .0003 \Rightarrow 0$$

$$R_t \sim 1.0$$

$$u = \frac{r_t}{R_t} = .130$$

$$MS = \frac{1}{u} - 1 = + 6.7$$

WORST LOADED BOLT
UPPER MOTOR MIPANEL
LOWER FLANGE
USING 3T LOADS

∴ BOLTS OK ON LOWER FLANGE

USING 3T LOADS

UPPER MOTOR MOUNT PANEL - RIGHT FLANGE

RANDOM Y $W/Q=7.1$ 1T LOADS

EL	2634	2643	2652	
F _x	10.565	19.290	3.786	LB/IN
M _x	.0322	.0596	.0346	IN-LB/IN
V _x	.0842	.0788	.0349	LB/IN

RANDOM X $W/Q=7.1$ 1T LOADS

EL	2634	2643	2652	
F _x	4.362	10.206	5.221	LB/IN
M _x	.0237	.0492	.0261	IN-LB/IN
V _x	.1305	.1088	.3170	LB/IN

RANDOM Z $W/Q=7.1$ 1T LOADS


EL	2634	2643	2652	
F _x	4.810	8.451	1.537	LB/IN
M _x	.0164	.0346	.0259	IN-LB/IN
V _x	.0773	.0589	.3079	LB/IN

WORST CASE IS RANDOM Y @ EL 2643

$$\begin{aligned} F_x &= 19.290 \text{ LB/IN} \\ M_x &= .0596 \text{ IN-LB/IN} \\ V_x &= .0788 \text{ LB/IN} \end{aligned}$$

FLANGE STRESSES

SIMILAR TO LOWER FLANGE



$$\begin{aligned} d &= .312 \\ d_2 &= .438 \\ d &= .595/2 \end{aligned}$$

FLANGE $t = .050$
MINIMUM


$$\sum M_2 = 0 \quad F_1(.438) = 19,290(.750) + .063$$

$$F_1 = 33.175 \text{ LB/IN}$$

$$F_2 = 13.885 \text{ LB/IN}$$

$$V_1 = .079 \text{ LB/IN}$$

MOMENT
DIAGRAM



FLANGE TENSION (MEMB + BEND) @ MIN $t = .050$

$$S_t = 3 \left[\frac{V_1}{t} + \frac{6M_1}{t^2} \right]$$

$$= 3 \left[\frac{.079}{.050} + \frac{6(6.081)}{(.050)^2} \right]$$

@ 3 ∇ LOADS

$$= [2 + 14594]$$

$$= 43788 \text{ PSI}$$

$$MS = \frac{66000}{1.25(43788)} - 1 = +.21$$

$$MS = \frac{75000}{1.4(43788)} - 1 = +.22$$

\therefore RIGHT FLANGE OK @ $t = .050$

USING 3 ∇ LOADS

BOLT STRESSES

AT BOLT

$$F = F_1 = 33.175 \text{ LB/IN}$$

$$V = V_1 = .08 \text{ LB/IN}$$

3 BOLTS IN 6.245 IN

TOTAL LOAD/BOLT

$$F_B = \frac{6.245}{3} (33.175) = 69.06 \text{ LB}$$

$$V_B = \frac{6.245}{3} (1.08) = .17 \text{ LB}$$

BOLTS ARE NAS1352N06, $F_{TU} = 160000 \text{ PSI}$

$$S_t = 3 \frac{F_B}{A_s} = 3 \frac{69.06}{.009085} = 22804 \text{ PSI}$$

© 3T LOADS

$$S_s = 3 \frac{V_B}{A_s} = 3 \frac{.17}{.009085} = 56 \text{ PSI}$$

$$F_S = 1.4$$

$$S_t = 1.4 \times 22804 = 31926$$

$$r_t = \frac{31926}{160000} = .200$$

$$S_s = 1.4 \times 56 = 79 \text{ PSI}$$

$$r_s = \frac{79}{(.6)(160000)} = .0008 \Rightarrow 0$$

$$R_t \sim 1.0$$

$$u = \frac{r_t}{R_t} = .200$$

$$MS = \frac{1}{u} - 1 = +4.0$$

WORST LOADED BOLT
UPPER MOTOR MOUNT PANEL
RIGHT FLANGE
USING 3T LOADS

∴ BOLTS OK ON RIGHT FLANGE

USING 3T LOADS

UPPER MOTOR MOUNT PANEL - TOP FLANGE

Report 10381
Addendum 1

THE "TOP FLANGE" IS DEFINED AS THE $t=.055$
THICK FLANGES ABOVE THE MOTOR

RANDOM Y W/Q=7.1 1 T LOADS

EL	2700	2706	2708	2720	2722	2724	2727	
Fx	2.668	1.992	1.908	1.450	12.583	5.441	9.386	LB/IN
Fy	10.402	11.187	5.600	1.746	2.768	1.802	2.723	"
Fxy	14.836	3.392	1.508	1.531	4.418	6.550	4.165	"
Mx	.7180	.152	.109	.0028	.0018	.0175	.0323	IN-LB/IN
My	.2098	.0848	.0374	.0120	.0647	.0887	.0541	"
Mxy	.2478	.1788	.156	.0109	.0152	.0191	.0101	"
Vx	7.843	1.168	.461	.0180	.0274	.0833	.2003	LB/IN
Vy	2.017	.1869	.0524	.0312	.2143	.3327	.0937	"

RANDOM X W/Q=7.1 1 T LOADS

EL	2700	2706	2708	2720	2722	2724	2727	
Fx	3.158	2.287	2.126	2.073	21.826	4.077	13.081	LB/IN
Fy	13.105	14.451	7.696	2.562	3.137	2.007	4.085	"
Fxy	18.454	4.006	1.654	1.376	6.375	8.781	5.128	"
Mx	.711	.1832	.1264	.0032	.0033	.0221	.0456	IN-LB/IN
My	.194	.1049	.0658	.0159	.0744	.1043	.0659	"
Mxy	.292	.2168	.1890	.0133	.0184	.0191	.0128	"
Vx	9.222	1.566	.703	.0279	.0404	.1072	.2467	LB/IN
Vy	2.480	.2698	.0650	.0546	.2441	.4811	.1086	"

RANDOM Z W/Q=7.1 1 T LOADS

EL	2700	2706	2708	2720	2722	2724	2727	
Fx	.930	1.615	.850	1.965	5.069	2.978	5.081	LB/IN
Fy	4.819	3.240	2.478	.647	.823	.575	1.156	"
Fxy	4.160	1.210	1.165	.0977	1.598	2.078	1.219	"
Mx	.184	.0633	.0462	.0013	.0009	.0056	.0128	IN-LB/IN
My	.0642	.0349	.0389	.0049	.0187	.0255	.0156	"
Mxy	.156	.0498	.0471	.0034	.0040	.0058	.0040	"
Vx	1.999	.360	.212	.0067	.0157	.0246	.0566	IN
Vy	.535	.149	.0466	.0137	.0614	.0931	.0263	"

NOTE "ELEM-X" IS APPROXIMATELY PERPENDICULAR
TO FLANGE IN EL 2700, 2706, 2708. "ELEM-Y" IS IN
EL 2720, 2722, 2724, AND 2727.

WORST CASE IS RANDOM X @ BL 2727


$$\begin{aligned} F_y &= 4.085 \text{ LB/IN} \\ M_y &= .0659 \text{ IN-LB/IN} \\ V_y &= .1086 \text{ LB/IN} \end{aligned} \quad 1 \nabla \text{ LOADS}$$

THESE LOADS < LOWER FLANGE ($F_y' = 14.648 \text{ LB/IN}$)
AND RIGHT FLANGE ($F_x = 19.290 \text{ LB/IN}$) THEREFORE
BY COMPARISON

FLANGE STRESSES

$$\begin{aligned} MS &> + .21 && \text{LIMIT} \\ MS &> + .22 && \text{ULTIMATE} \end{aligned} \quad 3 \nabla \text{ LOADS}$$

\therefore TOP FLANGE OK @ $E = .050$
USING 3 ∇ LOADS



LOWER FRONT PANEL - LOWER FLANGE

RANDOM Y - W/Q=7.1 1 T LOADS

EL	1435	1445	1475	1503	1547	
Fx	12.694	11.462	13.066	14.183	4.526	LB/IN
⇒ Fy	8.847	15.037	13.761	22.265	28.357	"
Fxy	17.828	11.104	12.167	2.028	51.844	"
Mx	.0845	.1070	.0513	.0491	.0449	IN-LB/IN
My	.0704	.0540	.0395	.0220	.0121	"
Mxy	.0393	.0220	.0237	.0410	.0125	"
Vx	.4041	.3688	.0823	.0701	.5882	LB/IN
Vy	.1927	.2629	.0774	.0887	.5348	"


RANDOM X - W/Q=7.1 1 T LOADS

EL	1435	1445	1475	1503	1547	
Fx	2.380	4.856	3.713	5.100	1.181	LB/IN
⇒ Fy	9.004	7.217	3.547	5.689	11.649	"
Fxy	7.575	3.470	4.028	1.905	8.993	"
Mx	.2550	.3024	.0780	.0880	.0256	IN-LB/IN
My	.2191	.0763	.0429	.0698	.0077	"
Mxy	.1223	.0282	.0219	.0385	.0096	"
Vx	1.170	.9037	.2663	.1545	.2745	LB/IN
Vy	.5665	.8035	.1890	.1903	.2289	"

RANDOM Z - W/Q=7.1 1 T LOADS

EL	1435	1445	1475	1503	1547	
Fx	8.598	5.068	7.457	3.715	1.321	LB/IN
⇒ Fy	4.634	12.670	3.716	5.298	12.974	"
Fxy	7.599	3.849	5.260	1.366	24.039	"
Mx	.0425	.0565	.1794	.0855	.0578	IN-LB/IN
My	.0432	.0984	.1173	.0476	.0056	"
Mxy	.0177	.0127	.0782	.0703	.0087	"
Vx	.1572	.1446	.1552	.1231	.3921	LB/IN
Vy	.0816	.1303	.1706	.1584	.3526	"

WORST CASE IS RANDOM Y @ EL 1547, WHICH IS A SLIGHTLY SKEWED ELEMENT. "ELEM Y" IS TO BE ROTATED 3.4° CCW TO BE NORMAL TO THE LOWER FLANGE



	Y	Z
L	11.222	0
J	11.846	0
k	11.846	1.531
l	11.222	1.131

$$\theta = \angle j l k \quad \tan^{-1} \frac{1.531}{.624} = 67.83^\circ$$

$$B = \angle l j l \quad \tan^{-1} \frac{1.131}{.624} = 61.11^\circ$$

$$\psi = 180 - \theta - B = 51.06^\circ$$

$$\frac{\theta + B}{2} = \alpha = 64.47^\circ$$

$$\phi = 90 - B = 28.89^\circ$$

$$\Delta = 180 - \alpha - \phi = 86.64^\circ$$

X_{EL} is $90 - 86.64 = 3.36^\circ$ CW OF NORMAL
Y_{EL} " " " " " "

ROTATE Y_{EL} + 3.36° (CCW)

EL 1547

$$F_y' = \frac{28.357 + 4.526}{2} + \frac{28.357 - 4.526}{2} \cos(2 \times 3.36^\circ) + 51.044 \sin(2 \times 3.36^\circ)$$

$$= 34.248 \text{ LB/IN}$$

$$M_y' = \frac{.0121 + .0949}{2} + \frac{.0121 - .0949}{2} \cos(2 \times 3.36^\circ) + .0125 \sin(2 \times 3.36^\circ)$$

$$= .014 \text{ IN-LB/IN}$$

$$V_y' = V_y = .5548 \text{ LB/IN}$$


$$F_y' = 34.248 \text{ LB/IN}$$

$$m_y' = .014 \text{ IN-LB/IN}$$

$$V_y' = .555 \text{ LB/IN}$$

Report 10381
Addendum 1

FLANGE STRESSES




$$d = .313$$

$$d_2 = .312$$

$$l = 1.331/2$$

FLANGE $t = .040$
MINIMUM




$$\sum M_2 = 0 \quad F_1 (.312) = 34.248 (.625) + .383$$

$$F_1 = 69.83 \text{ LB/IN}$$

$$F_2 = 35.59 \text{ LB/IN}$$

$$V_1 = .555 \text{ LB/IN}$$

MOMENT
DIAGRAM



FLANGE TENSION (MEMB + BEND) @ $t_{min} = .040$

$$S_t = 3 \left[\frac{V_1}{t} + \frac{6 M_1}{t^2} \right] = \frac{.555}{.04} + \frac{6 (11.103)}{(.040)^2}$$

$$= 3 [14 + 41636]$$

$$= 124950 \text{ psi}$$

@ 35 LOADS

W/FS 1.25 LIMIT, 1.4 ULTIMATE

$$MS = \frac{F_{Ty}}{1.25 \times S_t} - 1$$

$$= \frac{35000}{1.25(124950)} - 1 = -.78$$

$$MS = \frac{F_{Tu}}{1.4 \times S_t} - 1$$

$$= \frac{42000}{1.4(124950)} - 1 = -.76$$

 \therefore FLANGE BAD @ $t = .040$ (LOWER FLANGE)SEE RECOMMENDATIONBOLT STRESSES

AT BOLT

$$F = F_1 = 69.83 \text{ LB/IN}$$

$$V = V_1 = .555 \text{ LB/IN}$$

8 NAS1352ND6 BOLTS ($F_{Tu} = 160000 \text{ psi}$) IN

$$11.188 - .625 = 10.563 \text{ IN}$$

TOTAL LOADS

$$F_B = \frac{10.563}{8} (69.83) = 92.2 \text{ LB}$$

$$V_B = \frac{10.563}{8} (.555) = .73 \text{ LB}$$

② ST LOADS

$$S_t = 3 \frac{F_B}{A_s} = 3 \frac{92.2}{.009085} = 30445 \text{ psi}$$

$$S_s = 3 \frac{V_B}{A_s} = 3 \frac{.73}{.009085} = 241 \text{ psi}$$

$$FS = 1.4$$

$$S_t = 1.4 \times 30445 = 42623 \text{ psi}$$

$$r_t = \frac{42623}{160000} = .266$$

$$S_s = 1.4 \times 241 = 337 \text{ psi}$$

$$r_s = \frac{337}{(.6)(160000)} = .003 \approx 0$$

$$R_t \sim 1.0$$

$$u = \frac{r_t}{R_t} = .266$$

$$MS = \frac{1}{u} - 1 = +2.8$$

WORST WAGED BOLT
LOWER FRONT PANEL
LOWER FLANGE
USING 3T LOADS

∴ BOLTS OK ON LOWER FLANGE
USING 3T LOADS

DUE TO LOW MS ON FLANGE, RECOMMEND A
THICKNESS INCREASE TO .090 (FROM .040)

@ $t = .090$, w/ 3T LOADS

$$S_t = 3 \left[\frac{.555}{.090} + \frac{6(11.103)}{(.090)^2} \right]$$

FLANGE
STRESSES

$$= 3 [6 + 8224]$$

$$= 24692 \text{ psi}$$

$$MS = \frac{35000}{1.25(24692)} - 1 = +.13$$

$$t = .090$$

$$MS = \frac{42000}{1.4(24692)} - 1 = +.21$$

$$t = .090$$

∴ w/ $t = .090$ LOWER FLANGE OK

USING 3T LOADS

LOWER FRONT PANEL - UPPER FLANGE

RANDOM Y W/Q=7.1 1 T LOADS

EL	1454	1516	1526	1556	
Fx	8.270	5.185	1.767	2.517	LB/IN
Fy	9.043	7.708	8.068	7.965	"
Fxy	13.420	18.987	13.420	11.165	"
Mx	.0082	.0203	.0459	.0314	IN-LB/IN
My	.0147	.0954	.0920	.0100	"
Mxy	.0088	.0075	.0110	.0058	"
Vx	.0149	.0270	.0361	.0282	LB/IN
Vy	.0206	.1585	.1362	.0160	"

RANDOM X W/Q=7.1 1 T LOADS

EL	1546	
Fx	1.492	LB/IN
Fy	4.259	"
Fxy	4.086	"
Mx	.0137	IN-LB/IN
My	.0405	"
Mxy	.0180	"
Vx	.0128	LB/IN
Vy	.0781	"


RANDOM Z W/Q=7.1 1 T LOADS

EL	1546	
Fx	.414	LB/IN
Fy	3.628	"
Fxy	2.445	"
Mx	.0088	IN-LB/IN
My	.0239	"
Mxy	.0094	"
Vx	.0108	LB/IN
Vy	.0342	LB/IN

WORST CASE IS RANDOM Y AT EL 1454, WHICH IS SLIGHTLY SKEWED. "ELEM Y" NEED BE ROTATED CCW 14.64 TO BE NORMAL TO THE UPPER FLANGE

EL 1454

	Y	Z
i	1.12	9.421
j	2.0	9.421
k	1.471	10.096
l	.971	10.096



$$\angle jlk \quad \tan^{-1} \frac{.675}{.351} = 62.53^\circ = \gamma$$

$$\angle ljl \quad \tan^{-1} \frac{.675}{1.029} = 33.26^\circ = \beta$$

$$\angle \psi = 180 - \gamma - \beta = 84.21^\circ$$

$$\alpha = \frac{\gamma + \beta}{2} = 47.89^\circ$$

$$\angle ljk \quad \tan^{-1} \frac{.675}{.529} = 51.91^\circ$$

$$\theta = 180 - 18.65 - \alpha = 113.45^\circ$$

$$\Delta = 14.64^\circ$$

YEL IS 14.64° CW OF NORMAL TO UPPER FLANGE

ROTATE F_y 14.64° CCW

$$\begin{aligned} F_y' &= \frac{9.043 + 8.270}{2} + \frac{9.043 - 8.270}{2} \cos(2 \times 14.64^\circ) \\ &\quad + 13.420 \sin(2 \times 14.64^\circ) \\ &= 15.557 \text{ LB/IN} \end{aligned}$$


$$M_y' = .0186 \text{ IN-LB/IN}$$

$$V_y' = V_y = .0206 \text{ LB/IN}$$

Report 10381
Addendum 1

EL 1516

	Y	Z
L	7.6	9.421
J	8.326	9.421
K	8.8	10.046
L	7.246	10.046



$$\angle JLK = \tan^{-1} \frac{.675}{1.2} = 29.36^\circ = \delta$$


$$\angle LJL = \tan^{-1} \frac{.675}{1.08} = 32.01^\circ = \beta$$

$$\alpha = \frac{\delta + \beta}{2} = 30.68^\circ$$

$$\angle JLK = \theta = \tan^{-1} \frac{.675}{.474} = 54.92^\circ$$

$$\psi = 180 - \beta - \theta = 93.07^\circ$$

$$180 = \theta + \psi + (\alpha - \delta) \quad \Delta = -1.33^\circ$$



ROTATE Y_{EL} 1.33° CW TO
ACHIEVE NORMAL

$$F_y' = \frac{7.708 + 5.185}{2} + \frac{7.708 - 5.185}{2} \cos(2\alpha - 1.33^\circ) + 18.987 \sin(-2.66^\circ)$$

$$= 6.825 \text{ LB/IN}$$

LESS SEVERE THAN EL 1454

$$F_y' = 15.557 \text{ LB/IN}$$

$$m_y' = .0186 \text{ IN-LB/IN}$$


$$V_y' = .0246 \text{ LB/IN}$$

© ELI454 RANDOMY

Report 10381
Addendum 1

FLANGE STRESSES

SIMILAR TO LOWER FLANGE



$$d = .675/2$$

$$d = .313$$

$$d_2 = .312$$

FLANGE $t = .040$
MINIMUM

$$\sum M_2 = 0 \quad F_1(.312) = 15.557(.625) + .026$$


$$F_1 = 31.247 \text{ LB/IN}$$

$$F_2 = 15.690 \text{ LB/IN}$$

17 LOADS

$$V_1 = .021 \text{ LB/IN}$$

MOMENT
DIAGRAM



FLANGE TENSION (MEMB + BEND) @ $t_{min} = .040$

$$S_t = 3 \left[\frac{V_1}{t} + \frac{6M_1}{t^2} \right]$$

© 37 LOADS

$$= 3 \left[\frac{.021}{.040} + \frac{6(4.895)}{(.040)^2} \right] = 55070 \text{ psi}$$

$$MS = \frac{35000}{1.25(55070)} - 1 = -.49$$

$$MS = \frac{42000}{1.4(55070)} - 1 = -.45$$

∴ UPPER FLANGE BAD @ $t = .040$
USING 37 LOADS

REQUIRE $t = .060$ MINIMUM , @ 3T LOADS

$$S_t = 3 \left[\frac{.021}{.060} + \frac{6(4.895)}{(.060)^2} \right] = 24476 \text{ PSI}$$

$$MS = \frac{35000}{1.25(24476)} - 1 = +.14$$

3T LOADS

$$MS = \frac{42000}{1.4(24476)} - 1 = +.23$$

∴ UPPER FLANGE OK @ $t = .060$
USING 3T LOADS

BOLT STRESSES

AT BOLT

$$F = F_1 = 31.247 \text{ LB/IN}$$

$$V = V_1 = .021 \text{ LB/IN}$$

7 BOLTS IN $11.188 - .9 = 10.288 \text{ IN}$
 A51352N06 W/ F_{TU} = 160000 PSI

TOTAL LOAD/BOLT

$$F_B = \frac{10.288}{7} (31.247) = 45.924 \text{ LB}$$

$$V_B = \frac{10.288}{7} (.021) = .031 \text{ LB}$$

1 T LOADS

$$S_t = 3 \frac{F_B}{A_s} = 3 \frac{45.924}{.009085} = 15165 \text{ PSI}$$

3 T LOADS

$$S_s = 3 \frac{V_B}{A_s} \Rightarrow 0$$

$$S_t = 1.4 \times 15165 = 21230 \text{ PSI}$$

$$r_t = \frac{21230}{160000} = .133$$

$$R_t = 1.0$$


$$u = \frac{r_t}{R_t} = .133$$

$$MS = \frac{1}{u} - 1 = +6.5$$

WORST LOADED BOLT
 LOWER FRONT PANEL
 UPPER FLANGE
 USING 3T LOADS

• BOLTS OK ON UPPER FLANGE
USING 3T LOADS

LOWER FRONT PANEL
QUAD. TRI



UPPER AFT PANEL - LOWER FLANGE

Report 10381
Addendum 1

RANDOM Y w/Q=7.1 1 T LOADS

EL	44328	44326	44339	
Fx			11.542	LB/IN
Fy	14.738	10.261		"
Fxy				"
Mx			1.426	IN-LB/IN
My	1.395	1.125		"
Mxy				"
Vx			2.512	LB/IN
Vy	.964	.517		"

RANDOM X w/Q=7.1 1 T LOADS

EL	44323	44329	44336	
Fx				LB/IN
Fy	16.378	17.394	17.282	"
Fxy				"
Mx				IN-LB/IN
My	1.228	10.041	10.496	"
Mxy				"
Vx				LB/IN
Vy	2.710	5.700	5.892	"

RANDOM Z w/Q=7.1 1 T LOADS



EL	44328			
Fx				LB/IN
Fy	10.544			"
Fxy				"
Mx				IN-LB/IN
My	1.519			"
Mxy				"
Vx				LB/IN
Vy	3.874			"

WORST CASE IS RANDOM X @ EL 44329

Fy = 17.394 LB/IN
My = 10.041 IN-LB/IN
Vy = 5.700 LB/IN

Report 10381
Addendum 1

	Y	Z
1	8.15	10.7
2	7.40	10.773
4	7.15	10.096
9	8.15	10.096



$$\angle A_j L = \tan^{-1} \frac{.677}{.75} = 42.07^\circ$$

$$\angle \alpha_2 = \tan^{-1} \frac{.604}{1} = 31.13^\circ$$

$$\alpha = \frac{Y+B}{2} = 36.60$$

$$\angle k_j = \tan^{-1} \frac{.677}{.25} = 69.73^\circ$$

$$\varphi = 180^\circ - \alpha - 38,60^\circ = 104,80^\circ$$

ROTATE γ_{BL} $42.07 - 36.60 = 5.47^\circ$ CW TO ACHIEVE NORMAL

$$F_y' = \frac{17.394 + 14.673}{2} + \frac{17.394 - 14.673}{2} \cos(2x - 5.47)^\circ + 3.360 \sin(2x - 5.47)^\circ$$

$$F_y' = 16.732 \text{ LB/IN}$$

$$M_y' = \frac{10.041 + 3.332}{2} + \frac{10.041 - 3.332}{2} \cos(2 \times -5.47^\circ)$$

$$+ 1.695 \sin(2 \times -5.47^\circ)$$


$$= 9.658 \text{ IN-LB/IN}$$

$$V_y' = V_y = 5.700 \text{ LB/IN}$$

$$F_y' = 16.732 \text{ LB/IN}$$

$$M_y' = 9.658 \text{ IN-LB/IN}$$

$$V_y' = 5.700 \text{ LB/IN}$$




$$d = .562$$


$$d_2 = .188$$

$$l = .6405/2$$

FLANGE $t = .060$
minimum



$$\sum M_2 = 0 \quad F_1(.188) = 16.732(.750) + 11.483$$



FLANGE STRESSES

Report 10381
Addendum 1

MEMB + BEND @ 3T LOADS FOR $t_{min} = .060$ IN

$$\begin{aligned} S_t &= 3 \left[\frac{V_1}{t} + \frac{6M_1}{t^2} \right] \\ &= 3 \left[\frac{5.700}{.060} + \frac{6(20.886)}{(.060)^2} \right] \\ &= 3 [95 + 34810] \\ &= 104715 \text{ PSI} \end{aligned}$$

MAT'L 6061-T651

$F_{ty} = 35000 \text{ PSI}$

$F_{tu} = 42000 \text{ PSI}$

W/F S 1.25 LIMIT, 1.4 ULTIMATE

$$\begin{aligned} MS &= \frac{F_{ty}}{1.25 \times S_t} - 1 \\ &= \frac{35000}{1.25(104715)} - 1 = -.73 \end{aligned}$$

$$\begin{aligned} MS &= \frac{F_{tu}}{1.4 \times S_t} - 1 \\ &= \frac{42000}{1.4(104715)} - 1 = -.71 \end{aligned}$$

\therefore LOWER FLANGE OVERSTRESSED @ $t = .060$

RAISE t TO $t = .120$

$$\begin{aligned} S_t &= 3 \left[\frac{5.700}{.120} + \frac{6(20.886)}{(.120)^2} \right] \\ &= 3 [48 + 8703] = 26250 \text{ PSI} \end{aligned}$$

$$MS = \frac{35000}{1.25(26250)} - 1 = +.07 \quad t = .120$$

$$MS = \frac{42000}{1.4(26250)} - 1 = +.14 \quad t = .120$$

∴ LOWER FLANGE OK @ t = .120 IN

USING 3 T LOADS

CONSIDER HIGHER STRENGTHENED 2024-T851 ALUM

$$F_{Ty} = 58000 \text{ psi}$$

$$F_{Tu} = 66000 \text{ psi}$$

RAISE t TO .095 IN MINIMUM WITH 2024-T851

$$S_t = 3 \left[\frac{5.700}{.095} + \frac{6(20.886)}{(.095)^2} \right]$$

$$= 41836 \text{ psi}$$

3 T LOADS

$$MS = \frac{58000}{1.25(41836)} - 1 = +.11 \quad t = .095$$

$$MS = \frac{66000}{1.4(41836)} - 1 = +.13 \quad t = .095$$

∴ LOWER FLANGE OK @ t = .095 IN

USING 3 T LOADS ON 2024-T851 MAT'L

BOLT STRESSES

AT BOLT LINE

$$F = F_1 = 127.83 \text{ LB/IN}$$

$$V = V_1 = 5.70 \text{ LB/IN}$$

9 NAS 1352N06 BOLTS ($F_{tu} = 160000 \text{ psi}$) IN 11.700 IN

TOTAL LOAD/BOLT

$$F_B = \frac{11.700}{9} (127.83) = 166.17 \text{ LB}$$

$$V_B = \frac{11.700}{9} (5.70) = 7.41 \text{ LB}$$

$$S_t = 3 \frac{F_B}{A_s} = 3 \frac{166.17}{.009085} = 54870 \text{ psi}$$

3T LOADS

$$S_s = 3 \frac{V_B}{A_s} = 3 \frac{7.41}{.009085} = 2447 \text{ psi}$$

$$F_s = 1.4$$

$$S_t = 1.4 \times 54870 = 76818 \text{ psi}$$

$$r_t = \frac{76818}{160000} = .480$$

$$S_s = 1.4 (2447) = 3426 \text{ psi}$$

$$r_s = \frac{3426}{(.6)(160000)} = .036 \sim 0$$

$$R_t \sim 1.0$$

$$u = \frac{r_t}{R_t} = .480$$

$$MS = \frac{1}{u} - 1 = +1.1$$

WORST LOADED BOLT
UPPER AFT PANEL
LOWER FLANGE
USING 3T LOADS

∴ BOLTS OK ON LOWER FLANGE

USING 3T LOADS

UPPER AFT PANEL - UPPER FLANGE

RANDOM Y W/Q=7.1 1T LOADS

EL	<u>44206</u>	44207
F _x	5.700	2.214
F _y	6.148	2.347
F _{xy}	4.136	4.712
M _x	.0947	.1050
M _y	.0511	.0325
M _{xy}	.0370	.0300
V _x	.1176	.1515
V _y	.0945	.0153

RANDOM X W/Q=7.1 1T LOADS


EL	44200	44211
F _x	4.224	3.963
F _y	4.162	3.433
F _{xy}	1.086	.7783
M _x	.2401	.2593
M _y	.2735	.2349
M _{xy}	.2060	.2051
V _x	.0832	.0961
V _y	.1819	.0955

RANDOM Z W/Q=7.1 1T LOADS


EL	44206
F _x	2.729
F _y	2.226
F _{xy}	1.955
M _x	.2549
M _y	.1680
M _{xy}	.0780
V _x	.3493
V _y	.1866

WORST CASE IS RANDOM Y AT SKEWED
ELEMENT 44206

EL 44206



	Y	Z
L	6.196	21.781
J	5.7	22.752
K	5.216	21.777



$$\angle Lj = \tan^{-1} \frac{.971}{.996} = 62.94^\circ$$

ROTATE X_{EL} $90 - 62.94 = 27.06^\circ$ CCW

$$\begin{aligned} F_x' &= \frac{5.700 + 6.148}{2} + \frac{5.700 - 6.148}{2} \cos(2 \times 27.06)^\circ \\ &\quad + 4.136 \sin(2 \times 27.06)^\circ \\ &= 9.013 \text{ LB/IN} \end{aligned}$$

$$\begin{aligned} m_x' &= \frac{.0947 + .0511}{2} + \frac{.0947 - .0511}{2} \cos(2 \times 27.06)^\circ \\ &\quad + .0370 \sin(2 \times 27.06)^\circ \\ &= .128 \text{ IN-LB/IN} \end{aligned}$$

$$V_x' = V_x = .1176 \text{ LB/IN}$$

$$F_x' = 9.013 \text{ LB/IN}$$


$$m_x' = .128 \text{ IN-LB/IN}$$

$$V_x' = .1176 \text{ LB/IN}$$

EL 44207

Report 10381
Addendum 1

	Y	Z
i	4.396	22.752
j	4.236	21.775
k	5.216	21.777
l	5.7	22.752



$$\angle i, j = \tan^{-1} \frac{.975}{.820} = 49.94^\circ$$

$$\angle j, l = \tan^{-1} \frac{.977}{1.404} = 33.72^\circ$$

$$\angle i, l = \tan^{-1} \frac{.977}{.160} = 80.70^\circ$$

$$\gamma = 80.70 - 33.72 = 46.98^\circ$$

$$B = 180 - 49.94 - 80.70 = 49.36^\circ$$

$$\alpha = \frac{\gamma + B}{2} = 48.17$$

$$180 - 49.94 - 48.17 = 81.89 = \psi$$

X_{EL} is $90 - 81.89 = 8.11^\circ$ CCW OF NORMAL

ROTATE X_{EL} CW 8.11° TO ACHIEVE NORMAL

$$F_x' = \frac{2.214 + 2.347}{2} + \frac{2.214 - 2.347}{2} \cos(2 \times 8.11)^\circ + 4.712 \sin(2 \times 8.11)^\circ$$

$$= .278 \text{ Lb/in}$$

MUCH LESS SEVERE THAN EL 44206

FLANGE STRESSES

Report 10381
Addendum 1

SIMILAR TO LOWER FLANGE, WITH

$$F_x' = 9.013 \text{ LB/IN}$$


$$M_x' = .128 \text{ IN-LB/IN}$$

$$V_x' = .1176 \text{ LB/IN}$$

$$d = 2/3 (.972)$$

$$d = .562$$

$$d_2 = .188$$



$$\sum M_2 = 0$$


$$F_1 (.188) = 9.013 (.750) + .204$$

$$F_1 = 37.04 \text{ LB/IN}$$

$$F_2 = 28.03 \text{ LB/IN}$$

$$V_1 = .118 \text{ LB/IN}$$

MOMENT
DIAGRAM



FLANGE TENSION (MEMBER END) @ $t_{min} = .050$

$$S_t = 3 \left[\frac{V_1}{t} + \frac{6M_1}{t^2} \right]$$

@ 3T LOADS

$$= 3 \left[\frac{.118}{.050} + \frac{6(5.269)}{(.050)^2} \right]$$

$$= 3 [2 + 12646] = 37944 \text{ PSI}$$

$$MS = \frac{35000}{1.25(37944)} - 1 = -.26$$

$$MS = \frac{42000}{1.4(37944)} - 1 = -.21$$

∴ UPPER FLANGE BAR @ $t = .05$

USING 3T LOADS

RAISE t TO .060 MIN , @ 3T LOADS

$$S_t = 3 \left[\frac{.118}{.060} + \frac{6(5.269)}{(.060)^2} \right] = 26351 \text{ psi}$$

$$MS = \frac{35000}{1.25(26351)} - 1 = +.06 \quad t = .060$$

$$MS = \frac{42000}{1.4(26351)} - 1 = +.14 \quad t = .060$$

∴ FLANGE OK @ $t = .060$
USING 3T LOADS

CONSIDER HIGHER STRENGTHED 2024-T851
THEN t_{min} CAN REMAIN @ .050

$$S_t = 37944 \text{ psi} \quad @ 3T \text{ LOADS}$$

$$MS = \frac{58000}{1.25(37944)} - 1 = +.22 \quad t = .050$$

$$MS = \frac{66000}{1.4(37944)} - 1 = +.24 \quad t = .050$$

∴ FLANGE OK @ $t = .050$
USING 3T LOADS, USING 2024-T851

BOLT STRESSES

AT BOLT

$$F = F_1 = 37.04 \text{ LB/IN}$$

$$V = V_1 = .118 \text{ LB/IN}$$

$$7 \text{ BOLTS (NAS1352N06, } F_{TU} = 160000 \text{ PSL)} \\ \text{IN } 11.700 - 2(1.950) = 9.800 \text{ IN}$$

TOTAL LOAD/BOLT

$$F_B = \frac{9.800}{7} (37.04) = 51.856 \text{ LB}$$

$$V_B = \frac{9.800}{7} (.118) = .165 \text{ LB}$$

$$S_t = 3 \frac{F_B}{A_s} = 3 \frac{51.856}{.009085} = 17123 \text{ PSL}$$

$$S_s = 3 \frac{V_B}{A_s} = 3 \frac{.165}{.009085} = 54 \text{ PSL}$$

⊗ 3T LOADS

$$F_S = 1.4$$

$$S_t = 1.4 \times 17123 = 23972 \text{ PSL}$$

$$r_t = \frac{23972}{160000} = .150$$

$$S_s = 1.4 \times 54 = 76 \text{ PSL}$$

$$r_s = \frac{76}{(.6)(160000)} = .0008 \Rightarrow 0$$

$$R_t \sim 1.0$$

$$U = \frac{r_t}{R_t} = .150$$

$$MS = \frac{1}{U} - 1 = +5.7$$

WORST LOADED BOLT
UPPER AFT PANEL
UPPER FLANGE
USING 3T LOADS

∴ BOLTS OK ON UPPER FLANGES

USING 3T LOADS

UPPER AFT PANEL - SIDE FLANGES

RANDOM Y W/Q=7.1 1T LOADS

EL	44344	44303	44345	44314	
Fx	5.191	4.931	.9843	8.913	LB/IN
Fy	6.417	17.088	14.568	5.542	"
Fxy	6.876	2.891	2.508	9.751	"
Mx	.0875	.1208	.1625	.0682	IN-LB/IN
My	.0602	.0536	.0664	.0634	"
Mxy	.0380	.0346	.0286	.0332	"
Vx	.0838	.1530	.1200	.0817	LB/IN
Vy	.1068	.0715	.0996	.1355	"

RANDOM X W/Q=7.1 1T LOADS


EL	44339	44303	44314	
Fx	14.481	3.925	5.501	LB/IN
Fy	5.088	14.671	8.150	"
Fxy	6.341	5.586	4.540	"
Mx	1.187	.3694	.3466	IN-LB/IN
My	.3179	.3466	.3886	"
Mxy	1.867	.3050	.2940	"
Vx	1.989	.3366	.1216	LB/IN
Vy	.766	.3135	.3499	"

RANDOM Z W/Q=7.1 1T LOADS


EL	44303	44314	
Fx	2.231	4.291	LB/IN
Fy	10.125	5.053	"
Fxy	1.188	4.474	"
Mx	.0854	.0356	IN-LB/IN
My	.0367	.0378	"
Mxy	.0259	.0265	"
Ux	.1224	.0866	LB/IN
Vy	.0785	.1075	"

WORST CASE IS RANDOM Y @ EL44344, A
SKEWED ELEMENT.

EL 44344



	Y	Z
L	.346	18.249
J	1.363	18.710
R	.346	18.971



$$\angle L_j = \theta = \tan^{-1} \frac{.461}{1.017} = 24.38^\circ$$

ROTATE X_{EL} CCW 24.38° TO ACHIEVE NORMAL

RANDOM Y


$$F_{x'} = \frac{5.191 + 6.417}{2} + \frac{5.191 - 6.417}{2} \cos(2 \times 24.38^\circ) + 6.876 \sin(2 \times 24.38^\circ)$$

$$= 10.570 \text{ LB/IN}$$

$$m_{x'} = .111 \text{ IN-LB/IN}$$

$$V_{x'} = V_x = .0838 \text{ LB/IN}$$

EL 44303



	Y	Z
L	.346	12.95
J	1.497	12.45
R	1.497	13.45




$$\angle L_j = \theta = \tan^{-1} \frac{.50}{1.151} = 23.48^\circ$$

ROTATE X_{EL} CW 23.48° TO ACHIEVE NORMAL


CW ROTATION IS A -23.48° ANGLE

\therefore EL 44303 LESS SEVERE THAN EL 44344 RANDOM Y

EL 44345



	Y	Z
L	11.846	18.971
J	10.925	18.665
Jr	11.846	18.249




$$\angle L_J = \theta = \tan^{-1} \frac{.306}{.921} = 18.38^\circ$$

ROTATE X_{EL} CCW 18.38° TO ACHIEVE NORMAL
RANDOM Y


$$F_{x'} = \frac{.9843 + 14.568}{2} + \frac{.9843 - 14.568}{2} \cos(2 \times 18.38^\circ) + 2.508 \sin(2 \times 18.38^\circ) = 3.905 \text{ LB/IN}$$

\therefore EL 44345 LESS SEVERE THAN EL 44344 RANDOM Y

EL 44314



	Y	Z
L	11.846	12.95
J	10.864	13.45
Jr	10.864	12.45



$$\angle L_J = \theta = \tan^{-1} \frac{.50}{.982} = 26.98^\circ$$

ROTATE X_{EL} CW 26.98° TO ACHIEVE NORMAL


CW ROTATION IS A -26.98° ANGLES

\therefore EL 44314 LESS SEVERE THAN EL 44344 RANDOM Y

$$\begin{aligned} F_x' &= 10.570 \text{ LB/IN} \\ M_x' &= .111 \text{ IN-LB/IN} \\ V_x' &= .0838 \text{ LB/IN} \end{aligned}$$

FLANGE STRESSES

SIMILAR TO LOWER FLANG



$$\sum M_2 = 0 \quad F_1(.188) = 10.570(.750) + .139$$

$$F_1 = 42.907 \text{ LB/IN}$$

$$F_2 = 32.337 \text{ LB/IN}$$

$$V_1 = .0838 \text{ LB/IN}$$

1/4 LOADS

MOMENT
DIAGRAM



FLANGE TENSION (MEMB + BEND) @ $t = .050$ MIN

$$\begin{aligned} S_t &= 3 \left[\frac{V_1}{t} + \frac{6M_1}{t^2} \right] = 3 \left[\frac{.0838}{.050} + \frac{6(6.079)}{(.050)^2} \right] \\ &= 3 [2 + 14590] = 43774 \text{ PSI} \end{aligned} \quad @ 3/4 \text{ LOADS}$$

$$MS = \frac{35000}{1.25(43774)} - 1 = -.36$$

$$MS = \frac{42000}{1.4(43774)} - 1 = -.31$$

∴ SIDE FLANGES BAD @ $t = .050$

USING 3/4 LOADS

RAISE t TO .065 MIN , @ 3T LOADS

$$S_t = 3 \left[\frac{.0838}{.065} + \frac{6(6.079)}{(.065)^2} \right] = 25903 \text{ psi}$$

$$MS = \frac{35000}{1.25(25903)} - 1 = +.08 \quad t = .065$$

$$MS = \frac{42000}{1.4(25903)} - 1 = +.16 \quad t = .065$$

∴ FLANGE OK @ $t = .065$
USING 3T LOADS

CONSIDER HIGHER STRENGTHED 2024-T851
THEN t_{min} CAN REMAIN AT $t = .050$

$$S_t = 43774 \text{ psi}$$

$$MS = \frac{58000}{1.25(43774)} - 1 = +.06 \quad t = .050$$

$$MS = \frac{66000}{1.4(43774)} - 1 = +.08 \quad t = .050$$

∴ FLANGE OK @ $t = .050$
USING 3T LOADS & 2024-T851 ALUM

BOLT STRESSES

AT BOLT

$$F = F_1 = 42.907 \text{ LB/IN}$$

$$V = V_1 = .0838 \text{ LB/IN}$$

$$8 \text{ BOLTS (NAS1352N06, } F_{TU} = 160000 \text{ psi)}$$

$$1 \text{ IN } 12.500 - .900 = 11.600 \text{ IN}$$

TOTAL LOAD/BOLT

$$F_B = \frac{11.600}{8} 42.907 = 62.215 \text{ LB}$$

$$V_B = \frac{11.600}{8} .0838 = .12 \text{ LB}$$

$$S_t = 3 \frac{F_B}{A_s} = 3 \frac{62.215}{.009085} = 20543 \text{ psi}$$

$$S_s = 3 \frac{F_B}{A_s} = 3 \frac{.12}{.009085} = 40 \text{ psi}$$

@ 3T LOADS

$$F_S = 1.4$$

$$S_t = 1.4 \times 20543 = 28762 \text{ psi}$$

$$r_t = \frac{28762}{160000} = .180$$

$$S_s = 1.4 \times 40 = 55 \text{ psi}$$

$$r_s = \frac{55}{(106)(160000)} = .0006 \approx 0$$

$$R_t \sim 1.0$$

$$u = \frac{r_t}{R_t} = .180$$

$$MS = \frac{1}{u} - 1 = +4.6$$

WORST LOADED SCREW
UPPER AFT PANEL
SIDE FLANGES
USING 3T LOADS

∴ BOLTS OK ON SIDE FLANGES

USING 3T LOADS

UPPER AFT PANEL

QUAD, TRI

44200	44201	44202	44203	44204	44205	44206	44207	44208	44209	44210	44211
44233	44234	44235	44236	44237	44238	44239	44240	44241	44242	44243	44244
44232	44259	44260	44261	44262	44263	44264	44265	44266	44267	44254	44225
44231	44258	44276	44277	44278	44279	44280	44281	44282	44283	44255	44226
44230	44257	44275	44274	44273	44272	44271	44270	44269	44268	44256	44227
44229	44253	44252	44251	44250	44249	44248	44247	44246	44245	44244	44228
44223	44222	44221	44220	44219	44218	44217	44216	44215	44214	44213	44212
44176	44177	44178	44179	44180	44181	44182	44183	44184	44185	44186	44187
44179	44180	44181	44182	44183	44184	44185	44186	44187	44188	44189	44190
44311	44312	44313	44314	44315	44316	44317	44318	44319	44320	44321	44322
44311	44312	44313	44314	44315	44316	44317	44318	44319	44320	44321	44322
44317	44318	44319	44320	44321	44322	44323	44324	44325	44326	44327	44328
44320	44321	44322	44323	44324	44325	44326	44327	44328	44329	44330	44331
44323	44324	44325	44326	44327	44328	44329	44330	44331	44332	44333	44334

UPPER RIGHT PANEL - LOWER FLANGE

	<u>RANDOM Y w/Q=7.1 IT LOADS</u>		
EL	1801	1813	1825
F _x	16.715	15.460	15.294 LB/IN
F _y	2.502	1.895	"
F _{xy}	7.034	3.940	"
M _x	.0575	.1563	.2430 IN-LB/IN
M _y	.0511	.0363	"
M _{xy}	.0239	.0272	"
V _x	.0437	.2148	.2859 LB/IN
V _y	.4898	.0378	"

RANDOM X w/Q=7.1 IT LOADS


EL	1861	1873	
F _x	12.662	16.519	LB/IN
F _y	1.775	9.735	"
F _{xy}	12.724	3.842	"
M _x	.0544	.0293	IN-LB/IN
M _y	.0238	.0169	"
M _{xy}	.0191	.0137	"
V _x	.1285	.2530	LB/IN
V _y	.16565	.2800	"

RANDOM Z w/Q=7.1 IT LOADS

EL	1873	
F _x	9.791	LB/IN
F _y	4.921	"
F _{xy}	2.159	"
M _x	.0067	IN-LB/IN
M _y	.0194	"
M _{xy}	.0047	"
V _x	.1000	LB/IN
V _y	.0763	"

EL 1825 RANDOM Y IS WORST CASE USING F_x, M_x, V_x

$$\begin{aligned} F_x &= 15.294 \text{ LB/IN} \\ M_x &= .2430 \text{ IN-LB/IN} \\ V_x &= .2859 \text{ LB/IN} \end{aligned}$$



	X	Z
L	17.472	10.096
J	17.157	11.221
K	18.082	11.221
EL	18.022	10.096

$$\angle L_j = \theta = \tan^{-1} \frac{1.125}{.315} = 74.36^\circ$$

$$\angle L_k = \psi = \tan^{-1} \frac{1.125}{1.210} = 42.92$$

$$\angle L_i = \tan^{-1} \frac{1.125}{1.865} = 52.44 = \phi$$

$$\alpha = (180 - \phi - \psi) / 2 = 42.32$$

$$\text{ROTATE } X_{EL} \text{ CW } (90 - 42.92) - 42.32 = 4.76^\circ$$

Random Y



$$F_x' = \frac{(16.715 + 2.502)}{2} + \frac{(16.715 - 2.502)}{2} \cos(2x - 4.76)^\circ + 7.034 \sin(2x - 4.76)^\circ$$

$$= 15.454 \text{ LB/in}$$

$$M_x' = .0567 \text{ in-LB/in}$$

$$V_x' = V_x = .0437 \text{ LB/in}$$

EL 1873



RANDOM X

ROTATE XEL CW 10° , THUS $\theta = -10^\circ$,
TO ACHIEVE NORMAL

$$F_x' = \frac{16.519 + 9.735}{2} + \frac{16.519 - 9.735}{2} \cos(-20^\circ)$$


$$+ 3.842 \sin(-20^\circ)$$

$$= 15.000 \text{ LB/IN}$$

$$M_x' = .0242 \text{ IN-LB/IN}$$

$$V_x' = V_x = .2530 \text{ LB/IN}$$

FLANGE STRESSES



$$l = 1.125/2$$

$$d = .312$$

$$d_2 = .188$$

$t = .040$ FLANGE MINIMUM


$$\sum M_2 = 0 \quad F_1(.188) = 15.294(.5) + .4038$$

$$F_1 = 42.824 \text{ LB/IN}$$

$$F_2 = 27.530 \text{ LB/IN}$$

$$V_1 = .2859 \text{ LB/IN}$$

MOMENT
DIAGRAM



FLANGE TENSION (MEMB + BEND) @ $t = .040$

$$S_t = 3 \left[\frac{V_1}{t} + \frac{6 M_1}{t^2} \right]$$

$$= 3 \left[\frac{.2859}{.040} + \frac{6(5.176)}{(.040)^2} \right]$$

$$= 3 [7 + 19410]$$

$$= 58251 \text{ PSI}$$

⑤ 3T LOADS

MAT'RL 6061-T4

$F_{TY} = 16000 \text{ PSI}$

$F_{TU} = 30000 \text{ PSI}$

W/FS 1.25 YIELD, 1.4 ULTIMATE

Report 10381
Addendum 1

$$MS = \frac{F_{ty}}{1.25 \times S_t} - 1$$

$$= \frac{16000}{1.25(58251)} - 1 = -.78$$

$$MS = \frac{F_{tu}}{1.4 \times S_t} - 1$$

$$= \frac{30000}{1.4(58251)} - 1 = -.63$$

∴ LOWER FLANGE IS BAD @ t=.040

RECOMMEND

1) CHANGE MATERIAL TO 6061-T6

2) RAISE TG t TO .060

W/ t=.060 6061-T6

F_{ty} 35000 psi
F_{tu} 42000 psi

$$MS = \frac{35000}{1.25(25894)} - 1 = +.08 \quad t=.060$$

$$MS = \frac{42000}{1.4(25894)} - 1 = +.16 \quad t=.060$$

∴ LOWER FLANGE OK @ t=.060 6061-T6

USING 3T LOADS

$$S_t = 3 \left[\frac{2859}{.090} + \frac{6(5.176)}{(.090)^2} \right]$$

② 3T LOADS

$$= 3 [3 + 3834]$$

$$= 11512 \text{ psi}$$

$$m_s = \frac{16000}{1.25(11512)} - 1 = +.11$$

$$m_s = \frac{30000}{1.4(11512)} - 1 = +.86$$

∴ LOWER FLANGE OK @ t = .090 6061-T4USING 3T LOADSBOLT STRESSES

$$F_B = \frac{8.783}{7} (42.824) = 53.73 \text{ LB}$$

7 NAS1352N06 BOLTS, $F_{tu} = 160000 \text{ psi}$ IN 8.783 IN.

$$S_t = 3 \frac{F_B}{A_s} = 3 \frac{53.73}{1.009085} = 17742 \text{ psi} \quad \text{② 3T LOADS}$$

$$f_t = 1.4 \times S_t = 24839 \text{ psi}$$

$$r_t = \frac{24839}{160000} = .155$$

$$f_s \rightarrow 0$$

$$R_t = 1.0$$

$$u = r_t / R_t = .155$$

$$m_s = \frac{1}{u} - 1 = +5.4$$

WORST LOADED BOLT
UPPER RIGHT PANEL
LOWER FLANGE @ 3T LOADS∴ BOLTS OK ON LOWER FLANGE @ 3T LOADS

UPPER RIGHT PANEL - QUAD, TRI

1884 1872	1860	1848	1836	1824	1812
1883 1871	1859	1847	1835	1823	1811
1882 1870	1858	1846	1834	1822	1810
1881 1869	1857	1845	1833	1821	1809
1880 1868	1856	1844	1832	1820	1808
1879 1867	1855	1843	1831	1819	1807
1878 1866	1854	1842	1830	1818	1806
1877 1865	1853	1841	1829	1817	1805
1876 1864	1852	1840	1828	1816	1804
1875 1863	1851	1839	1827	1815	1803
1874 1862	1850	1838	1826	1814	1802
1873 1861	1849	1837	1825	1813	1801
1872 1860	1848	1836	1824	1812	1800

LOWER RIGHT SUPPORT PANEL- LOWER FLANGE, AFT FLANGE

RANDOM Y W/Q=7.1 1 T LOADS

EL	2565	
F _x		
F _y	8.277	LB/IN
F _{xy}		
M _x		
M _y	.0475	IN-LB/IN
M _{xy}		
V _x		
V _y	.0903	LB/IN

RANDOM X W/Q=7.1 1 T LOADS


EL	2566	
F _y	3.334	LB/IN
M _y	.0044	IN-LB/IN
V _y	.0095	LB/IN

RANDOM Z W/Q=7.1 1 T LOADS

EL	2565	
F _y	5.195	LB/IN
M _y	.0126	IN-LB/IN
V _y	.0144	LB/IN

WORST CASE IS RANDOM Y @ EL 2565

$$\begin{aligned} F_y &= 8.277 \text{ LB/IN} \\ M_y &= .0475 \text{ IN-LB/IN} \\ V_y &= .0903 \text{ LB/IN} \end{aligned}$$




$$\begin{aligned} l &= 1.131/2 \\ d &= .312 \\ d_2 &= .313 \end{aligned}$$

FLANGE $t = .040$
MINIMUM

FLANGE STRESSES

Report 10381
Addendum 1



$$\sum M_2 = 0$$

$$F_1 (.313) = 8.277 (.625) + .099$$

$$F_1 = 16.844 \text{ LB/IN}$$

$$F_2 = 8.567 \text{ LB/IN}$$

$$V_1 = .0903 \text{ LB/IN}$$

FLANGE TENSION (MEMB + BEND) @ $t_{min} = .040$

$$S_t = 3 \left[\frac{V_1}{t} + \frac{6M_1}{t^2} \right]$$

@ 3T LOADS

$$= 3 \left[\frac{.0903}{.040} + \frac{6(2.673)}{(.040)^2} \right]$$

$$= 3 [2 + 10024]$$

$$= 30078 \text{ PSI}$$

MAT'L 6061-T651

$$F_{ty} = 35000 \text{ PSI}$$

$$F_{tu} = 42000 \text{ PSI}$$

$$F_s = 1.25, 1.4$$

$$MS = \frac{F_{ty}}{1.25 \times S_t} - 1$$

$$= \frac{35000}{(1.25)(30078)} - 1 = -.07$$

$$MS = \frac{F_{tu}}{1.4 \times S_t} - 1$$

$$= \frac{42000}{(1.4)(30078)} - 1 = -.003$$

∴ FLANGES BAD @ $t = .040$

USING 3T LOADS

RECOMMEND TIGHTENING TOLERANCE TO

$$t = .050 \pm .005$$

THEN @ $t_{MIN} = .045$, @ 3T LOADS

$$S_t = 3 \left[\frac{.0903}{.045} + \frac{6(2.673)}{(.045)^2} \right] = 23766 \text{ psi}$$

$$MS = \frac{35000}{1.25(23766)} - 1 = +.18 \quad t = .045$$

$$MS = \frac{42000}{1.4(23766)} - 1 = +.26 \quad t = .045$$

∴ FLANGES OK @ $t = .045$

USING 3T LOADS

BOLT STRESSES

3 A31352N06 SCREWS, $F_{tu} = 160000 \text{ psi}$ IN 6.500 IN

$$F_B = \frac{6.500}{3} 16.844 = 36.50 \text{ LB}$$

$$S_t = 3 \frac{F_B}{A_s} = 3 \frac{36.50}{.009085} = 12052 \text{ psi} \quad @ 3T \text{ LOADS}$$

$$S_t = 1.4 \times 12052 = 16874 \text{ psi}$$

$$r_t = \frac{16874}{160000} = .105$$

$$S_s \sim 0$$

$$R_t \sim 1.0$$

$$u = \frac{r_t}{R_t} = .105$$


$$m_s = \frac{1}{u} - 1 = +8.5$$

WORST LOADED SCREW
LOWER RIGHT SUPPORT
LOWER FLANGE
USING 3T LOADS

∴ BOLTS OK ON LOWER & AFT FLANGES

USING 3T LOADS

LOWER RIGHT SUPPORT PANEL - QUAD, TRI, BARS, BEAMS, GRID



5.4.2 Lower Baseplate Mounting Bolts and Pins Stresses per 15g Static Design Loads

The following pages contain a detailed analysis of lower baseplate mounting bolts and pin stresses per 15g static design loads.

TABLE 56 AMSU A1-EOS LOWER BASEPLATE MOUNTING BOLTS MARGINS OF SAFETY													
LOAD CASE	BOLT GRID	APPLIED TENSION T3 (LB)	T3 FS	PRELOAD TENSION (LB)	TOTAL TENSION (LB)	TENSION ALLOW (LB)	APPLIED SHEAR T1 (LB)	APPLIED SHEAR T2 (LB)	SHEAR FS	TOTAL SHEAR (LB)	SHEAR ALLOW (LB)	MARGIN OF SAFETY	
GX = 15	1	158.4	1.4	1315	1536.8	2800	125.9	19.3	1.4	178.3	1273	0.81	
	4	43.2	1.4	1315	1375.5	2800	89.4	3.4	1.4	125.3	1273		
	7	160.5	1.4	1315	1539.7	2800	155.5	16.4	1.4	218.9	1273	0.79	
	9	57.5	1.4	1315	1395.5	2800	119.8	2.3	1.4	167.8	1273		
	12	19.9	1.4	1315	1342.9	2800	111.8	1.1	1.4	156.5	1273		
	15	18.8	1.4	1315	1341.3	2800	104.9	0.2	1.4	146.9	1273		
	17	152.7	1.4	1315	1528.8	2800	57.8	6.0	1.4	81.4	1273	0.83	
	21	205.6	1.4	1315	1602.8	2800	113.0	57.4	1.4	177.4	1273	0.73	
	85	58.1	1.4	1315	1396.3	2800	39.5	5.3	1.4	55.8	1273		
	105	112.1	1.4	1315	1471.9	2800	8.7	17.6	1.4	27.5	1273		
	169	7.3	1.4	1315	1325.2	2800	23.2	21.4	1.4	44.2	1273		
	189	95.3	1.4	1315	1448.4	2800	8.0	31.9	1.4	46.0	1273		
	254	27.1	1.4	1315	1352.9	2800	44.2	13.4	1.4	64.7	1273		
	257	31.1	1.4	1315	1358.5	2800	90.0	5.6	1.4	126.2	1273		
	261	123.9	1.4	1315	1488.5	2800	55.0	9.6	1.4	78.2	1273		
	263	36.1	1.4	1315	1365.5	2800	103.5	7.5	1.4	145.3	1273		
	266	11.8	1.4	1315	1331.5	2800	102.3	2.7	1.4	143.3	1273		
	269	5.4	1.4	1315	1322.6	2800	95.8	3.3	1.4	134.2	1273		
	271	85.0	1.4	1315	1434.0	2800	52.6	6.7	1.4	74.2	1273		
	275	60.0	1.4	1315	1399.0	2800	76.4	24.0	1.4	112.1	1273		

TABLE 56 AMSU A1-EOS LOWER BASEPLATE MOUNTING BOLTS MARGINS OF SAFETY													
LOAD CASE	BOLT GRID	APPLIED TENSION T3 (LB)	T3 FS	PRELOAD TENSION (LB)	TOTAL TENSION (LB)	TENSION ALLOW (LB)	APPLIED SHEAR T1 (LB)	APPLIED SHEAR T2 (LB)	SHEAR FS	TOTAL SHEAR (LB)	SHEAR ALLOW (LB)	MARGIN OF SAFETY	
GY = 15	1	108.7	1.4	1315	1467.18	2800	49.2	57.8	1.4	106.3	1273		
	4	41	1.4	1315	1372.4	2800	43.5	17.9	1.4	65.9	1273		
	7	263	1.4	1315	1683.2	2800	8.5	108.7	1.4	152.6	1273	0.66	
	9	75.8	1.4	1315	1421.12	2800	16.1	42	1.4	63.0	1273		
	12	68.4	1.4	1315	1410.76	2800	8.1	27.4	1.4	40.0	1273		
	15	79.8	1.4	1315	1426.72	2800	15	23.3	1.4	38.8	1273		
	17	216.7	1.4	1315	1618.38	2800	29.9	16.6	1.4	47.9	1273		
	21	308.3	1.4	1315	1746.62	2800	86.3	164.1	1.4	259.6	1273	0.58	
	85	7.4	1.4	1315	1325.36	2800	3.6	66.4	1.4	93.1	1273		
	105	81.7	1.4	1315	1429.38	2800	11.3	124.6	1.4	175.2	1273	0.94	
	169	36.6	1.4	1315	1366.24	2800	6.6	50.3	1.4	71.0	1273		
	189	190.7	1.4	1315	1581.98	2800	8.8	78.6	1.4	110.7	1273		
	254	20	1.4	1315	1343	2800	35.2	52.2	1.4	88.1	1273		
	257	70.9	1.4	1315	1414.26	2800	20.8	14.3	1.4	35.3	1273		
	261	298.4	1.4	1315	1732.76	2800	13.9	283.9	1.4	397.9	1273	0.53	
	263	95.7	1.4	1315	1448.98	2800	19.6	37.6	1.4	59.4	1273		
	266	64.9	1.4	1315	1405.86	2800	7.2	25.2	1.4	36.7	1273		
	269	67.2	1.4	1315	1409.08	2800	12.4	23.9	1.4	37.7	1273		
	271	222.5	1.4	1315	1626.5	2800	68	20.5	1.4	99.4	1273	0.72	
	275	183.8	1.4	1315	1572.32	2800	93	183.9	1.4	288.5	1273	0.72	

TABLE 56 AMSU A1-EOS LOWER BASEPLATE MOUNTING BOLTS MARGINS OF SAFETY												
LOAD CASE	BOLT GRID	APPLIED TENSION T3 (LB)	T3 FS	PRELOAD TENSION (LB)	TOTAL TENSION (LB)	TENSION ALLOW (LB)	APPLIED SHEAR T1 (LB)	APPLIED SHEAR T2 (LB)	SHEAR FS	TOTAL SHEAR (LB)	SHEAR ALLOW (LB)	MARGIN OF SAFETY
GZ = 15	1	55.3	1.4	1315	1392.4	2800	19.4	10.3	1.4	30.8	1273	
	4	31.9	1.4	1315	1359.7	2800	21.1	5.2	1.4	30.4	1273	
	7	199.2	1.4	1315	1593.9	2800	2.1	24.1	1.4	33.9	1273	0.76
	9	61.3	1.4	1315	1400.8	2800	25.6	3.2	1.4	36.1	1273	
	12	46.1	1.4	1315	1379.5	2800	8.6	4.4	1.4	13.5	1273	
	15	48.8	1.4	1315	1383.3	2800	2.6	8.9	1.4	13.0	1273	
	17	139.8	1.4	1315	1510.7	2800	40.5	4.7	1.4	57.1	1273	
	21	58.8	1.4	1315	1397.3	2800	61.7	59.2	1.4	119.7	1273	
	85	53.6	1.4	1315	1390.0	2800	16.3	1.5	1.4	22.9	1273	
	105	123.6	1.4	1315	1488.0	2800	7	42.9	1.4	60.9	1273	
	169	57.1	1.4	1315	1394.9	2800	11.4	12.8	1.4	24.0	1273	
	189	171.2	1.4	1315	1554.7	2800	3.7	48.5	1.4	68.1	1273	0.80
	254	1.3	1.4	1315	1316.8	2800	7.9	15.8	1.4	24.7	1273	
	257	63	1.4	1315	1403.2	2800	20.7	5.1	1.4	29.8	1273	
	261	146.9	1.4	1315	1520.7	2800	7.4	53.9	1.4	76.2	1273	
	263	66.5	1.4	1315	1408.1	2800	19.7	3.1	1.4	27.9	1273	
	266	39.9	1.4	1315	1370.9	2800	3.6	8.2	1.4	12.5	1273	
	269	40.3	1.4	1315	1371.4	2800	8.8	10.4	1.4	19.1	1273	
	271	154.7	1.4	1315	1531.6	2800	59.6	0.4	1.4	83.4	1273	
	275	45.7	1.4	1315	1379.0	2800	48.1	56.6	1.4	104.0	1273	

TABLE 56 AMSU A1-EOS LOWER BASEPLATE SHEAR PINS SHEAR TEAROUT MARGINS OF SAFETY										
LOAD CASE	BOLT GRID	COMP	APPLIED SHEAR T1 (LB)	APPLIED SHEAR T2 (LB)	TOTAL SHEAR (LB)	SHEAR TEAROUT (PSI)	FS	SHEAR Fsu (PSI)	MS	
GX = 15	127	BASEPL	984.8	2	985	7473	1.4	27000	1.58	
TABLE 56 AMSU A1-EOS LOWER BASEPLATE SHEAR PINS BEARING MARGINS OF SAFETY										
LOAD CASE	BOLT GRID	COMP	APPLIED LOAD T1 (LB)	APPLIED LOAD T2 (LB)	TOTAL LOAD (LB)	BEARING STRESS (PSI)	FS	ALLOW Fcy/Ftu (PSI)	MS	
GX = 15	127	BASEPL	984.8	2	985	8379	1.25	35000	2.34	
	127	BASEPL	984.8	2	985	8379	1.4	42000	2.58	

TABLE 56 AMSU A1-EOS LOWER BASEPLATE MOUNTING BOLTS MEMBER COMPRESSION MARGINS OF SAFETY										
LOAD CASE	MEMBER 1	MEMBER 2	APPLIED LOAD (LB)	BEARING AREA (IN2)	BEARING STRESS (PSI)	FS	ALLOW Ftu (PSI)	MS		
PRELOAD	BOLT	WASHER	1315	0.036	36290	1.40	140000	1.76		
	WASHER	.435 ISO	1315	0.112	11781	1.40	60000	2.64		
	.435 ISO	BASEPL	1315	0.083	15928	1.25	35000	0.76		
	ISOLATOR	BASEPL	1315	0.083	15928	1.40	42000	0.88		
	BASEPL	.590 ISO	1315	0.156	8433	1.25	35000	2.32		
	BASEPL	.590 ISO	1315	0.156	8433	1.40	42000	2.56		
	.590 ISO	SPCCR	1315	0.234	5620	1.40	60000	6.63		
TABLE 56 AMSU A1-EOS LOWER BASEPLATE MOUNTING BOLTS SHEAR TEAROUT MARGINS OF SAFETY										
LOAD CASE	BOLT GRID	COMP	APPLIED SHEAR T1 (LB)	APPLIED SHEAR T2 (LB)	TOTAL SHEAR (LB)	SHEAR TEAROUT (PSI)	FS	SHEAR Fsu (PSI)	MS	
GY = 15	261	BASEPL	13.9	283.9	284	3207	1.4	27000	5.01	
TABLE 56 AMSU A1-EOS LOWER BASEPLATE MOUNTING BOLTS BEARING MARGINS OF SAFETY										
LOAD CASE	BOLT GRID	COMP	APPLIED LOAD T1 (LB)	APPLIED LOAD T2 (LB)	TOTAL LOAD (LB)	BEARING STRESS (PSI)	FS	ALLOW Fcy/Ftu (PSI)	MS	
GY = 15	261	BASEPL	13.9	283.9	284	1927	1.25	35000	13.53	
	261	BASEPL	13.9	283.9	284	1927	1.4	42000	14.57	
	261	.590 ISO	13.9	283.9	284	1927	1.4	35000	11.97	
TABLE 56 AMSU A1-EOS THREAD SHEAR RANDOM VIBRATION 3S LOADING										
LOAD CASE	INT/EXT THREAD	PRELOAD	APPLIED LOAD LB	APPLIED LOAD FS	JOINT STIFFNESS FACTOR	TOTAL LOAD LB	SHEAR AREA SQ IN	THREAD SHEAR PSI	ALLOWABLE Fsu PSI	MARGIN OF SAFETY
GY = 15	EXTERNAL .190-32UNF SCREW	1315	308.3	1.4	1	1746.62	0.05065	34484	84000	1.44
	A-286									

11-11-95

AMSU A1 EOS 1356405 LOWER BASEPLATE MOUNTING BOLTS STRESSES PER STATIC LOADS


STATIC LOADS 15g INDEPENDENTLY ACTING IN
GLOBAL X, Y, Z DIRECTIONS

FACTOR'S OF SAFETY 1.4 ULTIMATE

ASSUMPTIONS

- 1) STRESSES IN BOLTS DERIVED FROM NASTRAN
SPC FORCES PER UNI-DIRECTION LOAD CASE
PLUS BOLT PRELOAD TORQUE (50 IN-LB)
 - 2) 20 BOLTS PLUS 2 DOWEL PINS PER
FIGURE 1 SKETCH, WITH NOTED NASTRAN
GRID NUMBER. GRIDS 127 & 147 ARE THE
DOWEL PINS.
 - 3) BOLT GRIDS (1, 4, 7, 9, 12, 15, 17, 21, 85, 105,
169, 189, 254, 257, 261, 263, 266, 264, 271, 275)
REACT TENSION/COMPRESSION (NASTRAN
T3 SPC FORCES) PLUS SHEAR (NASTRAN
T1 & T2 SPC FORCES).
 - 4) PIN GRIDS (127, 147) REACT ONLY SHEAR
(NASTRAN T1 & T2 SPC FORCES).
 - 5) INTERACTIVE TENSION PLUS SHEAR
CONSIDERED PER MIL-HDBK-5E FIG 1.5.3.5
 $R_s^2 + R_t^2 = 1$ CURVE.
 - 6) ALLOWABLES ARE PER MS16997 (UNC-3A)
TENSILE LOAD 2800 #10-32
SHEAR LOAD 1273 LB SCREWS
- TENSILE LOAD ALLOWABLE BASED ON F_{tu}
(140000 PSI) AND TENSILE AREA ($A_s = .01999 \text{ in}^2$)
SHEAR LOAD ALLOWABLE BASED OF $F_{su} = .6 \times F_{tu}$
AREA PER MINOR ϕ ($\pi/4 (1.1389^2)$).
- 7) THE FACTOR OF SAFETY, 1.4, IS APPLIED
ONLY TO THE APPLIED LOADS, NOT TO PRELOAD.

BASEPLATE SCREWS & PINS



THE FOLLOWING TABLES LIST BOLT LOADS (LB)
PER EACH OF THE 3 159 STATIC LOAD CASES.
(REF NASTRAN OUTPUT).

EOS AMSU-A1 STATIC ANALYSIS
LAUNCH_SHOCK_LOAD_GX=15

TABLE 1

MAY 11, 1995

FORCES OF SINGLE-POINT CONSTRAINT

POINT ID.	TYPE	T1	T2	T3
1	G	-1.258689E+02	-1.925428E+01	-1.583812E+02
4	G	-8.936213E+01	-3.449354E+00	-4.321259E+01
7	G	-1.555324E+02	-1.639825E+01	-1.604990E+02
9	G	-1.198174E+02	-2.323261E+00	-5.753431E+01
12	G	-1.117775E+02	-1.102563E+00	-1.990412E+01
15	G	-1.049295E+02	2.357800E-01	1.884999E+01
17	G	-5.776802E+01	-5.988444E+00	1.526645E+02
21	G	-1.129670E+02	5.739198E+01	2.055744E+02
85	G	-3.954858E+01	5.255445E+00	-5.809161E+01
105	G	-8.667003E+00	-1.759135E+01	1.121176E+02
127	G	-1.453382E+01	-7.860929E+00	0.0
147	G	-1.358557E+01	1.389905E+01	0.0
169	G	-2.319088E+01	-2.135475E+01	-7.277608E+00
189	G	-8.034056E+00	3.189130E+01	9.530946E+01
254	G	-4.417500E+01	1.340856E+01	-2.712557E+01
257	G	-9.000320E+01	-5.570083E+00	-3.113841E+01
261	G	-5.496064E+01	9.612906E+00	-1.239343E+02
263	G	-1.035119E+02	-7.489269E+00	-3.609636E+01
266	G	-1.022560E+02	-2.693850E+00	-1.180209E+01
269	G	-9.576151E+01	-3.327263E+00	5.448496E+00
271	G	-5.261657E+01	6.668529E+00	8.500832E+01
275	G	-7.635905E+01	-2.395988E+01	6.002437E+01

EOS AMSU-A1 STATIC ANALYSIS
LAUNCH_SHOCK_LOAD_GY=15

TABLE 2

MAY 11, 1995

FORCES OF SINGLE-POINT CONSTRAINT

POINT ID.	TYPE	T1	T2	T3
1	G	-4.922646E+01	-5.776447E+01	-1.086544E+02
4	G	-4.347932E+01	-1.792556E+01	-4.098786E+01
7	G	-8.491455E+00	-1.087068E+02	-2.630446E+02
9	G	1.610494E+01	-4.199586E+01	-7.578282E+01
12	G	8.147963E+00	-2.741898E+01	-6.838016E+01
15	G	1.503447E+01	-2.332141E+01	-7.976778E+01
17	G	-2.994038E+01	-1.656991E+01	-2.166770E+02
21	G	8.626559E+01	-1.640731E+02	-3.082957E+02
85	G	-3.598199E+00	-6.635413E+01	-7.431519E+00
105	G	-1.125033E+01	-1.246174E+02	-8.174689E+01
127	G	3.137108E+00	-5.558894E+01	0.0
147	G	-3.884206E+00	-1.303475E+02	0.0
169	G	6.632992E+00	-5.031898E+01	3.664951E+01
189	G	8.759583E+00	-7.864672E+01	1.907108E+02
254	G	3.523089E+01	-5.222286E+01	2.000888E+01
257	G	2.078536E+01	-1.434851E+01	7.093593E+01
261	G	1.390133E+01	-2.838523E+02	2.983871E+02
263	G	-1.958684E+01	-3.764598E+01	9.571375E+01
266	G	-7.217860E+00	-2.524164E+01	6.485027E+01
269	G	-1.238178E+01	-2.386706E+01	6.723901E+01
271	G	6.803258E+01	-2.047393E+01	2.224868E+02
275	G	-9.297598E+01	-1.839245E+02	1.837866E+02

EOS AMSU-A1 STATIC ANALYSIS
LAUNCH_SHOCK_LOAD_GZ=15

TABLE 3

MAY 11, 1995

FORCES OF SINGLE-POINT CONSTRAINT

POINT ID.	TYPE	T1	T2	T3
1	G	-1.938496E+01	-1.031298E+01	-5.532035E+01
4	G	-2.114051E+01	-5.205739E+00	-3.193669E+01
7	G	-2.123874E+00	-2.408677E+01	-1.992273E+02
9	G	2.555438E+01	3.230314E+00	-6.137473E+01
12	G	8.647001E+00	4.380313E+00	-4.614014E+01
15	G	-2.639420E+00	8.850567E+00	-4.880497E+01
17	G	-4.054764E+01	4.674185E+00	-1.398236E+02
21	G	6.168258E+01	-5.916256E+01	-5.882284E+01
85	G	-1.630356E+01	-1.521022E+00	-5.358508E+01
105	G	7.041644E+00	4.292433E+01	-1.235561E+02
127	G	-3.645182E+00	-8.849172E-01	0.0
147	G	1.124046E+01	-1.528708E+00	0.0
169	G	-1.144201E+01	-1.275482E+01	-5.711489E+01
189	G	3.653283E+00	-4.854662E+01	-1.712159E+02
254	G	-7.883881E+00	1.581296E+01	-1.267313E+00
257	G	-2.067689E+01	-5.077182E+00	-6.299686E+01
261	G	7.427674E+00	5.385385E+01	-1.468824E+02
263	G	1.966401E+01	-3.097493E+00	-6.651685E+01
266	G	3.598240E+00	-8.165441E+00	-3.990044E+01
269	G	8.849655E+00	-1.037084E+01	-4.030917E+01
271	G	-5.964692E+01	3.574720E-01	-1.547499E+02
275	G	4.807593E+01	5.663111E+01	-4.568103E+01

DETAILED CALCULATIONS ARE PERFORMED FOR THE MOST SEVERE CASE, LAUNCH SHOCK LOAD GY=15, GRID 261. SUMMARIZED RESULTS FOR SELECTED BOLTS AND PINS AND LOAD CASES IS IN TABLE 4.

CASE GY=15g GRID 261 BOLT

$$F_t = T_3 = 298.4 \text{ LB} \quad \text{APPLIED TENSION}$$

$$F_s = \sqrt{T_1^2 + T_2^2} = \sqrt{(13.9)^2 + (283.9)^2} = 284.2 \text{ LB} \quad \text{APPLIED SHEAR}$$

PRELOAD TORQUE, $T = .2 F_L$

F_L = PRELOAD

Δ = NOMINAL ϕ , .190 IN #10 SCREW

T	F_L
50 IN-LB	1315 LB

ASSUMING $F_i = 1315 \text{ LB}$ PRELOAD

TOTAL BOLT TENSILE LOAD, F_b , IS A FUNCTION OF PRELOAD, APPLIED TENSION, & JOINT STIFFNESS.

$$F_b = F_i + \frac{k_b F_t}{k_b + k_m}$$

$$F_i = 421 \text{ LB}$$

$$F_t = 298.4 \text{ LB}$$

k_b = BOLT STIFFNESS

k_m = MEMBER STIFFNESS

$$k_b = \frac{EA}{l}$$

$$= .9126 \times 10^6 \text{ LB/IN}$$

$$E_b = 28 \times 10^6 \text{ PSI}$$

$$A = \pi/4 (1.190)^2 = .02835 \text{ IN}^2$$

l = GRIP OF THERMAL SPACERS + BP LEDGES
.25 + .25 + .31 + .06

$$k_m = \frac{\pi E_m d}{2 \ln \left[\frac{5(l + d/2)}{d + 2.5d} \right]}$$

$$= 58409 \text{ LB/IN}$$

FOR G-10 SPACER ONLY
W/FIBERS \perp THICKNESS
USE EPOXY ONLY PROP

$$E_m = 250000 \text{ PSI}$$

$$d = .87 \text{ IN}$$

$$d = .190 \text{ IN}$$

WITH $k_m \ll k_b$ USE $k_b/(k_b + k_m) = 1.0$ &
APPLY THE APPLIED LOAD DIRECTLY TO PRELOAD

TENSILE LOAD W/FS

$$F_t = 1315 + 1.4(298.4) = 1733 \text{ LB}$$

SHEAR LOAD W/FS

$$F_s = 1.4(284.2) = 398 \text{ LB}$$

$$r_t = \frac{1733}{2800} = .619$$

$$r_s = \frac{398}{1273} = .313$$

PER FIG 1.5.3.5 MIL-HDBK-5E $R_t^2 + R_s^3 = 1$
CURVE FOR COMBINED TENSION & SHEAR

$$R_t = .944$$

$$R_s = .477$$

$$u = \frac{r_t}{R_t} = \frac{r_s}{R_s} = .656$$

$$MS = \frac{1}{u} - 1 = +.52$$

COMBINED TENSION
PLUS SHEAR ULTIMATE
GRID 261 SCREW
Gy = 15g

CASE Gy = 15g GRID 21 BOLT

$$F_t = T_3 = 308.3 \text{ LB} \quad \text{APPLIED TENSION}$$

$$F_s = \sqrt{T_1^2 + T_2^2} = \sqrt{86.3^2 + 164.1^2} = 185.4 \text{ LB} \quad \text{APPLIED SHEAR}$$

$$F_L = 1315 \text{ LB PRELOAD}$$

$$S_t = 1315 + 1.4(308.3) = 1747 \text{ LB}$$

$$S_s = 1.4(185.4) = 259.6 \text{ LB}$$

$$r_t = \frac{1747}{2800} = .624$$

$$r_s = \frac{259.6}{1273} = .204$$

$$R_t = .983$$


$$R_s = .320$$

$$u = \frac{r_t}{R_t} = \frac{r_s}{R_s} = .635$$

$$MS = \frac{1}{u} - 1 = +.57$$

COMBINED TENSION
PLUS SHEAR ULTIMATE
GRID 21 SCREW
Gy = 15g

MIL-HDBK-5E
1 June 1987




*Typical interaction curves for combined loading conditions. *Refer to Section 1.5.3.5 for analytical margin of safety.*

THE 2 SHEAR PIN HOLES ARE PER 1356405


Report 10381
Addendum 1

.5964 ϕ HOLES W/ ASSUMED TITANIUM BUSHINGS
.5960 ϕ ALLOY STEEL PINS

ASSUME 1333395-2 & -3 TITANIUM BUSHINGS W/.375 ϕ
ALLOY STEEL PINS. PER 1356404 THE PIN JOINTS
ARE VIEW P & VIEW N





VIEW P 4 4
C
SCALE: 2/1



.086-56UNC-2B THRU ONE WALL
ITEMS 1 AND 28

VIEW N 4 8
C
SCALE: 2/1

1333395 TI-6AL-4V BUSHINGS ARE SCALLOPED ALONG
THE OD, THUS REDUCING THE BEARING AREA TO THE
6061-T6 ALUMINUM BASEPLATE.




SHEAR-TEAROUT OF ALUMINUM BASEPLATE

THE SHEAR LOAD ORIGINATES FROM THE UNIT 15g STATIC SOLUTIONS WITH ALL SHEAR LOAD REACTED ONLY AT THE 2 PINS (NO SPL RESTRAINT IN T1 OR T2 DIRECTIONS FOR THE 20 SCREWS)

MAXIMUM SHEAR LOAD IS AT GR127 PIN FOR GX=15g LOAD

$$F = \sqrt{984.8^2 + 2.0^2} = 985 \text{ LB}$$

THE SHEAR TEAROUT OF THE ALUMINUM LOWER BASEPLATE FOR DIMENSIONS AS NOTED, PER BRUNN, "ANALYSIS AND DESIGN OF AIRPLANE STRUCTURES", 1973, P D1.4-D1.5



$$e = .404$$

$$d = .5960$$

$$t = .375$$

$$\frac{e}{d} = 0.68$$

$$AS = (e - \frac{d}{2} \cos 40)(t)(2) = .132 \text{ IN}^2$$

PER ULTIMATE SF 1.4

$$\tau = \frac{1.4 \times 985}{.132} = 10464 \text{ PSI}$$

SHEAR ALLOWABLE FOR LOWER BASEPLATE (1356405)
6061-T6

$$F_{su} = 27000 \text{ PSI}$$

$$MS = \frac{27000}{10464} - 1 = +1.6 \quad \text{BASEPLATE}$$

BEARING OF 133345-2 BUSHING ONTO ALUMINUM BASEPLATE

WITH PREVIOUSLY DETERMINED MAXIMUM BOLT SHEAR OF

$$F = 985 \text{ LB}$$

BEARING AREA W/O CONSIDERING SCALLOPS IN
133345-2 BUSHING

$$A = (.375 - .010 - .035)(.5936) = .196 \text{ IN}^2$$

SCALLOPS EXIST AROUND 40% OF CIRCUMFERENCE

$$\pi d = \pi(.5936) = 1.865$$

$$\text{REMOVE } 12 \times .062 = .744$$

$$(.744/1.865) \times 100 = 40\%$$

BEARING AREA W/ SCALLOPS

$$A = (.6)(.196) = .118 \text{ IN}^2$$

BEARING STRESS

$$\sigma = \frac{1.25 \times 985}{.118} = 10476 \text{ psi}$$

LIMIT LOAD
W/ 1.25 FS

WITH $e/D = .68 < 1.5$ USE $F_{br} = F_{cy}$

6061-T6 ALUMINUM

$$F_{cy} = 35000 \text{ psi}$$

$$MS = \frac{35000}{10476} - 1 = +2.3$$

BASEPLATE

$$\sigma = \frac{1.4 \times 985}{.118} = 11733 \text{ psi}$$

ULTIMATE LOAD
W/ 1.4 FS

WITH $e/D = .68 < 1.5$ USE $F_{br} = F_{tu} = 42000 \text{ psi}$

$$MS = \frac{42000}{11733} - 1 = +2.6$$

BASEPLATE

RESULTS FOR ALL SHEAR (T1 & T2 FORCES) REACTED
AT SHEAR PINS (GRIDS 127, 147).

EOS AMSU-A1 STATIC ANALYSIS
LAUNCH_SHOCK_LOAD_GX=15

FORCES OF SINGLE - P O I					
POINT ID.	TYPE	T1	T2	T3	
1	G	0.0	0.0	-1.485400E+02	
4	G	0.0	0.0	-3.155964E+01	
7	G	0.0	0.0	-1.606117E+02	
9	G	0.0	0.0	-5.649572E+01	
12	G	0.0	0.0	-1.992761E+01	
15	G	0.0	0.0	1.712983E+01	
17	G	0.0	0.0	1.595522E+02	
21	G	0.0	0.0	1.940879E+02	
85	G	0.0	0.0	-8.084093E+01	
105	G	0.0	0.0	1.166457E+02	
127	G	-9.848364E+02	-1.957444E+00	0.0	
147	G	-6.203901E+02	1.957444E+00	0.0	
169	G	0.0	0.0	-2.474701E+01	
189	G	0.0	0.0	1.065255E+02	
254	G	0.0	0.0	-1.448587E+01	
257	G	0.0	0.0	-3.174564E+01	
261	G	0.0	0.0	-1.137115E+02	
263	G	0.0	0.0	-3.900265E+01	
266	G	0.0	0.0	-1.144709E+01	
269	G	0.0	0.0	5.779668E+00	
271	G	0.0	0.0	8.338869E+01	
275	G	0.0	0.0	5.000587E+01	


EOS AMSU-A1 STATIC ANALYSIS
LAUNCH_SHOCK_LOAD_GY=15

FORCES OF SINGLE - P O I					
POINT ID.	TYPE	T1	T2	T3	
1	G	0.0	0.0	-7.765912E+01	
4	G	0.0	0.0	-3.411418E+01	
7	G	0.0	0.0	-2.643308E+02	
9	G	0.0	0.0	-8.226789E+01	
12	G	0.0	0.0	-7.924261E+01	
15	G	0.0	0.0	-8.992119E+01	
17	G	0.0	0.0	-2.211956E+02	
21	G	0.0	0.0	-2.993695E+02	
85	G	0.0	0.0	-1.207610E+01	
105	G	0.0	0.0	-1.094637E+02	
127	G	8.818773E+00	-6.744928E+02	0.0	
147	G	-8.818773E+00	-9.307338E+02	0.0	
169	G	0.0	0.0	4.529426E+01	
189	G	0.0	0.0	2.281156E+02	
254	G	0.0	0.0	1.687144E+01	
257	G	0.0	0.0	7.181385E+01	
261	G	0.0	0.0	2.525800E+02	
263	G	0.0	0.0	9.802837E+01	
266	G	0.0	0.0	7.032902E+01	
269	G	0.0	0.0	7.296421E+01	
271	G	0.0	0.0	2.327888E+02	
275	G	0.0	0.0	1.808551E+02	

EOS AMSU-A1 STATIC ANALYSIS
LAUNCH_SHOCK_LOAD_GZ=15


FORCES OF SINGLE - P O I					
POINT ID.	TYPE	T1	T2	T3	
1	G	0.0	0.0	-5.179372E+01	
4	G	0.0	0.0	-3.265757E+01	
7	G	0.0	0.0	-2.059886E+02	
9	G	0.0	0.0	-6.171374E+01	
12	G	0.0	0.0	-4.586198E+01	
15	G	0.0	0.0	-4.759489E+01	
17	G	0.0	0.0	-1.416723E+02	
21	G	0.0	0.0	-5.164100E+01	
85	G	0.0	0.0	-5.265801E+01	
105	G	0.0	0.0	-1.266990E+02	
127	G	-1.271475E+01	2.596414E-02	0.0	
147	G	1.271475E+01	-2.596429E-02	0.0	
169	G	0.0	0.0	-5.745068E+01	
189	G	0.0	0.0	-1.748955E+02	
254	G	0.0	0.0	2.310870E-01	
257	G	0.0	0.0	-6.460750E+01	
261	G	0.0	0.0	-1.454034E+02	
263	G	0.0	0.0	-6.695461E+01	
266	G	0.0	0.0	-3.945700E+01	
269	G	0.0	0.0	-3.842529E+01	
271	G	0.0	0.0	-1.582297E+02	
275	G	0.0	0.0	-4.175319E+01	

FROM 1356863 THERMAL INTERFACE CONTROL DWG,
THE BOLT JOINT IS AS FOLLOWS



WHERE THE .435 Ø X .250 THK ISOLATOR IS A
G-10CR SPACER, AND THE .590 OD X .310 THK
ISOLATOR IS A 133395-G SPACER, ALSO G-10CR

THE BASEPLATE HOLE DIMENSIONS ARE PER 1356403
W/SKETCH PER 1356404 VIEW R



COMPRESSION OF G-10CR ISOLATORS UNDER BOLT PRELOAD

MAXIMUM LOAD AS DETERMINED ABOVE FOR 50 IN-LB
PRELOAD TORQUE ($F_L = 1315 \text{ LB}$)

$$F = 1315 \text{ LB}$$

APPLY A $FS = 1.4$ (ULTIMATE) (1.25 LIMIT FOR 6061-T6)

MINIMUM BOLT JOINT BEARING AREAS WITH

BOLT ASSUMED A-286 STEEL $F_{T_u} = 140000 \text{ PSI}$

WASHER ASSUMED ALLOY STEEL $F_{T_u} = 160000 \text{ PSI}$

G-10CR ISOLATORS
(LAMINATES \perp TO CENTERLINE) $F_{T_u} = 60000 \text{ PSI}$

BASEPLATE 6061-T6 ALUM $F_{T_u} = 42000 \text{ PSI}$
 $F_{T_y} = 35000 \text{ PSI}$

BOLT HEAD TO WASHER

ASSUME MS 16775 .190-32UNC SCREW

ASSUME NAS 1149E0363P WASHER

$$\begin{aligned} \text{HEAD OD} & .3125 - 2(.005) = .3025 \text{ MIN} \\ \text{WASHER ID} & .203 + .010 = .213 \text{ MAX} \end{aligned}$$

$$A = \pi/4 (.3025^2 - .213^2) = .0362 \text{ IN}^2 \text{ MIN}$$

$$F/A = \frac{1315}{.0362} = 36240 \text{ PSI}$$

$$MS = \frac{140000}{1.4 \times 36240} - 1 = +1.8 \quad \text{BOLT/WASHER}$$

WASHER TO .435 OD X .250 THK ISOLATOR

ASSUME NAS 1149E0363P WASHER

$$\begin{aligned} \text{WASHER OD} & .438 - .005 = .433 \text{ MIN ID } .213 \text{ MAX} \\ \text{ISOLATOR OD} & .435 - .002 = .433 \text{ MIN (ASSUMED)} \end{aligned}$$

$$A = \pi/4 (.433^2 - .213^2) = .112 \text{ IN}^2 \text{ MIN}$$

$$F/A = \frac{1315}{.112} = 11781 \text{ PSI}$$

$$MS = \frac{60000}{1.4 \times 11781} - 1 = +2.6 \quad \text{ISOLATOR}$$

.435 OD ISOLATOR TO BASEPLATE LEDGE

ISOLATOR OD .433 MIN (ASSUMED)
BASEPLATE ID .287 MAX

$$A = \pi/4 (.433^2 - .287^2) = .083 \text{ IN}^2$$

$$F/A = \frac{1315}{.083} = 15928 \text{ PSL}$$

$$MS = \frac{42000}{1.4 \times 15928} - 1 = +0.88 \quad \text{BASEPLATE}$$

$$MS = \frac{35000}{1.25 \times 15928} - 1 = +0.76 \quad \text{BASEPLATE}$$

BASEPLATE LEDGE TO 1333395-6 .540 OD ISOLATOR

ISOLATOR OD .540 - 2(.030) = .530 MIN
BASEPLATE ID .287 MAX

$$A = \pi/4 (.530^2 - .287^2) = .156 \text{ IN}^2$$

$$F/A = \frac{1315}{.156} = 8433 \text{ PSL}$$

$$MS = \frac{42000}{1.4 \times 8433} - 1 = +2.6 \quad \text{BASEPLATE}$$

$$MS = \frac{35000}{1.25 \times 8433} - 1 = +2.3 \quad \text{BASEPLATE}$$

.590 OD ISOLATOR TO SPACECRAFT

ISOLATOR OD .590 MIN
ISOLATOR ID .224 MAX (ASSUMED)

$$A = \pi/4 (.590^2 - .224^2) = .234 \text{ IN}^2$$

$$F/A = \frac{1315}{.234} = 5620 \text{ PSI}$$

$$MS = \frac{60000}{1.4 \times 5620} - 1 = +6.6 \quad \text{ISOLATOR}$$


SHEAR-TEAROUT OF ALUMINUM BASEPLATE

THE MAXIMUM .190-32UNC SCREW SHEAR LOAD ORIGINATES FROM THE UNIT 15g STATIC SOLUTIONS WITH SHEAR LOAD REACTED AT BOTH THE 20 SCREWS AND 2 SHEAR PINS.

MAXIMUM SHEAR LOAD IS AT GR261 FOR 6Y=15g LOAD

$$F = \sqrt{13.9^2 + 283.9^2} = 284 \text{ LB}$$

THE SHEAR TEAROUT OF THE ALUMINUM LOWER BASEPLATE AT THE LOWER .590 OD ISOLATOR (THIS IS THE ISOLATOR/HOLE WITH THE CLOSE TOLERANCE FIT) PER BRUHN, "ANALYSIS AND DESIGN OF AIRPLANE STRUCTURES", 1973, PD1.4-D1.5



$$e = .404 \quad \frac{e}{d} = 0.68$$

$$d = .5920$$

$$t = .250$$

$$AS = (e - \frac{d}{2} \cos 40) (t) (2) = .089 \text{ IN}^2$$

$$\gamma = \frac{1.4 \times 284}{.089} = 4486 \text{ PSI}$$

SHEAR ALLOWABLE FOR 1356405 6061-T6 LOWER
BASEPLATE

$$F_{su} = 27000 \text{ psi}$$

$$MS = \frac{27000}{4486} - 1 = +5.0 \quad \text{BASEPLATE}$$

BEARING OF .590 OD ISOLATOR ONTO BASEPLATE
HOLE PER MAXIMUM SHEAR LOAD.

MAXIMUM BOLT SHEAR

$$F = 284 \text{ LB}$$

BEARING AREA

$$A = (.590)(.250) = .148 \text{ IN}^2$$

BEARING STRESS

$$\tau = \frac{1.25 \times 284}{.148} = 2407 \text{ psi} \quad \begin{array}{l} \text{LIMIT LOAD} \\ \text{w/ 1.25 FS} \end{array}$$

WITH $e/D = .68 < 1.5$ USE $F_{ory} = F_{cy}$

$$F_{cy} = 35000 \text{ psi} \quad 6061\text{-T6 ALUM}$$

$$MS = \frac{35000}{2407} - 1 = +13 \quad \text{BASEPLATE}$$

WITH $e/D = .68 < 1.5$ USE $F_{bru} = F_{bu}$

$$F_{bu} = 42000 \text{ psi} \quad 6061\text{-T6 ALUM}$$

$$\tau = \frac{1.4 \times 284}{.148} = 2696 \text{ psi}$$

$$MS = \frac{42000}{2696} - 1 = +14 \quad \text{BASEPLATE}$$

FOR ISOLATOR USE $F_{bru} = F_{cu} \text{ EDGE} = 35000 \text{ psi}$

$$MS = \frac{35000}{2696} - 1 = +11 \quad \begin{array}{l} .590 \text{ OD} \\ \text{ISOLATOR} \end{array}$$

THREAD SHEAR OF .190-32UNF SCREW INTO
SPACECRAFT MOUNTING SURFACE

ASSUMPTIONS

- 1) SCREW MAT'L HAS $F_{T_u} = 140000 \text{ PSI}$
- 2) -3A SCREW THREAD
- 2) SPACECRAFT HAS INSERT ALSO WITH $F_{T_u} = 140000 \text{ PSI}$
- 3) LENGTH OF ENGAGEMENT $\geq 1 \text{ DIA}$ ($\geq .190 \text{ IN}$)

SHEAR LOAD 1747 LB (REF GRID 21 GY=15g CASE)

SHEAR AREA

$$A_s = \frac{\pi E L_e}{2}$$

$$E = .1697$$

$$L_e = .190$$

$$= .05065 \text{ IN}$$

WITH $F_S = 1.4$

$$\tau = \frac{1747}{.05065} = 34484 \text{ PSI}$$

$$F_{S_u} = .6 F_{T_u} = .6 (140000) = 84000 \text{ PSI}$$

$$MS = \frac{84000}{34484} - 1 = +1.4$$

\therefore SPACECRAFT MOUNTING JOINT OK
PER ASSUMPTIONS

5.4.3 Thread Shear Stresses in Attachment Hardware per Random Vibration Loads

The following pages contain a detailed analysis of thread shear stresses in attachment hardware per random vibration loads.

TABLE 57 AMSU EOS-A1 THREAD SHEAR PER RANDOM VIBRATION LOADS										
1331650 LOWER RIGHT PANEL TO 1356405 LOWER BASEPLATE										
LOAD CASE	INT/EXT THREADS	PRELOAD LB	APPLIED LOAD LB	APPLIED LOAD FS	JOINT STIFFNESS FACTOR	TOTAL LOAD LB	SHEAR AREA SQ. IN	THREAD SHEAR PSI	ALLOWABLE Fsu PSI	MARGIN OF SAFETY
RANDOM	INTERNAL	399	408	1.4	0.565	722	0.0355	20330	27000	0.33
Y	.216-28UNF-2B									
	BASEPLATE									
	6061-T6									
	EXTERNAL	399	408	1.4	0.565	722	0.025	28869	48000	0.66
	.216-28UNF-2A									
	MS51830-103									
	INSERT									
	CRES 303									
	INTERNAL	399	408	1.4	0.513	692	0.0344	20117	48000	1.39
	.138-32UNRC-3A									
	MS51830-103									
	INSERT									
	CRES 303									
	EXTERNAL	399	408	1.4	0.513	692	0.0287	24112	96000	2.98
	.138-32UNJC-3B									
	MS1352N06-6									
	SCREW									
	ALLOY STEEL									

TABLE 57 AMSU EOS-A1 THREAD SHEAR PER RANDOM VIBRATION LOADS										
1331414 LOWER MOTOR MOUNT PANEL TO 1356405 LOWER BASEPLATE										
LOAD CASE	INT/EXT THREADS	PRELOAD LB	APPLIED LOAD LB	APPLIED LOAD FS	JOINT STIFFNESS FACTOR	TOTAL LOAD LB	SHEAR AREA SQ. IN	THREAD SHEAR PSI	ALLOWABLE Fsu PSI	MARGIN OF SAFETY
RANDOM Y	INTERNAL	399	158	1.4	0.602	532	0.0355	14990	27000	0.80
	.216-28UNF-2B									
	BASEPLATE									
	6061-T6									
	EXTERNAL	399	158	1.4	0.602	532	0.025	21286	48000	1.25
	.216-28UNF-2A									
	MS51830-103									
	INSERT									
	CRES 303									
	INTERNAL	399	158	1.4	0.56	523	0.0344	15200	48000	2.16
	.138-32UNRC-3A									
	MS51830-103									
	INSERT									
	CRES 303									
	EXTERNAL	399	158	1.4	0.56	523	0.0287	18219	96000	4.27
	.138-32UNJC-3B									
	MS1352N06-6									
	SCREW									
	ALLOY STEEL									

TABLE 57 AMSU EOS-A1 THREAD SHEAR PER RANDOM VIBRATION LOADS										
1331447 LOWER RIGHT FRONT SUPPORT PANEL TO 1356405 LOWER BASEPLATE										
LOAD CASE	INT/EXT THREADS	PRELOAD LB	APPLIED LOAD LB	APPLIED LOAD FS	JOINT STIFFNESS FACTOR	TOTAL LOAD LB	SHEAR AREA SQ. IN	THREAD SHEAR PSI	ALLOWABLE Fsu PSI	MARGIN OF SAFETY
RANDOM	INTERNAL	399	110	1.4	0.606	492	0.0355	13868	27000	0.95
Y	.216-28UNF-2B									
	BASEPLATE									
	6061-T6									
	EXTERNAL	399	110	1.4	0.606	492	0.025	19693	48000	1.44
	.216-28UNF-2A									
	MS51830-103									
	INSERT									
	CRES 303									
	INTERNAL	399	110	1.4	0.565	486	0.0344	14128	48000	2.40
	.138-32UNRC-3A									
	MS51830-103									
	INSERT									
	CRES 303									
	EXTERNAL	399	110	1.4	0.565	486	0.0287	16934	96000	4.67
	.138-32UNJC-3B									
	MS1352N06-6									
	SCREW									
	ALLOY STEEL									

TABLE 57 AMSU EOS-A1 THREAD SHEAR PER RANDOM VIBRATION LOADS										
1331652 LOWER AFT PANEL TO 1356405 LOWER BASEPLATE										
LOAD CASE	INT/EXT THREADS	PRELOAD LB	APPLIED LOAD LB	APPLIED LOAD FS	JOINT STIFFNESS FACTOR	TOTAL LOAD LB	SHEAR AREA SQ. IN	THREAD SHEAR PSI	ALLOWABLE Fsu PSI	MARGIN OF SAFETY
RANDOM	INTERNAL	399	946	1.4	0.434	974	0.0341	28557	84000	1.94
Y	.138-32UNJC-3B									
	MF1331-06									
	ANCHOR NUT									
	A286 STEEL									
	EXTERNAL	399	946	1.4	0.434	974	0.0208	46817	96000	1.05
	.138-32UNRC-3A									
	NAS1352N06-8									
	SCREW									
	ALLOY STEEL									
1331642 UPPER AFT PANEL TO 1331356 UPPER BASEPLATE										
		LB	LB	FS	FACTOR	LB	SQ. IN	PSI	PSI	SAFETY
RANDOM	INTERNAL	399	499	1.4	0.362	652	0.0341	19117	84000	3.39
X	.138-32UNJC-3B									
	MF1331-06									
	ANCHOR NUT									
	A286 STEEL									
	EXTERNAL	399	499	1.4	0.362	652	0.0208	31341	96000	2.06
	.138-32UNRC-3A									
	NAS1352N06-10									
	SCREW									
	ALLOY STEEL									

TABLE 57 AMSU EOS-A1 THREAD SHEAR PER RANDOM VIBRATION LOADS										
1331651 UPPER RIGHT PANEL TO 1331356 UPPER BASEPLATE										
LOAD CASE	INT/EXT THREADS	PRELOAD LB	APPLIED LOAD LB	APPLIED LOAD FS	JOINT STIFFNESS FACTOR	TOTAL LOAD LB	SHEAR AREA SQ. IN	THREAD SHEAR PSI	ALLOWABLE Fsu PSI	MARGIN OF SAFETY
RANDOM	INTERNAL	399	161	1.4	0.322	472	0.0341	13829	84000	5.07
Y	.138-32UNJC-3B									
	MF1331-06									
	ANCHOR NUT									
	A286 STEEL									
	EXTERNAL	399	161	1.4	0.322	472	0.0208	22672	96000	3.23
	.138-32UNRC-3A									
	NAS1352N06-10									
	SCREW									
	ALLOY STEEL									
1331389 UPPER MOTOR MOUNT PANEL TO 1331390 UPPER RIGHT FRONT SUPPORT PANEL										
		LB	LB	FS	FACTOR	LB	SQ. IN	PSI	PSI	SAFETY
RANDOM	INTERNAL	399	207	1.4	0.505	545	0.0341	15993	84000	4.25
Y	.138-32UNJC-3B									
	MF1331-06									
	ANCHOR NUT									
	A286 STEEL									
	EXTERNAL	399	207	1.4	0.505	545	0.0208	26219	96000	2.66
	.138-32UNRC-3A									
	NAS1352N06-6									
	SCREW									
	ALLOY STEEL									

TABLE 57 AMSU EOS-A1 THREAD SHEAR PER RANDOM VIBRATION LOADS										
1331401 LOWER FRONT PANEL TO 1356405 LOWER BASEPLATE										
LOAD CASE	INT/EXT THREADS	PRELOAD LB	APPLIED LOAD LB	APPLIED LOAD FS	JOINT STIFFNESS FACTOR	TOTAL LOAD LB	SHEAR AREA SQ. IN	THREAD SHEAR PSI	ALLOWABLE Fsu PSI	MARGIN OF SAFETY
RANDOM	INTERNAL	399	277	1.4	0.457	576	0.0341	16898	84000	3.97
Y	.138-32UNJC-3B									
	MF1331-06									
	ANCHOR NUT									
	A286 STEEL									
	EXTERNAL	399	277	1.4	0.457	576	0.0208	27703	96000	2.47
	.138-32UNRC-3A									
	NAS1352N06-6									
	SCREW									
	ALLOY STEEL									
TABLE 57 AMSU EOS-A1 THREAD SHEAR PER RANDOM VIBRATION LOADS										
1331401 LOWER FRONT PANEL TO 1356405 LOWER BASEPLATE										
RANDOM	INTERNAL	399	277	1.4	0.586	626	0.0355	17641	27000	0.53
Y	.216-28UNF-2B									
	PANEL									
	6061-T6									
	EXTERNAL	399	277	1.4	0.586	626	0.025	25050	48000	0.92
	.216-28UNF-2A									
	MS51830-103									
	INSERT									
	CRES 303									
	INTERNAL	399	277	1.4	0.541	609	0.0344	17698	48000	1.71
	.138-32UNRC-3A									
	MS51830-103									
	INSERT									
	CRES 303									
	EXTERNAL	399	277	1.4	0.541	609	0.0287	21213	96000	3.53
	.138-32UNJC-3B									
	MS1352N06-6									
	SCREW									
	ALLOY STEEL									

TABLE 57 AMSU EOS-A1 THREAD SHEAR PER RANDOM VIBRATION LOADS

1331389 UPPER MOTOR MOUNT PANEL TO 1331356 UPPER BASEPLATE										
LOAD CASE	INT/EXT THREADS	PRELOAD LB	APPLIED LOAD LB	APPLIED LOAD FS	JOINT STIFFNESS FACTOR	TOTAL LOAD LB	SHEAR AREA SQ. IN	THREAD SHEAR PSI	ALLOWABLE Fsu PSI	MARGIN OF SAFETY
RANDOM	INTERNAL	399	134	1.4	0.601	512	0.0355	14415	27000	0.87
Y	.216-28UNF-2B									
	BASEPLATE									
	6061-T6									
	EXTERNAL	399	134	1.4	0.601	512	0.025	20470	48000	1.34
	.216-28UNF-2A									
	MS51830-103									
	INSERT									
	CRES 303									
	INTERNAL	399	134	1.4	0.561	504	0.0344	14658	48000	2.27
	.138-32UNRC-3A									
	MS51830-103									
	INSERT									
	CRES 303									
	EXTERNAL	399	134	1.4	0.561	504	0.0287	17569	96000	4.46
	.138-32UNJC-3B									
	MS1352N06-6									
	SCREW									
	ALLOY STEEL									

TABLE 57 AMSU EOS-A1 THREAD SHEAR PER RANDOM VIBRATION LOADS										
1331352 UPPER FRONT PANEL TO 1331356 UPPER BASEPLATE										
LOAD CASE	INT/EXT THREADS	PRELOAD LB	APPLIED LOAD LB	APPLIED LOAD FS	JOINT STIFFNESS FACTOR	TOTAL LOAD LB	SHEAR AREA SQ. IN	THREAD SHEAR PSI	ALLOWABLE Fsu PSI	MARGIN OF SAFETY
RANDOM	INTERNAL	399	111	1.4	0.605	493	0.0355	13888	27000	0.94
Y	.216-28UNF-2B									
	BASEPLATE									
	6061-T6									
	EXTERNAL	399	111	1.4	0.605	493	0.025	19721	48000	1.43
	.216-28UNF-2A									
	MS51830-103									
	INSERT									
	CRES 303									
	INTERNAL	399	111	1.4	0.566	487	0.0344	14156	48000	2.39
	.138-32UNRC-3A									
	MS51830-103									
	INSERT									
	CRES 303									
	EXTERNAL	399	111	1.4	0.566	487	0.0287	16967	96000	4.66
	.138-32UNJC-3B									
	MS1352N06-6									
	SCREW									
	ALLOY STEEL									

TABLE 57 AMSU EOS-A1 THREAD SHEAR PER RANDOM VIBRATION LOADS										
1331390 UPPER RIGHT FRONT SUPPORT PANEL TO 1331356 UPPER BASEPLATE										
LOAD CASE	INT/EXT THREADS	PRELOAD LB	APPLIED LOAD LB	APPLIED LOAD FS	JOINT STIFFNESS FACTOR	TOTAL LOAD LB	SHEAR AREA SQ. IN	THREAD SHEAR PSI	ALLOWABLE Fsu PSI	MARGIN OF SAFETY
RANDOM Y	INTERNAL	399	187	1.4	0.586	552	0.0355	15561	27000	0.74
	.216-28UNF-2B									
	BASEPLATE									
	6061-T6									
	EXTERNAL	399	187	1.4	0.586	552	0.025	22097	48000	1.17
	.216-28UNF-2A									
	MS51830-103									
	INSERT									
	CRES 303									
	INTERNAL	399	187	1.4	0.541	541	0.0344	15716	48000	2.05
	.138-32UNRC-3A									
	MS51830-103									
	INTERNAL	399	187	1.4	0.541	541	0.0287	18837	96000	4.10
	.138-32UNJC-3B									
	MS1352N06-6									
	SCREW									
	ALLOY STEEL									

12-6-95

THREAD SHEAR- MS 51830-103 INSERTS
1331650 LOWER RIGHT PANEL TO
1356405 LOWER BASE PLATE

USE RANDOM VIBRATION NASTRAN "ELFORCE" DATA
AS LOAD. PER LOWER FLANGE BENDING
STRESS/ BOLT TENSILE STRESS EVALUATION, THE
FORCE @ THE NAS 1352 NØ6-6 SCREW IS:

$$F_1 = 3 \times 105.88 \text{ LB/IN} = 317.64 \text{ LB/IN} \quad "3T"$$

W/15 SCREWS IN 19.29 INCHES

LOAD PER SCREW, P

$$P = \frac{19.29}{15} (317.64) = 408 \text{ LB}$$

FACTOR OF SAFETY ON P


$$FS = 1.4$$

PRELOAD (9-11 IN-LB TORQUE)

$$T = .2 F_L d$$


$$d = .138$$

$$F_L = 11 / (.2)(.138) = 399 \text{ LB}$$



1356405 LOWER BASE PLATE

M551830-103 W3875-ITEM 5



VIEW M-M 1E

M551830-103

15 TO 1331650 LOWER RIGHT PANEL
4 1331414 LOWER MOTOR MOUNT PANEL
3 1331447 LOWER RIGHT FRONT SUPPORT PANEL

FOR NAS1352NØ6 SCREW TO EXTEND BEYOND
INSERT REQUIRES A -6 SCREW OF $L = .375$ IN.
A -6 SCREW OF .375 IN. LENGTH IS ADEQUATE WITH
THE MS51830-103 INSERT

BASEPLATE INT THD TO INSERT EXT THD

. 216-28 UNF-2A EXT THD IN MS51830-103
. 216-28 UNF-2B INT THD IN BASEPLATE

ENGAGEMENT LENGTH

$$L_e = .125 - .010 - \frac{1}{n} \quad n = 28$$

$$= .1079 \text{ IN}$$

MAT'L

GRES 302 $F_{su} = .6(80000) = 48000 \text{ psi}$ INSERT
6061-T6 $F_{su} = 24000 \text{ psi}$ BASEPLATE

THREAD SHEAR AREA (H-28 APP A5)

INT THD

$$A_{Sn} = \pi n L_e D_{smin} \left[\frac{1}{2} n + .57735 (D_{smin} - E_{nmax}) \right]$$

$$n = 28$$

$$L_e = .1079$$

$$D_{smin} = .2085$$

MIN MAJOR EXT

$$E_{nmax} = .1970$$

MAX PITCH INT

$$A_{Sn} = .0355 \text{ IN}^2$$

EXT THD

$$A_{Se} = \pi n L_e K_{nmax} \left[\frac{1}{2} n + .57735 (E_{smin} - K_{nmax}) \right]$$

$$K_{nmax} = .186$$

MAX MINOR INT

$$E_{smin} = .1886$$

MIN PITCH EXT

$$A_{Se} = .0250 \text{ IN}^2$$

JOINT STIFFNESS

PER SHIGLEY, MECHANICAL ENGINEERING DESIGN,
4TH EDITION, 1983, P371-376, WITH ASSUMPTIONS
USE d = INSERT NOMINAL ϕ , .216 IN

$$F_b = \frac{k_b P}{k_b + k_m} + F_L$$

b = BOLT
 m = MEMBER

$$k_b = \frac{EA}{L}$$

$$E = 29 \times 10^6 \text{ PSI}$$

$$A = \pi/4 (.216)^2 = .0366 \text{ IN}^2$$

$$L = .032 + .105 + .015 = .152 \text{ IN}$$

GRIP LENGTH

$$= 6.991 \times 10^6 \text{ LB/IN}$$

$$k_m = \frac{\pi E d}{2 \ln \left[5 \frac{L + d/2}{L + 2.5d} \right]}$$

$$E = 10 \times 10^6 \text{ PSI}$$

$$d = .216 \text{ IN}$$

$$L = .152 \text{ IN}$$

$$= 5.381 \times 10^6 \text{ LB/IN}$$

$w/E = 10 \times 10^6 \text{ PSI}$
WHOLE GRIP LENGTH

TOTAL SCREW TENSILE LOAD

$$P = 1.4 F = 1.4(408) = 571 \text{ LB}$$

$$F_L = 399 \text{ LB}$$

$$F_b = (.565)(571) + 399 = 722 \text{ LB}$$

SHEAR STRESS

BASEPLATE 6061-T6 INT THD

$$\tau = \frac{F_b}{A_{S_n}} = \frac{722}{.0355} = 20335 \text{ PSI}$$

$$MS = \frac{27000}{20335} - 1 = +.33 \quad \text{BASEPLATE}$$

∴ THREAD SHEAR OK IN BASEPLATE 10 THDS

MS51830-103 INSERT CRES EXT THD

$$\gamma = \frac{F_b}{A_{S_s}} = \frac{722}{.0250} = 28880 \text{ psi}$$

$$m_s = \frac{48000}{28880} - 1 = +.66 \quad \text{INSERT}$$

∴ THREAD SHEAR OK IN INSERT OD THDS

MS51830-103 INT THD TO MS1352NØ6-6 SCREW EXT THD

- 138-32 UNRL-3A EXT THD MS1352NØ6
- 138-32 UNJL-3B INT THD MS51830-103

ENGAGEMENT LENGTH

$$l_e = .170 - .015 - 1/n \quad n = 32$$

$$= .124 \text{ IN}$$

MATERIAL

ALLOY STEEL $F_{Su} = .6(160000) = 96000 \text{ psi}$ SCREW

CRES 303 $F_{Su} = .6(80000) = 48000 \text{ psi}$ INSERT

THREAD SHEAR AREA (H-28 APPA5)

INT THD

$$A_{S_n} = \pi E \frac{3l_e}{4}$$

$$= .10344 \text{ IN}^2$$

$$l_e = .124$$

$$E = \text{BASIC PITCH } \phi .1177 \text{ IN}$$

$$A_{S_s} = \pi E \frac{5l_e}{8}$$

$$= .0287 \text{ IN}^2$$

JOINT STIFFNESS

$$F_b = \frac{k_b}{k_b + k_m} P + F_i$$

b = BOLT
m = MEMBER

$$k_b = \frac{EA}{L_{GRIP}}$$

$$= 2.854 \times 10^6 \text{ LB/IN}$$

$$E = 29 \times 10^6 \text{ PSI}$$

$$A = \pi/4 (.138)^2 = .0150 \text{ IN}^2$$

$$L = .032 + .105 + .015 = .152 \text{ IN}$$

GRIP LENGTH

$$k_m = \frac{\pi E d}{2 L_n \left[5 \frac{d + d/2}{L + 2.5d} \right]}$$

$$= 2.713 \times 10^6 \text{ LB/IN}$$

$$E = 10 \times 10^6 \text{ PSI}$$

$$d = .138 \text{ IN}$$

$$L = .152 \text{ IN}$$

W/B = 10 x 10⁶ PSI ASSUMED
ENTIRE GRIP LENGTH

TOTAL SCREW TENSILE LOAD

$$P = 1.4 F = 1.4(408) = 571 \text{ LB}$$

$$F_L = 399 \text{ LB}$$

$$F_b = (.513)(571) + 399 = 692 \text{ LB}$$

SHEAR STRESS

MS51830-102 INSERT LRES INT TND

$$\gamma = \frac{F_b}{A_{Sn}} = \frac{692}{.03414} = 20108 \text{ PSI}$$

$$MS = \frac{48000}{20108} - 1 = +1.4 \quad \text{INSERT}$$

∴ THREAD SHEAR OK IN INSERT ID TND

MS1352N06 SCREW STEEL EXT TND (NEXT RESIST)

$$\gamma = \frac{F_b}{A_{Ss}} = \frac{692}{.0287} = 24111 \text{ PSI}$$

$$MS = \frac{96000}{24111} - 1 = +3.0 \quad \text{SCREW}$$

∴ THREAD SHEAR OK IN SCREW ID TND

12-7-45

1331414 LOWER MOTOR MOUNT PANEL TO
1356405 LOWER BASEPLATE

FORCE @ NAS1352NØ6-6 SCREW IS

$$F_1 = 3 \times 29.84 \text{ LB/IN} = 89.52 \text{ LB/IN} \quad \text{"3V RANDOM"}$$

W/ 6 SCREWS IN 10.562 IN

LOAD PER SCREW, P


$$P = \frac{10.562}{6} (89.52) = 157.6 \text{ LB}$$

FACTOR OF SAFETY ON P

$$FS = 1.4$$

PRELOAD (9-11 IN-LB TORQUE)

$$F_i = 11 / (.62) (.138) = 399 \text{ LB}$$



THE NAS1352NØ6-6 SCREW (L=.375 IN) WILL EXTEND BEYOND INSERT THREADS. FULL L OF INSERT ID LENGTH IS MADE.

BASEPLATE INT THD TO INSERT EXT THD.216-28UNF-2A
.216-28UNF-2AINSERT MSS1830-103
BASEPLATE

$$L_e = .125 - .010 - 1/n = .079 \text{ IN}$$

$$n = 28$$

$$F_{su} = 48000 \text{ psi INSERT}$$

$$F_{su} = 27000 \text{ psi BASEPLATE}$$

$$A_{sn} = .0355 \text{ IN}^2$$

$$A_{ss} = .0250 \text{ IN}^2$$

JOINT STIFFNESS

$$F_b = \frac{k_b}{k_b + k_m} P + F_i$$

$$k_b = \frac{EA}{L_{GRIP}}$$

$$= 10.418 \times 10^6 \text{ LB/IN}$$

$$k_m = \frac{\pi E d}{2 \ln \left[5 \frac{L + d/2}{L + 2.5d} \right]}$$

$$= 6.897 \times 10^6 \text{ LB/IN}$$

$$E = 29 \times 10^6 \text{ psi}$$

$$A = \pi/4 (.216)^2 = .0366 \text{ IN}^2$$

$$L = .032 + .055 + .015$$

$$= .102 \text{ IN}$$

GRIP LENGTH

$$E = 10 \times 10^6 \text{ psi}$$

$$d = .216 \text{ IN}$$

$$L = .102 \text{ IN}$$

TOTAL SCREW TENSILE LOAD

$$F_b = (.602)(1.4)(157.6) + 399 = 532 \text{ LB}$$

SHEAR STRESSBASEPLATE LOG1-T6 INT THD

$$\tau = \frac{F_b}{A_{sn}} = \frac{532}{.0355} = 14980 \text{ psi}$$

$$MS = \frac{27000}{14980} - 1 = +.80 \text{ BASEPLATE}$$

∴ THREAD SHEAR OK IN BASEPLATE

MS51830-103 INSERT CRES EXT THD

$$\gamma = \frac{F_b}{AS_s} = \frac{532}{.0250} = 21280 \text{ psi}$$

$$MS = \frac{48000}{21280} - 1 = +1.3 \quad \text{INSERT}$$

∴ THREAD SHEAR OK IN INSERT EXT THDS

MS51830-103 INT THD TO MS1352N06-6 SCREW EXT THD

.138-32UNRC-3A EXT THD MS1352N06
.138-32UNJL-3B INT THD MS51830-103

$$L = .170 - .015 - \frac{1}{n} \quad n = 32$$

$$= .124 \text{ IN}$$

$$F_{su} = 96000 \text{ psi} \quad \text{SCREW}$$

$$F_{su} = 48000 \text{ psi} \quad \text{INSERT}$$

$$AS_n = .0344 \text{ IN}^2$$

$$AS_s = .0287 \text{ IN}^2$$

$$k_b = \frac{EA}{L} \quad L = .102 \text{ IN}$$

$$= 4.253 \times 10^6 \text{ LB/IN} \quad A = .0150 \text{ IN}^2$$

$$E = 29 \times 10^6 \text{ psi}$$

$$k_m = 3.342 \times 10^6 \text{ LB/IN}$$

$$F_b = (.560)(1.4)(157.6) + 399 = 523 \text{ LB}$$

SHEAR STRESS

MS51830-103 INSERT CRES INT THD

$$\gamma = \frac{F_b}{AS_n} = \frac{523}{.0344} = 15191 \text{ psi}$$

$$MS = \frac{48000}{15191} - 1 = +2.2 \quad \text{INSERT}$$

∴ THREAD SHEAR OK IN INSERT ID THDS

NAS1352NØ6 SCREW STEEL EXT THD (HEAT RESISTANT)

$$\gamma = \frac{F_b}{A_{S_6}} = \frac{523}{.0287} = 18223 \text{ PSI}$$

$$MS = \frac{96000}{18223} - 1 = +4.3 \quad \text{SCREW}$$

∴ THREAD SHEAR OK IN SCREW EXT THDS

1331447 LOWER RIGHT FRONT SUPPORT PANEL TO
1356405 LOWER BASEPLATE

FORCE IN NAS1352NØ6-6 SCREW IS

$$F_1 = 3 \times 16.844 = 50.53 \text{ LB/IN} \quad \text{"3 RANDOM"}$$

W/ 3 SCREWS IN 6.500 IN, LOAD PER SCREW


$$P = \frac{6.500}{3} (50.53) = 109.5 \text{ LB}$$

FACTOR OF SAFETY ON P, 1.4

PRELOAD @ 1170-LB TORQUE

$$F_L = 11 / (.2)(1.38) = 399 \text{ LB}$$

THE NAS1352NØ6-6 SCREW LENGTH, .375, IS ADEQUATE TO ENGAGE ENTIRE INSERT THREADS.



BASEPLATE INT THD TO INSERT EXT THD

$$L_e = .125 - .010 - 1/n = .079 \text{ IN} \quad n = 28$$

$$A_{S_n} = .0355 \text{ IN}^2$$

$$A_{S_s} = .0250 \text{ IN}^2$$

JOINT STIFFNESS

$$F_b = \frac{k_b}{k_b + k_m} P + F_i$$

$$k_b = \frac{EA}{L}$$

$$= 10.955 \times 10^6 \text{ LB/IN}$$

$$k_m = \frac{\pi E d}{2 \ln \left[5 \frac{Q + d/2}{Q + 2.5d} \right]}$$

$$= 7.133 \times 10^6 \text{ LB/IN}$$

$$E = 29 \times 10^6 \text{ PSI}$$

$$A = \pi/4 (1.216)^2 = .0366 \text{ IN}^2$$

$$Q = .032 + .050 .015 = .097 \text{ IN}$$

$$E = 10 \times 10^6 \text{ PSI}$$

$$d = .216 \text{ IN}$$

$$Q = .097 \text{ IN}$$

TOTAL SCREW TENSILE LOAD

$$F_b = (.606)(1.4)(109.5) + 399 = 492 \text{ LB}$$

SHEAR STRESSBASEPLATE 6061-T6 INT THD

$$\tau = \frac{F_b}{A_{S_n}} = \frac{492}{.0355} = 13855 \text{ PSI}$$

$$MS = \frac{27000}{13855} - 1 = +.95 \quad \text{BASEPLATE}$$

∴ THREAD SHEAR OK IN BASEPLATE

MS 51830-103 INSERT CRES EXT THD

$$\tau = \frac{F_b}{A_{S_s}} = \frac{492}{.0250} = 19680 \text{ PSI}$$

$$MS = \frac{48000}{19680} - 1 = +1.4 \quad \text{INSERT}$$

∴ THREAD SHEAR OK IN INSERT EXT THDS

MS51830 INT THD TO MS1352NØ6-6 SCREW EXT THD

$$d_e = .175 - .015 - \frac{1}{16} = .124 \text{ IN}$$

$$n = 22$$

$$A_{S_n} = .0344 \text{ IN}^2$$

$$A_{S_s} = .0287 \text{ IN}^2$$

$$k_b = 4.471 \times 10^6 \text{ LB/IN}$$

$$k_m = 3.440 \times 10^6 \text{ LB/IN}$$

$$F_b = (.565)(1.4)(109.5) + 399 = 486 \text{ LB}$$

SHEAR STRESS

MS51830 INSERT CPES INT THD

$$\gamma = \frac{F_b}{A_{S_n}} = \frac{486}{.0344} = 14117 \text{ PSI}$$

$$MS = \frac{48000}{14117} - 1 = +2.4 \quad \text{INSERT}$$

∴ THREAD SHEAR OK IN INSERT INT THDS

MS1352NØ6 SCREW HEAT RESISTANT STEEL EXT THD

$$\gamma = \frac{F_b}{A_{S_s}} = \frac{486}{.0287} - 1 = 16934 \text{ PSI}$$

$$MS = \frac{96000}{16934} - 1 = +4.7 \quad \text{SCREW}$$

∴ THREAD SHEAR OK IN SCREW EXT THDS

THREAD SHEAR - MF1301 ANCHOR NUTS

1331652 LOWER AFT PANEL TO 1356405 LOWER BASEPLATE VIA MF1331-06 ANCHORS

USE RANDOM VIBRATION NASTRAN "ELFORC" DATA AS LOAD. PER LOWER AFT PANEL LOWER FLANGE BENDING STRESS/ BOLT TENSILE STRESS EVALUATION, THE FORCE @ THE NAS1352 NØ6-8 SCREW IS:

$$F_1 = 3 \times 238.8 = 716.4 \text{ LB/IN} \quad "3T"$$

WITH 8 SCREWS IN 10.563 IN, THE LOAD PER SCREW, P, IS


$$P = \frac{10.563}{8} (716.4) = 946 \text{ LB}$$

FACTOR OF SAFETY ON EXTERNAL LOAD, P, IS 1.4

PRELOAD (11 IN-LB MAX TORQUE)

$$F_L = T / .20 \quad d = .138$$

$$F_L = 11 / (.2)(.138) = 399 \text{ LB}$$



FOR THE NAS1352NØ6 SCREW TO EXTEND BEYOND THE NUT PLATE, UTILIZING THE FULL COMPLIMENT OF NUTPLATE THREADS, ITS LENGTH MUST EXCEED

$$\ell = .032 + .075 + .130 + .171 = .408 \text{ IN}$$

THUS A -8 ℓ = .500 IN SCREW IS REQ'D.

MF1331-06 NUT PLATE INT THREADS TO NAS1352N06-8 SCREW

.1380-32 UNJC-3B MF1331-06 INT THD
.1380-32 UNRL-3A NAS1352N06-8 EXT THD

ENGAGEMENT LENGTH

$$l_e = .171 - .025 - \frac{1}{n} = .115 \text{ IN} \quad n = 32$$

MAT'L

A286 STEEL $F_{su} = .6(140000) = 84000 \text{ psi}$ ASSUMED NUT PLATE
HEAT TREATED (REF MSS1830 A-286 $F_{tu} = 140000 \text{ psi}$) F_{tu}
ALLOY STEEL $F_{su} = .6(160000) = 96000 \text{ psi}$ SCREW

THREAD SHEAR AREA (H-28)

INT THD

$$A_{S_n} = \pi n l_e D_{smin} \left[\frac{1}{2}n + .57735 (D_{smin} - E_{nmax}) \right]$$

$$n = 32$$

$$l_e = .115$$

$$D_{smin} = .1320$$

$$E_{nmax} = .1204$$

$$A_{S_n} = .0341 \text{ IN}^2$$

$$A_{S_g} = \pi n l_e K_{nmax} \left[\frac{1}{2}n + .57735 (E_{smin} - K_{nmax}) \right]$$

$$K_{nmax} = .1157 \text{ IN}$$

$$E_{smin} = .1156 \text{ IN}$$

$$A_{S_g} = .0208 \text{ IN}^2$$

JOINT STIFFNESS

PER SNIGLEY, MECHANICAL ENGINEERING DESIGN,
4TH ED, 1983, P371-376, WITH ASSUMPTIONS,

$$F_b = \frac{k_b P}{k_b + k_m} + F_i$$

b = BOLT
m = MEMBER

$$k_b = \frac{EA}{L}$$

$$= 1.656 \times 10^6 \text{ LB/IN}$$

$$E = 29 \times 10^6 \text{ PSI}$$

$$A = \pi/4 (.138)^2 = .0150 \text{ IN}^2$$

$$L = \text{GRIP LENGTH}$$

$$= .032 + .075 + .130 + .025 = .262 \text{ IN}$$

$$k_m = \frac{\pi E d}{2 \ln \left[5 \frac{L + d/2}{L + 2.5d} \right]}$$

$$= 2.161 \times 10^6 \text{ LB/IN}$$

$$E = 10 \times 10^6 \text{ PSI}$$

$$d = .138 \text{ IN}$$

$$L = .262 \text{ IN}$$

TOTAL SCREW TENSILE LOAD

$$F_b = (F_s)(P) + (F_i)$$

$$P_b = \frac{k_b}{k_b + k_m} \quad P = (.434)(946) = 410 \text{ LB}$$

$$F_b = (1.4)(410) + 399 = 474 \text{ LB}$$

SHEAR STRESS

NUT PLATE A-286 INT THD

$$\tau = \frac{F_b}{A_{S_n}} = \frac{474}{.0341} = 28600 \text{ PSI}$$

$$MS = \frac{84000}{28600} - 1 = +1.9 \quad \text{NUT PLATE}$$

SCREW HEAT RESIST STEEL EXT THD

$$\tau = \frac{F_b}{A_{S_s}} = \frac{474}{.0208} = 46775 \text{ PSI}$$

$$MS = \frac{96000}{46775} - 1 = +1.1 \quad \text{SCREW}$$

∴ BOTH NUT PLATE & SCREW ARE OK FOR
THREAD SHEAR

1331642 UPPER AFT PANEL TO
1331356 UPPER BASEPLATE VIA MF1331-06 ANCHOR NUTS

FORUS @ MF1331-06 NUT PLATE / NAS1352N06-10 SCREW

$$F_1 = 3 \times 127.83 = 383.49 \text{ LB/IN} \quad "3\text{T LOADS}"$$

W/ 9 SCREWS IN 11.7 IN

LOAD PER SCREW, P

$$P = \left(\frac{11.7}{9}\right)(383.49) = 498.5 \text{ LB}$$

FS \Rightarrow 1.4 ON P


PRELOAD @ 11 IN-LB TORQUE

$$F_L = 11/(.2)(.138) = 399 \text{ LB}$$

FOR THE NAS1352N06 SCREW TO EXTEND BEYOND NUT PLATE, UTILIZING FULL COMPLIMENT OF NUTPLATE THREADS, ITS LENGTH MUST EXCEED

$$L = .032 + .250 + .100 + .171 = .553$$

THUS A -10 (L=.625) IS REQ'D



PREVIOUS 1331642 FLANGET WAS .065 (NOW .100)
@ .065, THE REQ'D SCREW LENGTH WOULD BE

$$L = .032 + .250 + .065 + .171 = .518$$

THUS PREVIOUS -8 (L=.500) WOULD HAVE BEEN TOO SHORT

.1380-32 UNJC-3B

MF1331-06 NUT PLATE

.1380-32 UNJC-3A

NAS1352N06-6 SCREW

ENGAGEMENT LENGTH

$$L_e = .171 - .025 - 1/4$$

$$n = 32$$

$$= .115 \text{ IN}$$

$$F_{su} = 84000 \text{ psi}$$

NUT PLATE

$$F_{su} = 96000 \text{ psi}$$

SCREW

$$A_{sn} = .0341 \text{ IN}^2$$

$$A_{ss} = .0208 \text{ IN}^2$$

JOINT STIFFNESS

$$F_b = \frac{k_b}{k_b + k_m} P + F_i$$

$$k_b = \frac{EA}{L_{GRIP}}$$

$$= 1.066 \times 10^6 \text{ LB/IN}$$

$$k_m = \frac{\pi E d}{2 \ln \left[5 \frac{L + d/2}{L + 2.5d} \right]}$$

$$= 1.881 \times 10^6 \text{ LB/IN}$$

$$E = 29 \times 10^6 \text{ psi}$$

$$A = \pi/4 (.138)^2 = .0150 \text{ IN}^2$$

$$L = .032 + .250 + .100$$

$$+ .025 = .407 \text{ IN}$$

$$E = 10 \times 10^6 \text{ psi}$$

$$d = .138 \text{ IN}$$

$$L = .407 \text{ IN}$$

TOTAL SCREW LOAD

$$F_b = (FS)(P) + F_i$$

$$P_b = \frac{k_b}{k_b + k_m} P = (.362)(498.5) = 180.3 \text{ LB}$$

$$F_b = (1.4)(180.3) + 399 = 651.4$$

SHEAR STRESS

NUT PLATE A-286 INT THD

$$\tau = \frac{F_b}{A_{sn}} = \frac{651.4}{.0341} = 19102 \text{ psi}$$

$$MS = \frac{84000}{19102} - 1 = + 3.4 \quad \text{NUTPLATE}$$

SCREW HEAT RESISTANT STEEL EXT TND

$$\gamma = \frac{F_b}{AS_s} = \frac{651.4}{.0208} = 31317 \text{ PSI}$$

$$MS = \frac{96000}{31317} - 1 = + 2.1 \quad \text{SCREW}$$

∴ BOTH NUTPLATE & SCREW ARE OK FOR
THREAD SHEAR

ADDITIONAL PANEL ATTACHMENTS

Report 10381
Addendum 1

1331051 UPPER RIGHT PANEL TO
1331356 UPPER BASEPLATE

MF1331-06 NUT PLATES

$$F_1 = 3 \times 42.82 = 128.46 \text{ LB/IN} \quad "3\pi"$$

u/7 SCREWS NAS1352N06-10 IN 8.783 IN

$$P = \frac{8.783}{7} 128.46 = 161.18 \text{ LB}$$

$$FS = 1.4 \text{ ON P}$$

$$FL = 399 \text{ LB (PRELOAD)}$$

USES NAS1352N06-10 SCREWS ($d = .625 \text{ IN}$)

$L_{GRIP} =$.250	t	UPPER BASEPLATE
	.065	t	UPPER RIGHT PANEL FLANGE
	.171	t	NUT PLATE MF1331-06
	.037	t	NAS62066 WASHER
	<u>.518</u>		

$$L_e = .171 - .025 - \frac{1}{4}n = .115 \text{ IN}$$

$$AS_n = .0341 \text{ IN}^2$$

$$AS_s = .0208 \text{ IN}^2$$

$$k_b = \frac{(29 \times 10^6)(.0150)}{(.518)} = 840 \times 10^3 \text{ LB/IN}$$

$$k_{em} = \frac{\pi (10 \times 10^6)(.138)}{2 \ln \left[5 \frac{.518 + .138/2}{.518 + 2.5(.138)} \right]} = 1771 \times 10^3 \text{ LB/IN}$$

$$F_b = (1.4)(.322)(161.18) + 399 = 472 \text{ LB}$$

$$\gamma = \frac{472}{.0341} = 13829 \text{ PSL}$$


$$MS = \frac{84000}{13829} - 1 = +5.1 \quad \text{NUT PLATE}$$

$$\gamma = \frac{472}{.0208} = 22692 \text{ PSL}$$

$$MS = \frac{96000}{22692} - 1 = +3.2 \quad \text{SCREW}$$

∴ BOTH NUT PLATE & SCREW ARE OK FOR TND SHEAR


1331651 UPPER RIGHT PANEL - 1331356 UPPER BASEPLATE




1331401 LOWER FRONT PANEL TO
1356405 LOWER BASEPLATE VIA

5 MF1331-06 NUTPLATES
3 MS51830-103 INSERTS

JOINT W/ NUTPLATES



JOINT W/ INSERT



$$F_1 = 3 \times 69.83 = 209.49 \text{ LB/IN}$$

"3T"

W/ 8 SCREWS IN 10.563 IN

$$P = \frac{10.563}{8} (209.49) = 277 \text{ LB}$$

$$FS = 1.4 \text{ ON } P$$

$$FL = 399 \text{ LB (PRELOAD)}$$

$$L_{GRIP} = .032 + .075 + .045 + .025 = .227 \text{ IN} \quad \text{W/ NUTPLATE}$$

$$L_{GRIP} = .032 + .075 + .015 = .122 \text{ IN} \quad \text{W/ INSERT}$$

REQ'D NAS 1352 N06-6 SCREW. ($L = .375$ IN)

$$\text{SCREW } L = .032 + .075 + .045 + .171 = .323 \text{ IN W/ NUT PLATE}$$

$$\text{SCREW } L = .032 + .075 + .015 + .170 = .292 \text{ IN W/ INSERT}$$

$$\therefore -6 \text{ SCREW } L = .375 > \begin{matrix} .323 \text{ IN} \\ .292 \text{ IN} \end{matrix}$$

$$L_e = .171 - .025 - 1/n = .115 \text{ IN W/ NUT PLATE}$$

$$L_e = .125 - .010 - 1/n = .079 \text{ IN PANEL-INSERT}$$

$$= .170 - .015 - 1/n = .124 \text{ IN INSERT/SCREW}$$

$$A_{Sn} = .0341 \text{ IN}^2$$

$$A_{Ss} = .0208 \text{ IN}^2$$

W/ NUT PLATE

$$A_{Sn} = .0355 \text{ IN}^2$$

$$A_{Ss} = .0250 \text{ IN}^2$$

PANEL-INSERT

.216-28 UNF

$$A_{Sn} = .0344 \text{ IN}^2$$

$$A_{Ss} = .0287 \text{ IN}^2$$

INSERT-SCREW

1138-32 UNRC

W/ NUT PLATE

$$J_{2b} = 1.916 \times 10^6 \text{ LB IN}$$

$$J_{2m} = \frac{\pi (10 \times 10^6 \times .138)}{2 \ln \left[5 \frac{.227 + .138/2}{.227 + 2.5(.138)} \right]} = 2.280 \times 10^6 \frac{\text{LB}}{\text{IN}}$$

$$F_b = (1.4)(.457)(277) + 399 = 576 \text{ LB}$$

$$\gamma = \frac{576}{.0341} = 16894 \text{ PSI}$$

$$MS = \frac{84000}{16894} - 1 = +4.0 \text{ NUT PLATE}$$

$$\gamma = \frac{576}{.0208} = 27692 \text{ PSI}$$

$$MS = \frac{96000}{27692} - 1 = +2.5 \text{ SCREW}$$

∴ BOTH NUTPLATE & SCREW OK FOR TND SHEAR

W/INSERT

PANEL/INSERT OD

PANEL 6061-T6 $F_{su} = 27000 \text{ psi}$

$$J_b = \frac{(29 \times 10^6)(.0366)}{(.122)} = 8.700 \times 10^6 \text{ LB/IN}$$

$$J_m = \frac{\pi(10 \times 10^6)(.216)}{2 \ln \left[5 \frac{.122 + .216/2}{.122 + 2.5(.216)} \right]} = 6.144 \times 10^6 \text{ LB/IN}$$

$$F_b = (1.4)(.586)(277) + 399 = 626 \text{ LB}$$

$$\gamma = \frac{626}{.0355} = 17642 \text{ psi}$$

$$MS = \frac{27000}{17642} - 1 = +.53 \quad \text{LOWER FRONT PANEL}$$

$$\gamma = \frac{626}{.0250} = 25040 \text{ psi}$$

$$MS = \frac{48000}{25040} - 1 = +.92 \quad \text{INSERT OD TND}$$

∴ THREAD SHEAR OK IN PANEL/INSERT JOINT

INSERT ID/SCREW

$$J_b = \frac{(29 \times 10^6)(.0150)}{.122} = 3.566 \times 10^6 \text{ LB/IN}$$

$$J_m = \frac{\pi(10 \times 10^6)(.138)}{2 \ln \left[5 \frac{.122 + .138/2}{.122 + 2.5(.138)} \right]} = 3.030 \times 10^6 \text{ LB/IN}$$

$$F_b = (1.4)(1.541)(277) + 399 = 609 \text{ LB}$$

$$\tau = \frac{609}{.0344} = 17693 \text{ psi}$$


$$MS = \frac{48000}{17693} - 1 = +1.7 \quad \text{INSERT ID THDS}$$

$$\tau = \frac{609}{.0287} = 21220 \text{ psi}$$

$$MS = \frac{96000}{21220} - 1 = +3.5 \quad \text{SCREW}$$

∴ THREAD SHEAR OK IN INSERT/SCREW THDS

1331389 UPPER MOTOR MT PANEL TO
1331356 UPPER BASEPLATE VIA MSS1830-103L INSERTS



$$F_1 = 3 \times 25.271 = 75.813 \text{ LB/IN} \quad "3\text{\"}$$

W/G SCREWS IN 10.563 IN

$$P = \frac{10.563}{6} (75.813) = 133.5 \text{ LB}$$

$$FS = 1.4 \text{ ON } P$$

$$F_L = 399 \text{ LB PRELOD}$$

$$L_{GRIP} = .032 + .055 + .015 = .102 \text{ IN}$$

REQ'D. NAS1352NØ6 LENGTH .375 -6 OK

$$SCREW L > .032 + .055 + .015 + .170 = .272 \text{ IN}$$

$$L_e = .125 - .010 - \frac{1}{n} = .109 \text{ IN}$$

BP-INSERT
.216-28UNF
n=28

$$L_e = .170 - .015 - \frac{1}{n} = .124 \text{ IN}$$

INSERT-SCREW
.138-32UN2C
n=32

$$A_{Sn} = .0355 \text{ IN}^2$$

UPPER BP-INSERT

$$A_{Ss} = .0250 \text{ IN}^2$$

$$A_{Sn} = .0344 \text{ IN}^2$$

INSERT-SCREW

$$A_{Ss} = .0287 \text{ IN}^2$$

UPPER BASEPLATE 6061-T6 $F_{su} = 27000 \text{ psi}$

$$J_{2b} = \frac{(29 \times 10^6)(.0366)}{.102} = 10.406 \times 10^6 \text{ LB/IN}$$

$$J_{em} = \frac{\pi(10 \times 10^6)(.216)}{2 \ln \left[5 \frac{.102 + .216/2}{.102 + 2.5(.216)} \right]} = 6.897 \times 10^6 \text{ LB/IN}$$

$$F_b = (1.4)(1.601)(133.5) + 399 = 511 \text{ LB}$$

$$\gamma = \frac{511}{.0355} = 14406 \text{ psi}$$

$$MS = \frac{27000}{14406} - 1 = +.87 \quad \text{UPPER BP}$$

$$\gamma = \frac{511}{.0250} = 20456 \text{ psi}$$

$$MS = \frac{48000}{20456} - 1 = +1.3 \quad \text{INSERT ID THD}$$

\therefore THREAD SHEAR OK IN UPPER BP/INSERT JOINT

INSERT ID - SCREW

$$J_{2b} = \frac{(29 \times 10^6)(.0150)}{.102} = 4.265 \times 10^6 \text{ LB/IN}$$

$$J_{em} = \frac{\pi(10 \times 10^6)(.138)}{2 \ln \left[5 \frac{.102 + .138/2}{.102 + 2.5(.138)} \right]} = 3.342 \times 10^6 \text{ LB/IN}$$

$$F_b = (1.4)(.561)(133.5) + 399 = 504 \text{ LB}$$

$$\gamma = \frac{504}{.0344} = 14645 \text{ psi}$$

$$MS = \frac{48000}{14645} - 1 = +2.3$$

INSERT ID THDS


$$\gamma = \frac{504}{.0287} = 17561 \text{ psi}$$

$$MS = \frac{96000}{17561} - 1 = +4.5$$

SCREW

∴ THREAD SHEAR OK IN INSERT/SCREW THDS

1331389 UPPER MOTOR MT PANEL TO
1331390 UPPER RIGHT FRONT SUPPORT PANEL
VIA MF1331-06 NUTPLATE



$$F_1 = 3 \times 33.175 = 99.525 \text{ LB/IN}$$

"3T"

W/3 SCREWS IN 6.245 IN

$$P = \frac{6.245}{3} (99.525) = 207 \text{ LB}$$

$$FS = 1.4 \text{ ON } P$$

$$F_L = 399 \text{ LB (PRELOAD)}$$

$$\text{REQ'D NAS1352 } L = .032 + .050 + .055 + .171 = .308 \text{ IN}$$

$$\therefore -6 \text{ } L = .375 \text{ IS OK}$$

$$L_{GRIP} = .032 + .050 + .055 + .025 = .162 \text{ IN}$$

$$l_e = .171 - .025 - \frac{1}{n} = .115$$

$$A_{Sn} = .0341 \text{ in}^2$$

$$A_{Ss} = .0208 \text{ in}^2$$

$$k_b = \frac{(29 \times 10^6)(.0150)}{.162} = 2.685 \times 10^6 \text{ LB/in}$$

$$k_m = \frac{8(10 \times 10^6)(.138)}{2 \ln \left[5 \frac{.162 + .138/2}{.162 + 2.5(.138)} \right]} = 2.633 \times 10^6 \text{ LB/in}$$

$$F_b = (1.4)(.505)(207) + 399 = 545 \text{ LB}$$

$$\gamma = \frac{545}{.0341} = 15992 \text{ psi}$$


$$MS = \frac{84000}{15992} - 1 = +4.3 \quad \text{NUT PLATE}$$

$$\gamma = \frac{545}{.0208} = 26202 \text{ psi}$$

$$MS = \frac{96000}{26202} - 1 = +2.7 \quad \text{SCREW}$$

\therefore THREAD SHEAR OK IN JOINT

1331352 UPPER FRONT PANEL TO
1331356 UPPER BASEPLATE VIA MS51830-103L INSERTS



$$F_1 = 3 \times 24.409 = 73.227 \text{ LB/IN}$$

7 SCREWS IN 10.575 IN

$$P = \frac{10.575}{7} (73.227) = 111 \text{ LB}$$

$$F_S = 1.4 \text{ ON } P$$

$$F_L = 399 \text{ LB (PRELOAD)}$$

$$L_{GRIP} = .032 + .050 + .015 = .097 \text{ IN}$$

REQ'D NAS1352 NØ6 LENGTH .375 -6 OK

$$\text{SCREW } L > .032 + .050 + .015 + .170 = .267 \text{ IN}$$

$$L_e = .125 - .010 - \frac{1}{n} = .079 \text{ IN}$$

BP-INSERT
1216-28UNF
n=28

$$L_e = .170 - .015 - \frac{1}{n} = .124 \text{ IN}$$

INSERT-SCREW
1138-32UNEL
N=32

$$A_{S_n} = .0355 \text{ IN}^2$$

$$A_{S_s} = .0250 \text{ IN}^2$$

BP-INSERT

$$A_{S_n} = .0344 \text{ IN}^2$$

$$A_{S_s} = .0287 \text{ IN}^2$$

INSERT-SCREW

BP - INSERT OD TMD

$$J_{eb} = \frac{(29 \times 10^6)(.0366)}{.097} = 10.942 \times 10^6 \text{ LB/IN}$$

$$J_{em} = \frac{\pi(10 \times 10^6)(.216)}{2 \ln \left[5 \frac{.097 + .216/2}{.097 + 2.5(.216)} \right]} = 7.133 \times 10^6 \text{ LB/IN}$$

$$F_b = (1.4)(.605)(111) + 399 = 493 \text{ LB}$$

$$\gamma = \frac{493}{.0355} = 13889 \text{ PSL}$$

$$MS = \frac{27000}{13889} - 1 = +.94 \quad \text{UPPER BP}$$

$$\gamma = \frac{493}{.0250} = 19720 \text{ PSL}$$

$$MS = \frac{48000}{19720} - 1 = +1.4 \quad \text{INSERT OD TMD}$$

∴ THREAD SHEAR OK IN UPPER BP/INSERT JOINT

INSERT ID - SCREW

$$J_{eb} = \frac{(29 \times 10^6)(.0150)}{.097} = 4.485 \times 10^6 \text{ LB/IN}$$

$$J_{em} = \frac{\pi(10 \times 10^6)(.138)}{2 \ln \left[5 \frac{.097 + .138/2}{.097 + 2.5(.138)} \right]} = 3.440 \times 10^6 \text{ LB/IN}$$

$$F_b = (1.4)(.566)(111) + 399 = 487 \text{ LB}$$

$$\gamma = \frac{487}{.0344} = 14155 \text{ PSL}$$


$$MS = \frac{48000}{14155} - 1 = +2.4 \quad \text{INSERT ID THD}$$

$$\gamma = \frac{487}{.0287} = 16969 \text{ PSI}$$

$$MS = \frac{96000}{16969} - 1 = +4.7 \quad \text{SCREW}$$

\therefore THREAD SHEAR OK IN INSERT/SCREW THDS

1331390 UPPER RIGHT FRONT SUPPORT PANEL TO
1331356 UPPER BASE PLATE VIA MS51830-103L INSERTS



$$F_1 = 3 \times 28.80 = 86.40 \text{ LB/IN} \quad "3\text{\"}$$

W/ 3 SCREWS IN 6.500 IN

$$P = \frac{6.500}{3} (86.40) = 187.2 \text{ LB}$$

$$FS = 1.4 \text{ ON } P$$

$$F_L = 399 \text{ LB (PRELOD)}$$

$$L_{GRIP} = .032 + .075 + .015 = .122 \text{ IN}$$

REQ'D NAS1352N06 LENGTH .375 -6 OK

$$\text{SCREW } L > .032 + .075 + .015 + .170 = .292 \text{ IN}$$

$$L_e = .125 - .010 - \frac{1}{n} = .079 \text{ IN}$$

BP-INSERT
.216-28UNF
n=28

$$L_e = .170 - .015 - \frac{1}{n} = .124 \text{ IN}$$

INSERT-SCREW
.138-32UNRC
n=32

$$A_{Sn} = .0355 \text{ IN}^2$$

$$A_{Ss} = .0250 \text{ IN}^2$$

UPPER BP- INSERT

$$A_{Sn} = .0344 \text{ IN}^2$$

$$A_{Ss} = .0287 \text{ IN}^2$$

INSERT-SCREW

BP - INSERT OD TND

$$k_b = \frac{(29 \times 10^6)(.0366)}{.122} = 8.700 \times 10^6 \text{ LB/IN}$$

$$k_m = \frac{27(10 \times 10^6)(.216)}{2 \ln \left[5 \frac{.122 + .216/2}{.122 + 2.5(.216)} \right]} = 6.144 \times 10^6 \text{ LB/IN}$$

$$F_b = (1.4)(.586)(187.2) + 399 = 553 \text{ LB}$$

$$\gamma = \frac{553}{.0355} = 15566 \text{ PSI}$$

$$MS = \frac{27000}{15566} - 1 = +.73 \quad \text{UPPER BP}$$

$$\gamma = \frac{553}{.0250} = 22120 \text{ PSI}$$

$$MS = \frac{48000}{22120} - 1 = +1.2 \quad \text{INSERT OD}$$

∴ THREAD SHEAR OK IN UPPER BP/INSERT OD TND

INSERT ID - SCREW

$$k_b = \frac{(29 \times 10^6)(.0150)}{.122} = 3.566 \times 10^6 \text{ LB/IN}$$

$$k_m = \frac{27(10 \times 10^6)(.138)}{2 \ln \left[5 \frac{.122 + .138/2}{.122 + 2.5(.138)} \right]} = 3.030 \times 10^6 \text{ LB/IN}$$

$$F_b = (1.4)(.541)(187.2) + 399 = 541 \text{ LB}$$

$$\gamma = \frac{541}{.0344} = 15718 \text{ PSI}$$

$$MS = \frac{48000}{15718} - 1 = +2.1$$

INSERT TO THD

$$\gamma = \frac{541}{10287} = 18850 \text{ PSI}$$

$$MS = \frac{96000}{18850} - 1 = +4.1$$

SCREW

∴ THREAD SHEAR OK IN INSERT/SCREW JOINT

5.4.4 Large Masses Attachment Screw Stresses per Random Vibration Loads

The following pages contain a detailed analysis of large masses attachment screw stresses per random vibration loads.

TABLE 58 A1-EOS LARGE MASS ITEMS ATTACHMENT SCREW STRESS SUMMARY - RANDOM VIBRATION LOADS													
COMPONENT	PART NO.	SCREW	PRELOAD LB	POINT MASS LB	GRMS G	GRID PT 3s LOAD LB	O-TURN 3s LOAD LB	JOINT STIFFNESS	FS	TOTAL TENSION LB	ALLOW LOAD LB	MARGIN OF SAFETY	
DC/DC CONVERTER	1356010	NAS1352N08	792.7	0.91	17.98	49.1	36.3	0.384	1.4	838.6	2240	1.67	
DETECTOR PREAMP	1331610	NAS1352N06	507.2	0.7225	24.25	52.6	56.9	1	1.4	660.4	1458	1.21	
LOWER SHELF PLO ASSY 1	1331555 1348360	NAS1352N04	246	0.529	15.56	24.7	56.8	1	1.4	360.1	966	1.68	
PLO ASSY 2	1348360	NAS1352N04	246	0.532	16.26	26.0	59.7	1	1.4	365.9	966	1.64	
OSCILLATOR 1	1336610	NAS1352N04	246	0.393	19.31	22.8	38	1	1.4	331.1	966	1.92	
OSCILLATOR 2	1336610	NAS1352N04	246	0.39	14.52	17.0	28.3	1	1.4	309.4	966	2.12	
OSCILLATOR 2	1336610	NAS1352N04	246	0.34	21.73	22.2	37	1	1.4	328.8	966	1.94	
BRACKET	1331592	NAS1352N04	246	0.248	16.71	12.4	40.9	1	1.4	320.7	966	2.01	
BRACKET	1331562	NAS1352N04	246	0.292	21.15	18.5	68.3	1	1.4	367.6	966	1.63	
BRACKET	1331562	NAS1352N04	246	0.194	22.15	12.9	61.3	1	1.4	349.9	966	1.76	
UPPER SHELF BRACKET	1331490 1331165	MS24693-C27	362	0.403	16.27	19.7	28.7	1	1.4	429.7	725	0.69	
BRACKET	1331481	NAS1352N04	246	0.222	26.73	17.8	75.2	1	1.4	376.2	966	1.57	
BRACKET	1331482	NAS1352N04	246	0.237	19.09	13.6	98.3	1	1.4	402.6	966	1.40	
OSCILLATOR 1	1336610	NAS1352N04	246	0.3966	22.1	26.3	43.9	1	1.4	344.3	966	1.81	

DC/DC CONVERTER ATTACHMENT

1-2-96

Report 10381
Addendum 1

REF 1356010 DC/DC CONVERTER
1356008 EOYAMSH A1 TOP ASSEMBLY
NAS1352 SCREW
NAS1149 WASHER
MS21043 NUT

LOADING CONDITION RANDOM VIBRATION (0.97 GRMS)

METHOD 1 - TENSILE LOAD DEVELOPED IN SCREW DUE TO:

- 1) MASS @ NASTRAN MODEL GRIDPOINTS
X ACCELERATION DUE TO RANDOM VIB
(@ GRID POINT 1403)
- 2) PRELOAD (T=24-26 IN-LB, REF 1356008)
- 3) ADDITIONAL OVERTURNING MOMENT EFFECTS
ON DC/DC CONVERTOR

RANDOM VIBRATION RESULTS WITH Q=7.1

RESPONSE OF LARGE MASSES Q=7.1											
COMPONENT	GRID	LOAD DIRECTION	X-RESPONSE			Y-RESPONSE			Z-RESPONSE		
			RMS	GRMS	Q	RMS	GRMS	Q	RMS	GRMS	Q
LARGE MASS	65050	X	3897	10.09585	1.0	0	0	0.0	0	0	0.0
		Y	0	0	0.0	3897	10.09585	1.0	0	0	0.0
		Z	0	0	0.0	0	0	0.0	3897	10.0959	1.0
DC/DC CONVERTER	1403	X	6940	17.97927	1.8	1116	2.891192	0.3	3074	7.96373	0.8
		Y	948	2.455959	0.2	4254	11.02073	1.1	787	2.03886	0.2
		Z	1338	3.466321	0.3	2832	7.336788	0.7	5789	14.9456	1.5
	1400	X	3911	10.13212	1.0	863	2.235751	0.2	3000	7.77202	0.8
		Y	1239	3.209845	0.3	3998	10.35751	1.0	785	2.03368	0.2
		Z	3503	9.07513	0.9	1825	4.727979	0.5	5616	14.5482	1.4
	1364	X	3742	9.694301	1.0	843	2.183938	0.2	3065	7.94041	0.8
		Y	846	2.19171	0.2	4005	10.37565	1.0	1235	3.19948	0.3
		Z	3256	8.435233	0.8	1847	4.784974	0.5	5317	13.7746	1.4
	1367	X	6298	16.31606	1.6	1142	2.958549	0.3	3170	8.21244	0.8
		Y	819	2.121762	0.2	4263	11.04404	1.1	1318	3.41451	0.3
		Z	1310	3.393782	0.3	2858	7.404145	0.7	5474	14.1813	1.4

THE ABOVE TABLE IDENTIFIES THE 4 GRID POINTS (1403, 1400, 1364, 1367) OF THE NASTRAN MODEL USED TO APPLY PT MASSES (CONM2 43365-43368) REPRESENTING THE DC/DC CONVERTER. EACH PT MASS IS 0.91 LB.

LARGEST RESPONSE PER X-LOAD, X-RESPONSE IS A 17 GRMS LEVEL OF 17.98 G AT GRID 1403.

STATISTICAL ST LOAD AT GR 1403

$$F_L = 3 (17.98) (0.91) = 49.1 \text{ LB}$$

PRELOAD TORQUE, $T = .2 F_i d$

F_i = PRELOAD


d = NOMINAL SCREW ϕ NAS1352NØ8-10
.1640-32UNRC-3A

= .164

$T = 26 \text{ IN-LB MAX}$

$$F_i = \frac{26}{(.2)(.164)} = 792.7 \text{ LB}$$


JOINT SKETCH




OVERTURNING MOMENT

USING "3T" LOADS. LARGEST


RESPONSE (17.98 GRMS @ 1T) IS USED IRRESPECTIVE OF DIRECTION TO CONSERVATIVELY FIND THE OVERTURNING MOMENT.



ASSUMED CG @ CENTER OF ATTACHMENT
BOLT PATTERN. HEIGHT ASSUMED AT MID
HEIGHT OF ENCLOSURE



ASSUMED LOAD DIRECTION THROUGH SCREW #4



$$V = (4)(.91)(3)(17.98) \\ = 196.3 \text{ LB}$$

$$M_t = 1.15(V) \\ = 225.8 \text{ IN-LB}$$

$$\theta = 48.72^\circ$$



TENSILE DISTANCES ALONG SKEWED AXES

$$d_2 = 0$$

$$d_4 = 0$$

$$d_3 = 2.395 + .310 = 2.705$$

$$d_1 = 2.705$$

$$\sum d_i^2 = 2.705^2 + 2.705^2 + 0^2 + 0^2 = 14.634 \text{ IN}^2$$

TENSILE FORCE AT SCREW #2

$$F_{t_2} = \frac{W_b d_2}{\sum d_i^2} = \frac{196.3 \cdot 2.705}{14.634}$$

$$= 36.3 \text{ LB}$$

TOTAL TENSILE LOAD, F_b

$$F_L = 792.7 \text{ LB PRELOAD}$$

$$F_t = F_{t_1} + F_{t_2} = 49.1 + 36.3 = 85.4 \text{ LB}$$

PER SHIGLEY "MECHANICAL ENGINEERING DESIGN", 4TH EDITION, P371, THE TOTAL TENSILE LOAD DEVELOPED IN THE SCREW IS A FUNCTION OF JOINT STIFFNESS

$$F_b = F_L + \left(\frac{k_b F_t}{k_b + k_m} \right) FS$$

FS = 1.4 ON
APPLIED
LOAD ONLY

$$k_b = \frac{EA}{L}$$

$$E = 28 \times 10^6 \text{ PSI}$$

$$A = \pi/4 (.164)^2 = .02112 \text{ IN}^2$$

$$L = \text{GRIP LENGTH}$$

$$= 1.471 \times 10^6 \text{ LB/IN} = .032 + .245 + .125 = .402 \text{ IN}$$

$$k_m = \frac{\pi E d}{2 \ln \left[\frac{5(d+d/2)}{(d+2.5d)} \right]}$$

$$E = 10 \times 10^6 \text{ PSI}$$

$$d = .164 \text{ IN}$$

$$d = .402 \text{ IN}$$

Report 10381
Addendum 1

$$= 2.359 \times 10^6 \text{ LB/IN}$$

$$\frac{k_b}{k_b + k_m} = .384$$

$$F_b = 792.7 + .384(1.4)(85.4) = 839 \text{ LB}$$

PER NAS1352 FOR A -08 SCREW OF HEAT RESISTING STEEL, THE MINIMUM BREAKING STRENGTH IS

$$F_{tu} = 2240 \text{ LB}$$

$$MS = \frac{2240}{839} - 1 = + 1.7$$

∴ DC/DC CONVERTER ATTACHMENT
SCREWS ARE OK IN TENSION

METHOD 2 - INSURE LOAD DEVELOPED FROM RANDOM VIBRATION NASTRAN RUNS PLUS THE OVERTURNING MOMENT IS LESS THAN THE SCREW BREAKING STRENGTH. USE "3σ" RANDOM VIBRATION LOADS & A 1.4 FS.

APPLIED LOAD, F,

$$F = 1.4 (49.1 + 36.3) = 120 \text{ LB}$$

BREAKING STRENGTH, F_{tu} ,

$$F_{tu} = 2240 \text{ LB}$$

$$MS = \frac{2240}{120} - 1 = + 17 \quad \therefore \text{OK}$$

DETECTOR PREAMP ATTACHMENT

Report 10381
Addendum 1

REF 1331610 DETECTOR PREAMP ASSY
1356008 EOS/AMSH A-1 TOP ASSY
1331081 INSULATOR RF SHOULDER WASHER
1331614 PREAMP BASE
NAS1352 SCREW
NAS620 WASHER
MS51830 INSERT
1331401 PANEL, LOWER FRONT

LOADING CONDITION RANDOM VIBRATION (9.97 GRMS)

FIND TENSILE LOAD DEVELOPED IN SCREW DUE TO:

- 1) MASS @ NASTRAN MODEL GRID POINTS X ACCEL
DUE TO RANDOM VIBRATION (@ GRIDPT 999)
- 2) PRELOAD (T=12-14 IN-LB)
- 3) ADDITIONAL OVERTURNING MOMENT EFFECTS ON
DETECTOR PREAMP

RANDOM VIBRATION RESULTS WITH Q=7.1

COMPONENT	GRID	LOAD DIRECTION	X-RESPONSE			Y-RESPONSE			Z-RESPONSE		
			RMS	GRMS	Q	RMS	GRMS	Q	RMS	GRMS	Q
	999	X	9362	24.25389	2.4	618	1.601036	0.2	709	1.83679	0.2
		Y	3219	8.339378	0.8	3327	8.619171	0.9	580	1.50259	0.1
		Z	1045	2.707254	0.3	690	1.787565	0.2	3727	9.65544	1.0
DETECTOR PREAMP	1078	X	3708	9.606218	1.0	725	1.878238	0.2	1420	3.67876	0.4
		Y	550	1.42487	0.1	3402	8.813472	0.9	1390	3.60104	0.4
		Z	804	2.082902	0.2	892	2.310881	0.2	4537	11.7539	1.2
	1080	X	3900	10.10363	1.0	1238	3.207254	0.3	1600	4.14508	0.4
		Y	1808	4.683938	0.5	3428	8.880829	0.9	1571	4.06995	0.4
		Z	2434	6.305699	0.6	1387	3.593264	0.4	4776	12.3731	1.2
	1001	X	6150	15.93264	1.6	1387	3.593264	0.4	789	2.04404	0.2
		Y	1190	3.082902	0.3	3556	9.212435	0.9	657	1.70207	0.2
		Z	813	2.106218	0.2	1476	3.823834	0.4	3764	9.7513	1.0

THE 4 GRID PTS (999, 1078, 1080, 1001) OF THE NASTRAN
MODEL USED TO APPLY PT MASSES (CONM2 43373 -
43376) REPRESENT THE DETECTOR PREAMP
EACH PT MASS IS .7225 LB. LARGEST RESPONSE PER
X-LOAD, X-RESPONSE AT GR 999 FOR "1T" LOAD
IS 24.25 G.

STATISTICAL 3T LOAD AT GR 999

$$F_{t1} = 3(24.25)(0.7225) = 52.6 \text{ LB}$$

PRELOAD TORQUE, $T = .2 F_i d$

$F_i = \text{PRELOAD}$


$d = .138 \text{ IN}$

$T = 14 \text{ IN-LB}$

NOM SCREW ϕ NAS1352N06-6
MAX .138-32UNRC-3A


$$F_L = \frac{14}{(.2)(.138)} = 507.2 \text{ LB}$$

SKETCH OF JOINT




OVERTURNING MOMENT


USING "3T" LOADS FROM RANDOM VIBRATION, THE LARGEST RESPONSE (24.25 GRMS @ 1T) IS APPLIED WITHOUT REGARD TO DIRECTION, AS A FORCE THROUGH THE ASSUMED PREAMP DETECTOR CG TO DEVELOP THE LARGEST POSSIBLE OVERTURNING MOMENT BOLT TENSILE LOAD.



ASSUMED CG @ CENTER OF ATTACHMENT BOLT PATTERN. HEIGHT OF CG ASSUMED AT 1.5 INCHES



ASSUMED LOAD DIRECTION IS \Rightarrow \perp TO SCREW #4



$$V = 4(.7225)(3)/(24.25) = 218.9 \text{ LB}$$

$$M_t = (1.5)(V) = 328.4 \text{ IN-LB}$$

TENSILE LOAD DISTANCES ALONG SKEWED AXIS

$$d_2 = d_4 = 0$$

$$d_1 = d_3 = 3.050 \cos(19.02) = 2.884 \text{ in}$$

$$\sum d_i^2 = 16.629 \text{ in}^2$$

TENSILE FORCE AT SCREW # 2

$$F_{t2} = \frac{W_t d_2}{\sum d_i^2} = \frac{(328.4)(2.884)}{16.629} = 56.9 \text{ LB}$$

TOTAL TENSILE LOAD, F_b

$$F_L = 507.2 \text{ LB} \quad \text{PRELOAD}$$

$$F_b = F_{t1} + F_{t2} = 52.6 + 56.9 = 109.5 \text{ LB}$$

WITH $FS = 1.4$ APPLIED TO F_t ONLY

$$F_b = F_L + (FS) \frac{k_b}{k_b + k_m} F_t$$

$$k_b = \frac{EA}{l}$$

$$= 2.702 \times 10^6 \text{ LB/in}$$

$$E = 28 \times 10^6 \text{ PSI}$$

$$A = \pi/4 (1.138)^2 = .01496 \text{ in}^2$$

$$l = \text{GRIP LENGTH}$$

$$= .032 + .063 + .045 + .015$$

$$= .155$$

WITH A LOW E FIBERGLAS ISOLATORS WASHER
IN THE MEMBER STACK-UP, CONSERVATIVELY
ASSUME

$$k_m \rightarrow 0$$

THEN

$$\frac{k_b}{k_b + k_m} = 1.0$$

$$F_t = F_L + (FS) F_t = 507.2 + (1.4)(109.5) = 661 \text{ LB}$$

PER NAS1352 FOR -06 SCREW OF HEAT RESISTANT STEEL, MINIMUM BREAKING STRENGTH IS

$$F_{tu} = 1458 \text{ LB}$$

$$MS = \frac{1458}{661} - 1 = +1.2$$

∴ DETECTOR PREAMP ATTACHMENT SCREWS ARE OK IN TENSION

METHOD 2 INSURE LOAD DEVELOPED FROM RANDOM VIBRATION NASTRAN RUNS PLUS THE OVERTURNING MOMENT & SCREW BREAKING STRENGTH. USE "3T" LOADS & A 1.4 FS

APPLIED LOAD, F

$$F = 1.4(52.6 + 56.9) = 153.3 \text{ LB}$$

BREAKING STRENGTH, F_{tu} ,

$$F_{tu} = 1458 \text{ LB}$$

$$MS = \frac{1458}{153.3} - 1 = +8.5 \quad \therefore \text{OK}$$

1-8-96

LOWER SHELF (A1-1) LARGE MASS ATTACHMENTS

REF	1331556	LOWER RF SHELF
	1331555	LOWER RF SHELF ASSY
	1356429	RECEIVER ASSY, A1-1
	1348360	PLO ASSY
	NAS1352	SCREW
	NAS620	WASHER
	1331081	INSULATOR RF SHOULDER WASHER
	1336610	OSCILLATOR
	1331592	BRACKET
	1331562	MIXER

LOADING CONDITION RANDOM VIBRATION (9.97 GRMS)


METHOD 1 - TENSILE LOAD DEVELOPED IN SCREW DUE TO:


- 1) MASS @ NASTRAN MODEL GRIDPOINTS Z-ACCEL
DUE TO RANDOM VIBRATION
- 2) PRELOAD (REF 1356429)
- 3) ADDITIONAL OVERTURNING MOMENT EFFECTS

1348360 PLO'S ATTACHMENT

2 PLO UNITS ARE ATTACHED TO THE 1331555 LOWER RF SHELF ASSY. FOR THE PLO IN THE +X-Y CORNER OF THE MODEL, 4 GRID POINTS (735, 738, 801, 804) OF THE NASTRAN MODEL ARE USED TO APPLY PT MASSES (LOUM2 1056-1059) TO REPRESENT THE PLO. EACH PT MASS IS 0.529 LB.

LARGEST RESPONSE PER Z-LOAD, Z-RESPONSE IS A 19 GRMS LEVEL OF 15.56 GRMS. AT GR 738





RANDOM VIBRATION RESULTS WITH $Q=7.1$

COMPONENT	GRID	LOAD DIRECTION	RESPONSE OF LARGE MASSES $Q=7.1$								
			X-RESPONSE			Y-RESPONSE			Z-RESPONSE		
			RMS	GRMS	Q	RMS	GRMS	Q	RMS	GRMS	Q
PLO +X-Y	735	X	4591	11.89378	1.2	915	2.370466	0.2	1540	3.98964	0.4
		Y	1688	4.373057	0.4	3839	9.945596	1.0	1385	3.58808	0.4
		Z	833	2.158031	0.2	755	1.955959	0.2	3733	9.67098	1.0
	738	X	4588	11.88601	1.2	1119	2.898964	0.3	3810	9.87047	1.0
		Y	1648	4.26943	0.4	4164	10.78756	1.1	2573	6.6658	0.7
		Z	847	2.194301	0.2	837	2.168394	0.2	6007	15.5622	1.5
	801	X	4448	11.52332	1.1	931	2.411917	0.2	1651	4.2772	0.4
		Y	1344	3.481865	0.3	3866	10.01554	1.0	676	1.7513	0.2
		Z	1188	3.07772	0.3	756	1.958549	0.2	3621	9.38083	0.9
	804	X	4428	11.4715	1.1	1117	2.893782	0.3	2687	6.96114	0.7
		Y	1352	3.502591	0.3	4160	10.7772	1.1	2170	5.62176	0.6
		Z	1170	3.031088	0.3	835	2.163212	0.2	5112	13.2435	1.3

STATISTICAL 3 σ LOAD AT 62738

$$F_{t1} = 3(15.56)(0.529) = 24.7 \text{ LB}$$

PRELOAD TORQUE $T = .2 F_i d$

$$F_i = \text{PRELOAD}$$

$$d = \text{NOMINAL SCREW } \phi = .112$$


ATTACHMENT SCREWS ARE (4) NAS1352NØ4LL6

.112-40UNRC-3A #4 SCREWS

$$T = 4.5 \text{ TO } 5.5 \text{ IN-LB (1356429 SH1)}$$

$$F_i = \frac{5.5}{12(.112)} = 246 \text{ LB}$$


SKETCH OF JOINT




OVERTURNING MOMENT

USING "3T" LOADS FROM RANDOM VIBRATION WITH A $Q=7.1$, THE LARGEST RESPONSE (15.56 GRMS @ 17 AT 62738) IS APPLIED WITHOUT REGARD TO DIRECTION, AS A FORCE THROUGH THE ASSUMED PLO ASSY CG TO DEVELOP THE LARGEST POSSIBLE OVERTURNING MOMENT BOLT TENSILE LOAD.

ASSUMED IN-PLANE CG IS @ CENTER OF ATTACHMENT BOLT PATTERN, HEIGHT OF CG ASSUMED AT 2.0 INCHES.






$$d_2 = d_4 = 0$$

$$\sum d_i^2 = 6.036$$

$$d_1/\epsilon d_2^2 = \underline{.288}$$

ASSUMED LOAD DIRECTION IS || TO SCREW #3-#1



$$d_2 = d_4 = .3347$$

$$\sum d_i^2 = 8.618$$

$$d_1 / \varepsilon d_i^2 = .238$$

∴ LESS SEVERE
CASE

$$V = 4(.529)(3)(15.56) = 98.8 \text{ LB}$$

$$M_t = (2.0) V = 197.5 \text{ IN-LB}$$

TENSILE FORCE AT SCREW #1

$$F_{t2} = \frac{M_t d_1}{\sum d_i^2} = \frac{(197.5)(1.737)}{6.036} = 56.8 \text{ LB}$$

TOTAL TENSILE LOAD, F_b

$$F_b = F_L + F_S \frac{k_b}{k_b + k_m} F_t$$

$$F_t = F_{t1} + F_{t2} = 24.7 + 56.8 = 81.5 \text{ LB}$$

WITH $F_S = 1.4$ APPLIED TO F_t ONLY

$$F_b = F_L + (F_S) \frac{k_b}{k_b + k_m} (F_t)$$

WORST CASE SCENARIO IS

$$k_b \gg k_m$$

THEN

$$F_b = F_L + (F_S)(F_t)$$

$$= 246 + 1.4(81.5) = 360 \text{ LB}$$

PER NAS1352 FOR UNF SCREW OF HEAT
RESISTANT STEEL, MIN BREAKING STRENGTH

$$F_{tu} = 966 \text{ LB}$$

$$MS = \frac{966}{360} - 1 = +1.7$$

∴ PLO MOUNTING SCREWS ARE OK IN
TENSION FOR +X-Y PLO.

FOR THE PLO IN THE +X+Y CORNER OF THE NASTRAN MODEL, 4 GRID POINTS (884, 886, 952, 954) ARE USED TO APPLY PT MASSES (CONM2 1052-1055) TO REPRESENT THE PLO, WITH EACH PT MASS AT 0.532 LB

LARGEST RESPONSE PER 3-LOAD, Z-RESPONSE IS A 17 GRMS LEVEL OF 16.26 GRMS AT GR 886.

RANDOM VIBRATION RESULTS WITH Q=7.1

RESPONSE OF LARGE MASSES Q=7.1											
COMPONENT	GRID	LOAD DIRECTION	X-RESPONSE			Y-RESPONSE			Z-RESPONSE		
			RMS	GRMS	Q	RMS	GRMS	Q	RMS	GRMS	Q
LOWER SHELF PLO +X+Y	884	X	4185	10.84197	1.1	1003	2.598446	0.3	2102	5.4456	0.5
		Y	1189	3.080311	0.3	3972	10.29016	1.0	1352	3.50259	0.3
		Z	1614	4.181347	0.4	765	1.981865	0.2	4286	11.1036	1.1
	886	X	4184	10.83938	1.1	1192	3.088083	0.3	2916	7.5544	0.7
		Y	1188	3.07772	0.3	4262	11.04145	1.1	1988	5.15026	0.5
		Z	1613	4.178756	0.4	897	2.323834	0.2	6276	16.2591	1.6
	952	X	3959	10.25648	1.0	1004	2.601036	0.3	1365	3.53627	0.4
		Y	1210	3.134715	0.3	3963	10.26684	1.0	873	2.26166	0.2
		Z	1946	5.041451	0.5	764	1.979275	0.2	4021	10.4171	1.0
	954	X	3958	10.25389	1.0	1192	3.088083	0.3	1146	2.96891	0.3
		Y	1203	3.11658	0.3	4263	11.04404	1.1	859	2.22539	0.2
		Z	1934	5.010363	0.5	895	2.318653	0.2	3829	9.91969	1.0

STATISTICAL 3T LOAD AT GR 886

$$F_{t1} = 3(16.26)(.532) = 25.9 \text{ LB}$$

PRELOAD

$$F_L = 240 \text{ LB}$$

SKETCH OF JOINT

SEE OTHER PLO ON LOWER SHELF.

OVERTURNING MOMENT

SEE OTHER PLO ON LOWER SHELF

$$V = 4(.532)(3)(16.26) = 103.8 \text{ LB}$$

$$M_{t1} = (2.0)V = 207.6 \text{ IN-LB}$$

TENSIVE FORCE AT SCREW # 1

$$F_{t2} = \frac{M_{t1} d_1}{\sum d_i^2} = \frac{(207.6)(1.737)}{6.036} = 59.7 \text{ LB}$$

TOTAL TENSILE LOAD, F_b

$$F_b = F_L + FS \frac{J_{rb}}{J_{rb} + J_{rm}} F_t$$

$$F_t = F_{t1} + F_{t2} = 25.9 + 59.7 = 85.6 \text{ LB}$$

WORST CASE SCENARIO

$$J_{rb} \gg J_{rm}$$

THEN

$$F_b = F_L + (FS)(F_t)$$

$$= 246 + 1.4(85.6) = 366 \text{ LB}$$

PER NAS1352

$$F_{tu} = 966 \text{ LB}$$

$$MS = \frac{966}{366} - 1 = +1.6$$

∴ PLO MOUNTING SCREWS ARE OK IN TENSION FOR +X+Y PLO.

1336610 OSCILLATORS ATTACHMENT

3 OSCILLATORS ARE ATTACHED TO THE 1331555 LOWER RF SHELF ASSY. FOR THE OSCILLATOR MOUNTED ON THE BOTTOM OF THE SHELF, 4 GRID PTS (888, 910, 937, 940) OF THE NASTRAN MODEL ARE USED TO APPLY PT MASSES (CONM2 1040-1043) TO REPRESENT THE UNDERSIDE OSCILLATOR. EACH PT MASS IS 0.393 LB.

LARGEST RESPONSE PER Z-LOAD, Z-RESPONSE IS A 1T GRMS LEVEL OF 19.31 GRMS AT GR 910.

RANDOM VIBRATION RESULTS WITH Q=7.1

COMPONENT	GRID	LOAD DIRECTION	RESPONSE OF LARGE MASSES Q=7.1								
			X-RESPONSE			Y-RESPONSE			Z-RESPONSE		
			RMS	GRMS	Q	RMS	GRMS	Q	RMS	GRMS	Q
ORO (BOTTOM MT)	960	X	4002	10.36788	1.0	1568	4.062176	0.4	1963	5.08549	0.5
		Y	1196	3.098446	0.3	4725	12.24093	1.2	2514	6.51295	0.6
		Z	1820	4.715026	0.5	1384	3.585492	0.4	5833	15.1114	1.5
	888	X	4149	10.7487	1.1	1322	3.42487	0.3	2398	6.21244	0.6
		Y	1184	3.067358	0.3	4434	11.48705	1.1	2862	7.41451	0.7
		Z	1652	4.279793	0.4	1035	2.681347	0.3	6407	16.5984	1.6
	910	X	4137	10.71762	1.1	1566	4.056995	0.4	1792	4.64249	0.5
		Y	1191	3.085492	0.3	4714	12.21244	1.2	2863	7.4171	0.7
		Z	1630	4.222798	0.4	1364	3.533679	0.4	7454	19.3109	1.9
	937	X	4044	10.47668	1.0	1325	3.432642	0.3	1960	5.07772	0.5
		Y	1210	3.134715	0.3	4437	11.49482	1.1	2598	6.73057	0.7
		Z	1899	4.919689	0.5	1032	2.673575	0.3	5252	13.6062	1.3

STATISTICAL 3T LOAD AT GR 910

$$F_{E1} = 3(19.31)(0.393) = 22.8 \text{ LB}$$

PRELOAD TORQUE

ATTACHMENT SCREWS ARE, NAS1352NØ4LL6 (SAME AS USED WITH PLO'S) #4 SCREWS

$$F_L = \frac{5.5}{(2)(6.112)} = 246 \text{ LB}$$

SKETCH OF JOINT


SEE PLO JOINT SKETCH, SUBSTITUTE 1336610 FOR 1348360.

1-8-95

OVERTURNING MOMENT


USING "35" LOADS FROM RANDOM VIBRATION $Q=7.1$ WITH LARGEST RESPONSE (19.31 GRMS @ 17 AT GR 910) APPLIED WITHOUT REGARD TO DIRECTION, AS A FORCE THROUGH THE ASSUMED DRO ASSY CG, DEVELOPING THE LARGEST POSSIBLE OVERTURNING MOMENT BOLT TENSIVE LOAD

ASSUMED IN-PLANE CG @ CENTER OF ATTACHMENT BOLT PATTERN. HEIGHT OF CG ASSUMED AT 1.5 INCHES.



LOAD ASSUMED \perp TO
SCREW #4-#2

Report 10381
Addendum 1



$$\theta = \tan^{-1} \frac{1.0625}{1.6875}$$

$$= 32.20^\circ$$

$$d_1 = 3.1672 - 1.3688$$

$$= 1.7983$$


$$d_3 = d_1$$

$$d_2 = d_4 = 0$$

$$\sum d_i^2 = 6.468$$

$$d_1 / \sum d_i^2 = \underline{\underline{.2780}}$$

LOAD ASSUMED \parallel
TO SCREW #3-#1



$$\theta = 32.20^\circ$$

$$d_1 = d_3 = 1.9941$$

$$d_2 = d_4 = .8620$$

$$\sum d_i^2 = 9.439$$

$$d_1 / \sum d_i^2 = .2113$$

\therefore LESS
SEVERE
THAN
ABOVE
CASE

$$V = 4(.393)(3)(19.31) = 91.1 \text{ LB}$$

$$M_t = 1.5 V = 136.6 \text{ IN-LB}$$

TENSILE FORCES @ SCREW #3

$$F_{t2} = \frac{M_t d_3}{\sum d_i^2} = \frac{(136.6)(1.7983)}{(6.468)} = 38.0 \text{ LB}$$

TOTAL TENSILE LOAD, F_t

$$F_b = F_L + F_S \frac{l_{eb}}{l_{eb} + l_{em}} F_t$$

$$F_t = F_{t1} + F_{t2} = 22.8 + 38.0 = 60.8 \text{ LB}$$

ASSUME WORST CASE SCENARIO

$$l_{eb} \gg l_{em}$$

$$l_{eb} / (l_{eb} + l_{em}) = 1.0$$

USE $F_S = 1.4$, THEN

$$F_b = 246 + (1.4)(1.0)(60.8) = 331 \text{ LB}$$

PER NAS1352 N04LL6 SCREW, #4, HEAT RESISTANT STEEL, MIN BREAKING STRENGTH

$$F_{tu} = 966 \text{ LB}$$

$$MS = \frac{966}{331} - 1 = +1.9$$

° UNDERSIDE MOUNTED DRO MOUNTING SCREWS OK IN TENSION.

DRO MOUNTED AT THE -X, -Y CORNER OF THE 1331553 LOWER SHELF ASSY ATTACHED AT GRIDS 915, 918, 965, 968 IN THE NASTRAN MODEL VIA PT MASSES (CONM2 1048-1051). EACH PT MASS IS .390 LB

LARGEST RESPONSE PER Z-LOAD, Z-RESPONSE IS A 1G GRMS LEVEL OF 14.52 GRMS AT GRID 915.

RANDOM VIBRATION RESULTS w/ Q=7.1

Report 10381
Addendum 1

RESPONSE OF LARGE MASSES Q=7.1											
COMPONENT	GRID	LOAD DIRECTION	X-RESPONSE			Y-RESPONSE			Z-RESPONSE		
			RMS	GRMS	Q	RMS	GRMS	Q	RMS	GRMS	Q
	968	X	3976	10.30052	1.0	1744	4.518135	0.4	1235	3.19948	0.3
		Y	1332	3.450777	0.3	4130	10.69948	1.1	934	2.41969	0.2
		Z	1618	4.19171	0.4	1855	4.805699	0.5	3877	10.044	1.0
	915	X	4062	10.52332	1.0	1859	4.816062	0.5	3018	7.81865	0.8
		Y	1145	2.966321	0.3	4762	12.33679	1.2	1966	5.09326	0.5
		Z	1586	4.108808	0.4	1766	4.57513	0.5	5603	14.5155	1.4
	918	X	4014	10.39896	1.0	1755	4.546632	0.5	1436	3.72021	0.4
		Y	1107	2.867876	0.3	4136	10.71503	1.1	940	2.43523	0.2
		Z	1618	4.19171	0.4	1858	4.813472	0.5	3975	10.2979	1.0
	965	X	3973	10.29275	1.0	1871	4.84715	0.5	2610	6.76166	0.7
		Y	1250	3.238342	0.3	4770	12.35751	1.2	2106	5.45596	0.5
		Z	1680	4.352332	0.4	1761	4.562176	0.5	5280	13.6788	1.4

STATISTICAL 3D LOAD @ GR 915

$$F_{t1} = 3(14.52)(.390) = 17.0 \text{ LB}$$

PRELOAD

$$F_L = 246 \text{ LB}$$

SKETCH OF JOINT

SEE PLO JOINT SKETCH, SUBSTITUTE 1336610
DRO FOR 1348360 PLO

OVERTURNING MOMENT

SEE OTHER DRO ABOVE FOR GEOMETRY

$$V = (4)(.390)(3)(14.52) = 68.0 \text{ LB}$$

$$M_t = (1.5)V = 101.9 \text{ IN-LB}$$

TENSILE FORCE AT SCREW #3

$$F_{t2} = \frac{M_t d_3}{\sum d_i^2} = \frac{(101.9)(1.7983)}{(4.468)} = 28.3 \text{ LB}$$

TOTAL TENSILE LOAD, F_{t1}

$$w/ J_{eb} \gg J_{em} \quad J_{eb}/J_{eb} + J_{em} = 1.0$$

$$F_t = F_{t1} + F_{t2} = 17.0 + 28.3 = 45.3 \text{ LB}$$

FS = 1.4 ON F_t ONLY,

$$F_D = 246 + (1.4)(1.0)(45.3) = 310 \text{ LB}$$

ALLOWABLE, NAS135ZNØ4LL6

$$F_{t4} = 966 \text{ LB}$$

$$MS = \frac{966}{310} - 1 = + 2.1$$

∴ OSCILLATOR @ SHELF -X,-Y CORNER
MOUNTING SCREWS OK IN TENSION

THE GDO MOUNTED TOWARDS THE CENTER OF THE SHELF (ON THE TOP) ATTACHES AT GRIDS 774, 777, 822, AND 825 WITH PT MASSES 1044-1047 (CONM2). EACH PT MASS IS .34 LB.

LARGEST RESPONSE PER Z-LOAD, Z-RESPONSE IS A 1T GRMS LOAD OF 21.73 GRMS AT GRID 825.

RANDOM VIBRATION RESULTS W/Q=7.1

RESPONSE OF LARGE MASSES Q=7.1												
COMPONENT	GRID	LOAD DIRECTION	X-RESPONSE			Y-RESPONSE			Z-RESPONSE			Q
			RMS	GRMS		RMS	GRMS		RMS	GRMS		
LOWER SHELF	825	X	4354	11.27979	1.1	1396	3.61658	0.4	2179	5.84508	0.6	
		Y	1286	3.331608	0.3	4525	11.7228	1.2	1832	4.74811	0.5	
		Z	1262	3.26943	0.3	1133	2.935233	0.3	8389	21.7332	2.2	
	774	X	4480	11.60622	1.1	1142	2.958549	0.3	2876	7.45078	0.7	
		Y	1436	3.720207	0.4	4197	10.87306	1.1	1854	4.80311	0.5	
		Z	1044	2.704663	0.3	856	2.217617	0.2	5162	13.3731	1.3	
	777	X	4443	11.51036	1.1	1400	3.626943	0.4	2355	6.10104	0.6	
		Y	1393	3.608808	0.4	4532	11.74093	1.2	1716	4.4456	0.4	
		Z	1044	2.704663	0.3	1134	2.937824	0.3	7141	18.5	1.8	
	822	X	4374	11.33161	1.1	1140	2.953368	0.3	2576	6.67358	0.7	
		Y	1296	3.357513	0.3	4190	10.85492	1.1	2265	5.86788	0.6	
		Z	1269	3.287565	0.3	853	2.209845	0.2	5771	14.9508	1.5	

STATISTICAL 3T LOAD @ GRID 825

$$F_{t1} = (3)(21.73)(.34) = 22.2 \text{ LB}$$

PRELOAD

$$F_L = 246 \text{ LB}$$

JOINT SKETCH

SEE PLO JOINT SKETCH, REPLACE 1348360 PLO WITH 1336610 GDO.

OVERTURNING MOMENT

SEE SKETCHES AT 1ST DRO EVALUATED FOR GEOMETRY

$$V = (4)(.34)(3)(21.73) = 88.7 \text{ LB}$$

$$M_t = (1.5)V = 133.0 \text{ IN-LB}$$

TENSIVE FORCE @ SCREW #3

$$F_{t2} = \frac{M_t d_3}{\sum d_i^2} = \frac{(133.0)(1.7983)}{(6.468)} = 37.0 \text{ LB}$$

TOTAL TENSIVE LOAD, F_b

$$w/ \text{ } l_{2b} \gg l_{em} \quad \therefore l_{2b} / (l_{2b} + l_{em}) = 1.0$$

$$F_t = F_{t1} + F_{t2} = 22.2 + 37.0 = 59.2 \text{ LB}$$

$$F_S = 1.4$$

$$F_b = F_L + F_S \frac{l_{2b}}{l_{2b} + l_{em}} F_t$$

$$= 246 + (1.4)(1.0)(59.2)$$

$$= 329 \text{ LB}$$

PER MS1352 N04LL6 SCREW, $F_{tu} = 966 \text{ LB}$

$$MS = \frac{966}{329} - 1 = +1.9$$

∴ GDO MOUNTING SCREWS OK IN TENSION.

1331592 BRACKET W/ 1331579 IF AMPLIFIERS,
1331576 SAW FILTERS, AND 1356886 ATTENUATOR

THE 1331592 BRACKET W/ 1331579 IF AMPS, 1331576 SAW FILTERS, AND 1356886 ATTENUATOR IS MOUNTED VIA 8 ATTACHMENT SCREWS TO THE 1331555 LOWER SHELF. GRID PTS 744, 747, 751, 762, 769, 781, 787, AND 788 ARE USED IN THE VASTRAV MODEL TO APPLY PT MASSES (CONMZ 1075-1082) TO REPRESENT THIS ASSY. EACH PT MASS IS .248 LB.

LARGEST RESPONSE PER Z-LOAD, Z-RESPONSE IS A 17 GRMS LOAD OF 16.71 GRMS AT GRID 788.

RANDOM VIBRATION RESULTS WITH Q=7.1

COMPONENT	GRID	LOAD DIRECTION	RESPONSE OF LARGE MASSES Q=7.1								
			X-RESPONSE			Y-RESPONSE			Z-RESPONSE		
			RMS	GRMS	Q	RMS	GRMS	Q	RMS	GRMS	Q
	788	X	4366	11.31088	1.1	1674	4.336788	0.4	2545	6.59326	0.7
		Y	1296	3.357513	0.3	4526	11.72539	1.2	2425	6.28238	0.6
		Z	1013	2.624352	0.3	1959	5.07513	0.5	6449	16.7073	1.7
	744	X	4423	11.45855	1.1	1594	4.129534	0.4	1311	3.39637	0.3
		Y	1397	3.619171	0.4	4741	12.28238	1.2	1536	3.97927	0.4
		Z	848	2.196891	0.2	1428	3.699482	0.4	3981	10.3135	1.0
	747	X	4390	11.37306	1.1	1720	4.455959	0.4	3594	9.31088	0.9
		Y	1305	3.380829	0.3	4834	12.52332	1.2	3049	7.89896	0.8
		Z	869	2.251295	0.2	1665	4.313472	0.4	5418	14.0363	1.4
	751	X	4248	11.00518	1.1	1667	4.318653	0.4	1680	4.35233	0.4
		Y	1122	2.906736	0.3	4517	11.70207	1.2	1652	4.27979	0.4
		Z	899	2.329016	0.2	1956	5.067358	0.5	5172	13.399	1.3
	762	X	4428	11.4715	1.1	1600	4.145078	0.4	1691	4.38083	0.4
		Y	1383	3.582902	0.4	4747	12.29793	1.2	2031	5.26166	0.5
		Z	926	2.398964	0.2	1427	3.696891	0.4	4715	12.215	1.2
	769	X	4318	11.18653	1.1	1666	4.316062	0.4	2229	5.77461	0.6
		Y	1205	3.121762	0.3	4514	11.6943	1.2	2104	5.45078	0.5
		Z	961	2.489637	0.2	1954	5.062176	0.5	6252	16.1969	1.6
	781	X	4420	11.45078	1.1	1601	4.147668	0.4	1807	4.68135	0.5
		Y	1363	3.531088	0.3	4747	12.29793	1.2	2383	6.17358	0.6
		Z	1005	2.603627	0.3	1426	3.694301	0.4	5480	14.1969	1.4
	787	X	4371	11.32383	1.1	1745	4.520725	0.4	2849	7.38083	0.7
		Y	1313	3.401554	0.3	4739	12.2772	1.2	2886	7.47668	0.7
		Z	1006	2.606218	0.3	1884	4.880829	0.5	5421	14.044	1.4

STATISTICAL 3σ LOAD @ GR 788


$$F_{L1} = 3(16.71)(.248) = 12.4 \text{ LB}$$

PRELOAD TORQUE

ATTACHMENT SCREWS ARE NAS1352 NØ477 (#4)
WITH T=5.5 IN-LB MAX

$$F_L = \frac{5.5}{(.2)(.112)} = 246 \text{ LB}$$

SKETCH OF JOINT (REF 1356429 VIEW F)



VIEW F



4	2
	E

HARDWARE USAGE, 8 PL (REF)
SCALE: 2/1

OVERTURNING MOMENT


USING "3T" LOADS FROM RANDOM VIBRATION, $Q=7.1$, WITH LARGEST RESPONSE (16.71 GRMS @ 1T @ GRID 788) APPLIED WITHOUT REGARD TO DIRECTION OR LOCATION. LOAD IS APPLIED AS A FORCE THROUGH THE BOLT PATTERN CG TO DEVELOP THE LARGEST POSSIBLE OVERTURNING MOMENT BOLT TENSILE LOAD.


ASSUMED IN-PLANE CG IS @ ATTACHMENT BOLT PATTERN CENTER. HEIGHT OF CG ASSUMED AT 2.0 INCHES



IF SCREW 1 X = 16.076 Y = 11.296 Z = 6.781

CG 2 X = 20.432 Y = 10.483 Z = 7.781





$$\theta = \tan^{-1} \frac{.812}{3.9375} = 11.65^\circ$$

$$d_4 = .812 \cos \theta = .7957$$

$$d_1 = 1.625 \cos \theta = 1.5915$$

$$d_2 = 1.1084 \cos \theta = 1.0866$$

$$d_6 = 0$$

$$\frac{d_1}{\sum d_i} = \frac{1.5915}{8.037} = .1981$$


$$d_5 = .6573 \cos \theta = .6478$$

$$d_3 = 1.1557 \cos \theta = 1.1325$$

$$d_8 = 1.4693 \cos \theta = 1.4390$$

$$d_7 = 1.1084 \cos \theta = 1.0856$$

LESS SEVERES THAN -Y DIRECTION
APPLYING V₁₂



APPLYING V IN -Y DIRECTION

$$V = 8(.248375)(3)(16.71) = 99.6 \text{ LB}$$

$$M_b = (2.0)V = 199.2 \text{ IN-LB}$$

TENSILE FORCE @ SCREW #1

$$F_{t2} = \frac{M_{t1} d_1}{\sum d_i^2} = \frac{(199.2)(.813)}{(3.9609)} = 40.9 \text{ LB}$$

TOTAL TENSILE LOAD, F_b

$$F_b = F_t + FS \frac{l_{eb}}{l_{eb} + l_{em}} F_t$$

$$F_t = F_{t1} + F_{t2} = 12.4 + 40.9 = 53.3 \text{ LB}$$

$$FS = 1.4$$

ASSUME $l_{eb} \gg l_{em}$

$$\text{THEN } \frac{l_{eb}}{l_{eb} + l_{em}} = 1.0$$

$$F_t = 246 \text{ LB}$$

$$F_b = 246 + (1.4)(1.0)(53.3) = 321 \text{ LB}$$

PER NAS1352 NØ4LL7 SCREW, #4, HEAT RESISTANT STEEL

$$F_{tu} = 966 \text{ LB}$$

$$MS = \frac{966}{321} - 1 = +2.0$$

∴ MOUNTING SCREWS OK IN TENSION
ON 1331592 BRACKET

19-96

1331562 MIXER ON 1331582 BRACKET WITH
1331559 FILTERS

Report 10381
 Addendum 1

THE 1331562 MIXER W/1331582 BRACKET & 1331559 FILTERS IS MOUNTED VIA 4 LONG #4 NAS1352N04-16 ATTACHMENT SCREWS TO THE 1331555 LOWER SHELF. GRIDS 784, 786, 813, 815 ARE USED IN THE NASTRAN MODEL TO APPLY PT MASSES (CONM2 1087-1090) OF .292 LB EACH.

LARGEST RESPONSE TO 3T LOAD Z-RESPONSE IS A 1T GRMS LOAD OF 21.15 GRMS AT GRID 815

COMPONENT	GRID	LOAD DIRECTION	RESPONSE OF LARGE MASSES Q=7.1								
			X-RESPONSE			Y-RESPONSE			Z-RESPONSE		
			RMS	GRMS	Q	RMS	GRMS	Q	RMS	GRMS	Q
	784	X	4388	11.36788	1.1	1738	4.502591	0.4	2205	5.71244	0.6
		Y	1330	3.445596	0.3	4840	12.53886	1.2	2910	7.53886	0.7
		Z	1025	2.65544	0.3	1707	4.42228	0.4	5180	13.4197	1.3
	786	X	4383	11.35492	1.1	1755	4.546632	0.5	2778	7.19689	0.7
		Y	1329	3.443005	0.3	4811	12.46373	1.2	3085	7.99223	0.8
		Z	1023	2.650259	0.3	1809	4.686528	0.5	5399	13.987	1.4
	813	X	4387	11.36528	1.1	1737	4.5	0.4	2759	7.14767	0.7
		Y	1346	3.487047	0.3	4852	12.56995	1.2	3062	7.93264	0.8
		Z	1183	3.064767	0.3	1667	4.318653	0.4	7058	18.285	1.8
	815	X	4410	11.42487	1.1	1755	4.546632	0.5	4159	10.7746	1.1
		Y	1402	3.632124	0.4	4791	12.41192	1.2	4086	10.5855	1.0
		Z	1169	3.028497	0.3	1838	4.761658	0.5	8164	21.1503	2.1

STATISTICAL 3T LOAD @ GR 815

$$F_{t1} = 3(21.15)(.292) = 18.5 \text{ LB}$$

PRELOAD





#4 ATTACHMENT SCREWS WITH T= 5.5 IN-LB MAX TORQUE PER 1356429


$$F_i = \frac{5.5}{(.2)(.112)} = 246 \text{ LB}$$

OVERTURNING MOMENT

"3T" LOADS FROM RANDOM VIBRATION, Q=7.1, WITH LARGEST RESPONSE (21.15 GRMS @ 1T @ GR 815) APPLIED WITHOUT REGARD TO DIRECTION OR LOCATION, LOAD IS APPLIED AS A FORCE THROUGH ATTACHMENT BOLT PATTERN CG TO FIND LARGEST POSSIBLE OVERTURNING MOMENT AND BOLT TENSILE LOAD.

ASSUMED IN-PLANE CG @ ATTACHMENT BOLT PATTERN CENTER, HEIGHT OF CG ASSUMED AT 2.0 INCHES.





$$\theta = \tan^{-1} \frac{.625}{.8375} = 36.73^\circ$$


$$d_2 = .8375 / \cos \theta = 1.0450$$

$$d_4 = (.8375 - .7835) \cos \theta = .0433$$

$$d_3 = .8375/\cos\theta + .425\sin\theta = 1.2991$$

$$\alpha_1 = .3711 \cos \theta = .2974$$

$$\frac{d_3}{\sum d_i^2} = \frac{1.2991}{2.8701} = .4526$$



$$\theta = \tan^{-1} \frac{.8375}{1.05} = 38.58^\circ$$

$$d_3 = .8375 / \sin \theta = 1.3431$$


$$d_1 = (.8375 - .7836) \sin \theta = .0336$$

$$d_2 = .7995 + .3390 \sin \theta = 1.0108$$

$$d_4 = .4789 \sin \theta = .2986$$

$$\frac{d_3}{\sum d_i^2} = \frac{1.3431}{2.9160} = \underline{\underline{.4606}}$$

WORST
CASE



$$\theta = \tan^{-1} \frac{.8375}{1.05} = 38.58^\circ$$


$$d_4 = 0$$

$$d_1 = .3390 \cos \theta = .2650$$

$$d_3 = .8375 / \cos \theta + .3820 \sin \theta = 1.3095$$

$$d_2 = 1.0023 + .0539 \cos \theta = 1.0444$$

$$\frac{d_3}{\sum d_i^2} = \frac{1.3095}{2.8759} = .4553$$



$$\theta = \tan^{-1} \frac{1.625}{1.8375} = 36.73^\circ$$

$$d_1 = 0$$

$$d_3 = 1.3102 + .0539 \sin \theta = 1.3424$$

$$d_2 = 0.7748 + 0.3711 \tan \theta = 1.0568$$

$$a_4 = .5695 \sin \theta = .3406$$

$$\frac{d_3}{\sum d_i^2} = \frac{1.3424}{3.0348} = .4423$$

APPLYING V IN CASE 2

$$V = 4(.292)(3)(21.15) = 74.1 \text{ LB}$$

$$M = (2.0)V = 148.2 \text{ IN-LB}$$

TENSILE FORCE AT SCREW #3

$$F_{t2} = \frac{M \pm d_3}{\sum d_i^2} = \frac{(148.2)(1.3431)}{(2.9160)} = 68.3 \text{ LB}$$

TOTAL TENSILE LOAD F_b

$$F_b = F_L + F_S \frac{k_b}{k_b + k_m} F_t$$

$$F_t = F_{t1} + F_{t2} = 18.5 + 68.3 = 86.8 \text{ LB}$$

$$F_S = 1.4$$

ASSUME $k_b \gg k_m$

$$\frac{k_b}{k_b + k_m} = 1.0$$

$$F_L = 246 \text{ LB}$$

$$F_b = 246 + 1.4(1.0)(86.8) = 367 \text{ LB}$$

NAS1352NØ4-16 SCREWS ALLOWABLE LOAD IS

$$F_{tu} = 966 \text{ LB}$$

$$MS = \frac{966}{367} - 1 = +1.6$$

∴ MOUNTING BOLTS OK IN TENSION
ON 1331582 BKT

1331562 MIXER ON 1331595 BRACKET
W/ 1331501 ISOLATOR

THE 1331562 MIXER ON THE 1331595 BRACKET IS MOUNTED VIA 4 NAS1352N04-15 #4 SCREWS TO THE 1331555 LOWER SHELF. GRIDS 841, 842, 872, 873 ARE USED IN THE NASTRAN MODEL TO APPLY PT MASSES (CONM2 1099-1102.) OF .194 LB EACH

LARGEST RESPONSE TO Z-LOAD Z-RESPONSE IS A 1T GRMS LOAD OF 22.15 GRMS AT GP 842.

RANDOM VIBRATION RESULTS W/ Q=7.1

COMPONENT	GRID	LOAD DIRECTION	RESPONSE OF LARGE MASSES Q=7.1								
			X-RESPONSE			Y-RESPONSE			Z-RESPONSE		
			RMS	GRMS	Q	RMS	GRMS	Q	RMS	GRMS	Q
	841	X	4307	11.15803	1.1	1336	3.46114	0.3	2398	6.21503	0.6
		Y	1249	3.235751	0.3	4450	11.5285	1.1	2103	5.44818	0.5
		Z	1380	3.523318	0.3	1057	2.738342	0.3	7942	20.5751	2.0
	842	X	4303	11.14767	1.1	1417	3.670984	0.4	2116	5.48187	0.5
		Y	1248	3.233181	0.3	4549	11.78497	1.2	2115	5.47927	0.5
		Z	1358	3.518135	0.3	1180	3.005181	0.3	8550	22.1503	2.2
	872	X	4234	10.96881	1.1	1337	3.463731	0.3	2445	6.3342	0.6
		Y	1208	3.129534	0.3	4450	11.5285	1.1	2529	6.55181	0.6
		Z	1493	3.867876	0.4	1058	2.735751	0.3	7504	19.4404	1.9
	873	X	4232	10.96373	1.1	1418	3.673575	0.4	2178	5.64249	0.6
		Y	1210	3.134715	0.3	4550	11.78756	1.2	2701	6.99741	0.7
		Z	1490	3.860104	0.4	1180	3.005181	0.3	8045	20.842	2.1

STATISTICAL 3T LOAD @ GR 842

$$F_{L1} = 3(22.15)(.194) = 12.9 \text{ LB}$$

PRELOAD





PER 1356429 FOR #4 SCREWS W/ 5.5 IN-LB T_{MAX}

$$F_L = \frac{5.5}{(.2)(.112)} = 246 \text{ LB}$$

OVERTURNING MOMENT

"3T" LOADS FROM RANDOM VIBRATION, $Q=7.1$ WITH LARGEST RESPONSE (22.15 GRMS @ 1T @ GR 842) APPLIED WITHOUT REGARD TO DIRECTION OR LOCATION. APPLY LOAD THROUGH ATTACHMENT BOLT PATTERN CG TO FIND LARGEST POSSIBLE OVERTURNING MOMENT BOLT TENSILE LOAD.

ASSUMED IN-PLANE CG @ ATTACHMENT BOLT PATTERN
CENTER. HEIGHT OF CG ASSUMED AT 2.0 INCHES




$$\theta = \tan^{-1} \frac{.65}{.55} = 49.76^\circ$$

$$d_2 = d_3 = \frac{.65}{\sin \theta} = .8515$$

$$d_1 = d_4 = .1846 \sin \theta = .1409$$

$$\frac{d_2}{\sum d_i^2} = \frac{.8515}{1.4897} = .5716$$

NOT WORST
CASE



$$\theta = \tan^{-1} \frac{.465}{.55} = 49.76^\circ$$

$$d_2 = d_3 = 0$$

$$d_1 = d_4 = .4654 / \cos \theta + .1846 \cos \theta = .8397$$

$$\frac{d_1}{\sum d_i^2} = \frac{.8397}{1.4103} = .5954$$

WORST
CASE

$$V = 4(.194)(3)(22.15) = 51.5 \text{ LB}$$

$$M = (2.0)V = 103 \text{ IN-LB}$$

$$F_{t2} = \frac{M d_4}{\sum d_i^2} = \frac{(103)(.8397)}{(1.4103)} = 61.3 \text{ LB}$$

$$F_t = F_{t1} + F_{t2} = 129 + 61.3 = 190.3 \text{ LB}$$

$$FS = 1.4$$

$$k_b \gg k_m$$

$$F_b = F_t + FS \frac{k_b}{k_b + k_m} F_t = 190.3 + (1.4)(1.0)(190.3) = 466 \text{ LB}$$

$$\text{NAS1352 N } \phi 4-15 \text{ SCREW, } F_t = 966 \text{ LB}$$

$$MS = \frac{966}{466} - 1 = +1.08$$

∴ MOUNTING BOLTS OK IN TENSION ON 1331595 BKT

UPPER SHELF (A1-2) LARGE MASS ATTACHMENTS

REF 1331491 UPPER RF SHELF
1331490 UPPER RF SHELF ASSY
1356409 RECEIVER ASSY, A1-2
1331471 BAND PASS FILTER BRACKET
1331559 BP FILTER
1331165 BRACKET
MS24693 SCREW
1336610 OSCILLATOR
1331562 MIXER/AMP
1331481 BRACKET
1331482 BRACKET

1331165 BRACKET ATTACHMENT

THE 1331165 BRACKET ATTACHES TO THE UPPER SHELF (1331490) VIA 3 MS24693-C27 SCREWS. ATTACHED TO THE OTHER END OF THE 1331165 BRACKET IS THE 1331471 BRACKET WITH MOUNTED 1331559 BP FILTERS & OTHER HARDWARE. 3 GRID PTS (1806, 1808, 1810) ARE USED IN THE NASTRAN MODEL TO APPLY PT MASSES (CONM2 Z102, Z103, Z104) OF .403 LB EACH.

LARGEST RESPONSE PER Z LOAD Z RESPONSE IS A 1T GRMS LOAD OF 16.27 GRMS AT GR 1806


RANDOM VIBRATION RESULTS, Q=7.1

RESPONSE OF LARGE MASSES Q=7.1											
COMPONENT	GRID	LOAD DIRECTION	X-RESPONSE			Y-RESPONSE			Z-RESPONSE		
			RMS	GRMS	Q	RMS	GRMS	Q	RMS	GRMS	Q
UPPER SHELF	1808	X	4125	10.68653	1.1	1106	2.865285	0.3	1900	4.92228	0.5
		Y	924	2.393782	0.2	1542	3.994819	0.4	1542	3.99482	0.4
		Z	1142	2.958549	0.3	1600	4.145078	0.4	5838	15.1244	1.5
	1806	X	4129	10.69689	1.1	1189	3.080311	0.3	2172	5.62694	0.6
		Y	924	2.393782	0.2	1524	3.948187	0.4	1524	3.94819	0.4
		Z	1144	2.963731	0.3	1726	4.471503	0.4	6282	16.2746	1.6
	1810	X	4122	10.67876	1.1	1067	2.764249	0.3	1578	4.08808	0.4
		Y	925	2.396373	0.2	1428	3.699482	0.4	1429	3.70207	0.4
		Z	1141	2.955959	0.3	1517	3.930052	0.4	5536	14.342	1.4

STATISTICAL 3T LOAD AT GR 1806

$$F_{t1} = 3(16.27)(.403) = 19.7 \text{ LB}$$

	1226	1214	1202	1190		1142	1130	1118	1106
1846	1828	1814	1800	1786	1772	1758	1744	1730	1716
1847	1829	1815	1801	1787	1773	1759	1745	1731	1717
1848	1830	1816	1802	1788	1774	1760	1746	1732	1718
1849	1831	1817	1803	1789	1775	1761	1747	1733	1719
1850	1832	1818	1804	1790	1776	1762	1748	1734	1720
1851	1833	1819	1805	1791	1777	1763	1749	1735	1721
1852	1834	1820	1806	1792	1778	1764	1750	1736	1722
1853	1835	1821	1807	1793	1779	1765	1751	1737	1723
1854	1836	1822	1808	1794	1780	1766	1752	1738	1724
1855	1837	1823	1809	1795	1781	1767	1753	1739	1725
1856	1838	1824	1810	1796	1782	1768	1754	1740	1726
1857	1839	1825	1811	1797	1783	1769	1755	1741	1727
1858	1840	1826	1812	1798	1784	1770	1756	1742	1728
1859	1841	1827	1813	1799	1785	1771	1757	1743	1729
1860	1842	1828	1814	1800	1786	1772	1758	1744	1730
1861	1843	1829	1815	1801	1787	1773	1759	1745	1731
1862	1844	1830	1816	1802	1788	1774	1760	1746	1732
1863	1845	1831	1817	1803	1789	1775	1761	1747	1733
1864	1846	1832	1818	1804	1790	1776	1762	1748	1734
1865	1847	1833	1819	1805	1791	1777	1763	1749	1735
1866	1848	1834	1820	1806	1792	1778	1764	1750	1736
1867	1849	1835	1821	1807	1793	1779	1765	1751	1737
1868	1850	1836	1822	1808	1794	1780	1766	1752	1738
1869	1851	1837	1823	1809	1795	1781	1767	1753	1739
1870	1852	1838	1824	1810	1796	1782	1768	1754	1740
1871	1853	1839	1825	1811	1797	1783	1769	1755	1741
1872	1854	1840	1826	1812	1798	1784	1770	1756	1742
1873	1855	1841	1827	1813	1799	1785	1771	1757	1743
1874	1856	1842	1828	1814	1800	1786	1772	1758	1744
1875	1857	1843	1829	1815	1801	1787	1773	1759	1745
1876	1858	1844	1830	1816	1802	1788	1774	1760	1746
1877	1859	1845	1831	1817	1803	1789	1775	1761	1747
1878	1860	1846	1832	1818	1804	1790	1776	1762	1748
1879	1861	1847	1833	1819	1805	1791	1777	1763	1749
1880	1862	1848	1834	1820	1806	1792	1778	1764	1750
1881	1863	1849	1835	1821	1807	1793	1779	1765	1751
1882	1864	1850	1836	1822	1808	1794	1780	1766	1752
1883	1865	1851	1837	1823	1809	1795	1781	1767	1753
1884	1866	1852	1838	1824	1810	1796	1782	1768	1754
1885	1867	1853	1839	1825	1811	1797	1783	1769	1755
1886	1868	1854	1840	1826	1812	1798	1784	1770	1756
1887	1869	1855	1841	1827	1813	1799	1785	1771	1757
1888	1870	1856	1842	1828	1814	1800	1786	1772	1758
1889	1871	1857	1843	1829	1815	1801	1787	1773	1759
1890	1872	1858	1844	1830	1816	1802	1788	1774	1760
1891	1873	1859	1845	1831	1817	1803	1789	1775	1761
1892	1874	1860	1846	1832	1818	1804	1790	1776	1762
1893	1875	1861	1847	1833	1819	1805	1791	1777	1763
1894	1876	1862	1848	1834	1820	1806	1792	1778	1764
1895	1877	1863	1849	1835	1821	1807	1793	1779	1765
1896	1878	1864	1850	1836	1822	1808	1794	1780	1766
1897	1879	1865	1851	1837	1823	1809	1795	1781	1767
1898	1880	1866	1852	1838	1824	1810	1796	1782	1768
1899	1881	1867	1853	1839	1825	1811	1797	1783	1769
1900	1882	1868	1854	1840	1826	1812	1798	1784	1770
1901	1883	1869	1855	1841	1827	1813	1799	1785	1771
1902	1884	1870	1856	1842	1828	1814	1800	1786	1772
1903	1885	1871	1857	1843	1829	1815	1801	1787	1773
1904	1886	1872	1858	1844	1830	1816	1802	1788	1774
1905	1887	1873	1859	1845	1831	1817	1803	1789	1775
1906	1888	1874	1860	1846	1832	1818	1804	1790	1776
1907	1889	1875	1861	1847	1833	1819	1805	1791	1777
1908	1890	1876	1862	1848	1834	1820	1806	1792	1778
1909	1891	1877	1863	1849	1835	1821	1807	1793	1779
1910	1892	1878	1864	1850	1836	1822	1808	1794	1780
1911	1893	1879	1865	1851	1837	1823	1809	1795	1781
1912	1894	1880	1866	1852	1838	1824	1810	1796	1782
1913	1895	1881	1867	1853	1839	1825	1811	1797	1783
1914	1896	1882	1868	1854	1840	1826	1812	1798	1784
1915	1897	1883	1869	1855	1841	1827	1813	1799	1785
1916	1898	1884	1870	1856	1842	1828	1814	1800	1786
1917	1899	1885	1871	1857	1843	1829	1815	1801	1787
1918	1900	1886	1872	1858	1844	1830	1816	1802	1788
1919	1901	1887	1873	1859	1845	1831	1817	1803	1789
1920	1902	1888	1874	1860	1846	1832	1818	1804	1790
1921	1903	1889	1875	1861	1847	1833	1819	1805	1791
1922	1904	1890	1876	1862	1848	1834	1820	1806	1792
1923	1905	1891	1877	1863	1849	1835	1821	1807	1793
1924	1906	1892	1878	1864	1850	1836	1822	1808	1794
1925	1907	1893	1879	1865	1851	1837	1823	1809	1795
1926	1908	1894	1880	1866	1852	1838	1824	1810	1796
1927	1909	1895	1881	1867	1853	1839	1825	1811	1797
1928	1910	1896	1882	1868	1854	1840	1826	1812	1798
1929	1911	1897	1883	1869	1855	1841	1827	1813	1799
1930	1912	1898	1884	1870	1856	1842	1828	1814	1800
1931	1913	1899	1885	1871	1857	1843	1829	1815	1801
1932	1914	1900	1886	1872	1858	1844	1830	1816	1802
1933	1915	1901	1887	1873	1859	1845	1831	1817	1803
1934	1916	1902	1888	1874	1860	1846	1832	1818	1804
1935	1917	1903	1889	1875	1861	1847	1833	1819	1805
1936	1918	1904	1890	1876	1862	1848	1834	1820	1806
1937	1919	1905	1891	1877	1863	1849	1835	1821	1807
1938	1920	1906	1892	1878	1864	1850	1836	1822	1808
1939	1921	1907	1893	1879	1865	1851	1837	1823	1809
1940	1922	1908	1894	1880	1866	1852	1838	1824	1810
1941	1923	1909	1895	1881	1867	1853	1839	1825	1811
1942	1924	1910	1896	1882	1868	1854	1840	1826	1812
1943	1925	1911	1897	1883	1869	1855	1841	1827	1813
1944	1926	1912	1898	1884	1870	1856	1842	1828	1814
1945	1927	1913	1899	1885	1871	1857	1843	1829	1815
1946	1928	1914	1900	1886	1872	1858	1844	1830	1816
1947	1929	1915	1901	1887	1873	1859	1845	1831	1817
1948	1930	1916	1902	1888	1874	1860	1846	1832	1818
1949	1931	1917	1903	1889	1875	1861	1847	1833	1819
1950	1932	1918	1904	1890	1876	1862	1848	1834	1820
1951	1933	1919	1905	1891	1877	1863	1849	1835	1821
1952	1934	1920	1906	1892	1878	1864	1850	1836	1822
1953	1935	1921	1907	1893	1879	1865	1851	1837	1823
1954	1936	1922	1908	1894	1880	1866	1852	1838	1824
1955	1937	1923	1909	1895	1881	1867	1853	1839	1825
1956	1938	1924	1910	1896	1882	1868	1854	1840	1826
1957	1939	1925	1911	1897	1883	1869	1855	1841	1827
1958	1940	1926	1912	1898	1884	1870	1856	1842	1828
1959	1941	1927	1913	1899	1885	1871	1857	1843	1829
1960	1942	1928	1914	1900	1886	1872	1858	1844	1830
1961	1943	1929	1915	1901	1887	1873	1859	1845	1831
1962	1944	1930	1916	1902	1888	1874	1860	1846	1832
1963	1945	1931	1917	1903	1889	1875	1861	1847	1833
1964	1946	1932	1918	1904	1890	1876	1862	1848	1834
1965	1947	1933	1919	1905	1891	1877	1863	1849	1835
1966	1948	1934	1920	1906	1892	1878	1864	1850	1836
1967	1949	1935	1921	1907	1893	1879	1865	1851	1837
1968	1950	1936	1922	1908	1894	1880	1866	1852	1838
1969	1951	1937	1923	1909	1895	1881	1867	1853	1839
1970	1952	1938	1924	1910	1896	1882	1868	1854	1840
1971	1953	1939	1925	1911	1897	1883	1869	1855	1841
1972	1954	1940	1926	1912	1898	1884	1870	1856	1842
1973	1955	1941	1927	1913	1899	1885	1871	1857	1843
1974	1956	1942	1928	1914	1900	1886	1872	1858	1844
1975	1957	1943	1929	1915	1901	1887	1873	1859	1845
1976	1958	1944	1930	1916	1902	1888	1874	18	



Report 10381
Addendum 1


$$F_c = \frac{T}{(12)(d)} = \frac{10}{(12)(6.138)} = 362 \text{ lb}$$

THE JOINT IN QUESTION IS A LINE OF 3 SCREWS. CONNECTING THE ITEM (5) 1331165 BRACKET WITH THE ITEM (27) SCREWS TO THE ITEM (15) SHELF.

OVERTURNING MOMENT


BECAUSE THE PRESENT BOLT PATTERN OF INTEREST IS ARRANGED IN A LINE AND NOT A PLANE PATTERN, THE PROCEDURE USED IN DETERMINING ADDITIONAL TENSILE LOADS IN THE ATTACHMENT SCREWS, AS UTILIZED ABOVE FOR OTHER COMPONENT MOUNTINGS, NEED BE MODIFIED.

THE PATTERN IS 3 SCREWS SPACED 1.250 INCHES APART. THUS THE PATTERN CG IS AT THE MIDDLE SCREW.



AS SHOWN ON THE PREVIOUS PAGE SKETCH, THE ITEM (10) 1331471 BRACKET ATTACHES TO THE ITEM (5) 1331165 BRACKET. MOUNTED ON THE 1331471 BKT ARE FILTERS AND CONNECTORS, SUCH THAT THE HARDWARE ATTACHED TO THE SHELF AT THE 3 MS24693-C27 SCREWS (ITEM (27)) WEIGHS APPROXIMATELY 1.21 LB.

OF INTEREST IS A LOAD IN THE Y-DIRECTION, NORMAL TO THE 1331471 BRACKET FACE, PRODUCING A MOMENT ALONG THE X-AXIS WHICH WOULD REACT THROUGH THE 1331165 BKT TO PRODUCE ADDED BOLT TENSION AND ALSO FLANGE BENDING IN THE 1331165 BKT.



PER THE PREVIOUS RANDOM VIBRATION RESULTS, $Q=7.1$
TABLE, THE LARGEST Y-RESPONSE IS 4.47 GRMS AT
GRID 1806. THUS, FOR A "3Y" LOAD

$$F_y = (3)(.4033)(3)(4.47) = 16.2 \text{ LB}$$


$$M_x = \frac{F_y (L)}{8} = (16.2)(1) = 16.2 \text{ IN-LB}$$

FIXED ENDS
W/ CENTER
LOAD

ON A PER INCH BASIS USING THE 1331165 BKT SPACING
BETWEEN THE SCREWS, $1.250 + 1.250 = 2.500$

$$M_{x'} = \frac{16.2}{2.50} = 6.5 \frac{\text{IN-LB}}{\text{IN}}$$

1331165 BRACKET




$$\sum M_2 = 0 \quad F_1 (.188) = 6.5$$

$$F_1 = 34.5 \text{ LB/IN}$$

$$F_2 = 34.5 \text{ LB/IN}$$

MOMENT
DIAGRAM



BOLT LOAD/BOLT 3 BOLTS SHARE LOAD

Report 10381
Addendum 1

$$F_{t2} = (34.5)(2.500)/3 = 28.7 \text{ LB}$$

TOTAL TENSILE LOAD, F_b , IN SCREW

$$F_b = F_i + F_s \frac{J_{eb}}{J_{eb} + J_{em}} F_t$$

$$F_t = F_{t1} + F_{t2} = 19.7 + 28.7 = 48.4 \text{ LB}$$

WITH $F_s = 1.4$ APPLIED TO F_t ONLY, AND $F_i = 362 \text{ LB}$

USING WORST CASE SCENARIO $J_{eb} \gg J_{em}$

$$F_b = F_i + F_s (1) F_t$$

$$= 362 + (1.4)(1.0)(48.4) = 430 \text{ LB}$$

ALLOWABLE MS24693-C27

$$F_{tu} = 725 \text{ LB}$$

$$MS = \frac{725}{430} - 1 = +1.68$$

∴ 1331165 BKT MOUNTING SCREWS TO SHELF
ARE OK IN TENSION

1331165-1 BRACKET FLANGE BENDING

THE BRACKET FLANGE MUST REACT THE ABOVE
DETERMINED $M = 6.5 \text{ IN-LB/IN}$ MOMENT. A
BENDING STRESS IS SET UP IN THE 1331165-1 BKT

$$S = \frac{6M}{t^2}$$

$$M = 6.5 \text{ IN-LB/IN}$$

$$t = .062-.010 \text{ MIN}$$

$$= \frac{6(6.5)}{(.052)^2}$$

$$= 14423 \text{ PSI}$$

MAT'L 6061-T6 ALUM (1331165-1 BKT)

$$F_{ty} = 35000 \text{ psi}$$

$$F_{tu} = 42000 \text{ psi}$$

WITH FS = 1.25 YIELD, 1.4 ULTIMATE

$$MS = \frac{F_{ty}}{1.25 \times S_t} - 1 = \frac{35000}{1.25(14423)} - 1$$

$$= +.94$$

$$MS = \frac{F_{tu}}{1.4 \times S_t} - 1 = \frac{42000}{1.4(14423)} - 1$$

$$= +1.1$$

∴ FLANGE ON 1331165 OK.

1331482

1331481 BRACKETS W/ 1331562 MIXERS & OTHER HARDWARE

THE 1331481 BRACKET MOUNTS BELOW THE 1331490 SHELF WITH 4 NAS1352NØ4LL4 #4 SCREWS. ATTACHED TO THE BRACKET ARE THE 1331562 MIXER & VARIOUS OTHER HARDWARE. 4 GRID PTS (1613, 1615, 1679, 1681) ARE USED IN THE NASTRAN MODEL TO APPLY PT MASSES (CONM2 2076, 2078, 2092, 2094) OF .222 LB EACH.

LARGEST RESPONSE PER Z-LOAD Z-RESPONSE IS A 17 GRMS LOAD OF 26.728 GRMS AT GR 1613.

THE 1331482 BRACKET MOUNTS ABOVE THE 1331490 SHELF WITH 4 NAS1352NØ4LL6 #4 SCREWS. ATTACHED TO THE BRACKET ARE A 1331562 MIXER & VARIOUS OTHER HARDWARE. 4 GRIDS (1615, 1619, 1681, 1685) ARE USED IN THE NASTRAN MODEL TO APPLY PT MASSES (CONM2 2096-2098) OF .237 LB EACH.

LARGEST RESPONSE PER Z-LOAD Z-RESPONSE IS A 17 GRMS LOAD OF 19.09 GRMS AT GR 1681.

RESPONSE OF LARGE MASSES Q=7.1											
COMPONENT	GRID	LOAD DIRECTION	X-RESPONSE			Y-RESPONSE			Z-RESPONSE		
			RMS	GRMS	Q	RMS	GRMS	Q	RMS	GRMS	Q
	1681	X	4444	11.51295	1.1	1274	3.300518	0.3	2691	6.9715	0.7
		Y	751	1.945596	0.2	1162	3.010363	0.3	1162	3.01036	0.3
		Z	736	1.906736	0.2	1888	4.891192	0.5	7370	19.0933	1.9
	1685	X	4447	11.52073	1.1	1175	3.044041	0.3	2241	5.8057	0.6
		Y	750	1.943005	0.2	1080	2.797927	0.3	1080	2.79793	0.3
		Z	736	1.906736	0.2	1720	4.455959	0.4	7183	18.6088	1.8
	1615	X	4562	11.81865	1.2	1263	3.272021	0.3	2309	5.98187	0.6
		Y	897	2.323834	0.2	1805	4.676166	0.5	1805	4.67617	0.5
		Z	924	2.393782	0.2	1890	4.896373	0.5	6861	17.7746	1.8
	1619	X	4561	11.81606	1.2	1176	3.046632	0.3	2173	5.62953	0.6
		Y	897	2.323834	0.2	1424	3.689119	0.4	1424	3.68912	0.4
		Z	919	2.380829	0.2	1728	4.476684	0.4	5271	13.6554	1.4
	1679	X	4443	11.51036	1.1	1327	3.437824	0.3	3456	8.95337	0.9
		Y	751	1.945596	0.2	1818	4.709845	0.5	1818	4.70984	0.5
		Z	736	1.906736	0.2	1983	5.137306	0.5	8986	23.2798	2.3
	1683	X	4445	11.51554	1.1	1234	3.196891	0.3	2328	6.03109	0.6
		Y	750	1.943005	0.2	907	2.349741	0.2	907	2.34974	0.2
		Z	736	1.906736	0.2	1820	4.715026	0.5	6888	17.8446	1.8
	1613	X	4562	11.81865	1.2	1319	3.417098	0.3	2929	7.58808	0.8
		Y	897	2.323834	0.2	2475	6.411917	0.6	2475	6.41192	0.6
		Z	924	2.393782	0.2	1983	5.137306	0.5	10317	26.728	2.6
	1617	X	4562	11.81865	1.2	1226	3.176166	0.3	2097	5.43264	0.5
		Y	897	2.323834	0.2	1503	3.893782	0.4	1503	3.89378	0.4
		Z	923	2.391192	0.2	1825	4.727979	0.5	5326	13.7979	1.4

1331481 LOWER BRACKET MOUNTING BOLTS
STATISTICAL 3T LOAD @ GR 1613

Report 10381
Addendum 1

$$F_{E1} = 3(26.728)(.222) = 17.8 \text{ LB}$$

PRELOAD



#4 SCREWS NAS1352N0444, REF 1356409


$$F_L = \frac{5.5}{(.12)(.112)} = 246 \text{ LB}$$

OVERTURNING MOMENT

RANDOM VIBRATION "3T" LOADS ($Q=7.1$) LARGEST RESPONSE (26.728 GRAMS @ 1T @ GR 1613) ARE APPLIED WITHOUT REGARD TO DIRECTION. A FORCE THROUGH THE ASSUMED MOUNTING BOLT CG IS USED TO FIND THE LARGEST POSSIBLE OVERTURNING MOMENT BOLT TENSILE LOAD.

ASSUMED IN-PLANE CG IS @ CENTER OF ATTACHMENT BOLT PATTERN, HEIGHT OF CG ASSUMED AT 1.75 INCHES.





$$\theta = \tan^{-1} \frac{.460}{.950} = 25.84^\circ$$

$$d_1 = .92 \cos \theta = .8280$$

$$d_2 = d_3 = 0$$

$$d_4 = d_1$$

$$\frac{d_4}{\sum d_i^2} = .6038$$

$$V = 4(.222)(3)(26.728) = 71.2 \text{ LB}$$

$$M_t = (1.75)V = 124.6 \text{ IN-LB}$$

TENSILE FORCE @ SCREW #4

$$F_{t2} = \frac{M_t d_4}{\sum d_i^2} = \frac{(124.6)(.8280)}{(1.3711)} = 75.2 \text{ LB}$$

TOTAL TENSILE FORCE, F_b

$$F_b = F_L + F_S \frac{L_{tb}}{L_{tb} + L_{tm}} F_t$$

$$F_t = F_{t1} + F_{t2} = 17.8 + 75.2 = 93.0 \text{ LB}$$

$$FS = 1.4$$

126 > 124 ASSUMED

$$F_b = 246 + (1.4)(1.0)(93.0) = 376 \text{ LB}$$

FOR NAS1352 NØ4 SCREWS

$$F_{t4} = 966 \text{ LB}$$

$$MS = \frac{966}{376} - 1 = +1.6$$

∴ MOUNTING SCREWS OK @ 1331481 LOWER BKT.

1331482 UPPER BKT MOUNTING BOLTS

$$F_{t1} = 3(19.09)(.237) = 13.6 \text{ LB}$$

$$F_L = 246 \text{ LB} \quad \text{NAS1352 NØ4LL6}$$

OVERTURNING MOMENT

WITH SAME BOLT PATTERN AS THE 1331481 LOWER BRACKET, ASSUME IN-PLANE CG IS @ CENTER OF ATTACHMENT BOLT PATTERN, BUT NOW, THE HEIGHT OF THE CG IS INCREASE TO A CONSERVATIVE 3.0 INCHES

$$V = 4(.237)(3)(19.09) = 54.3 \text{ LB}$$

$$M_t = (3.0)V = 162.9 \text{ IN-LB}$$

$$F_{t2} = \frac{(162.9)(.8280)}{(1.3711)} = 98.3 \text{ LB}$$

$$F_t = F_{t1} + F_{t2} = 13.6 + 98.3 = 111.9 \text{ LB}$$

$$F_b = 246 + (1.4)(1.0)(111.9) = 403 \text{ LB}$$

$$F_{tu} = 966 \text{ LB}$$

$$MS = \frac{966}{403} - 1 = +1.4$$

∴ MOUNTING SCREWS OK @ 1331482 UPPER BKT

4 1336610 MOUNT TO THE 1331440 UPPER SHELF, 3 ABOVE THE SHELF AND 1 BELOW. ALL USE 4 NAS1352NØ4 LLL #4 SCREWS. 4 GRID PTS ARE USED PER DRO TO APPLY PT MASS.

DRO	GRIDS	CONM2	UNIT WTS
-3	1723, 1728, 1779, 1784	2084-2087	.3966 LB
-4	1724, 1729, 1780, 1785	2072-2075	.3966
-5	1500, 1501, 1577, 1582	2088-2091	.3966
-8	1793, 1798, 1831, 1836	2080-2083	.3966

LARGEST RESPONSE PER $\frac{1}{2}$ LOAD $\frac{1}{2}$ RESPONSE IS A 17 GRMS LOAD OF 22.10 GRMS AT GR 1724.

STATISTICAL 3T LOAD @ GR 1724


$$F_{E1} = 3(22.10)(.3966) = 26.3 \text{ LB}$$

PRELOAD

$$F_i = 246 \text{ LB} \quad \#4 \text{ SCREW}$$

OVERTURNING MOMENT

USING "3T" LOAD FROM RANDOM VIA, $Q=7.1$, THE LARGEST RESPONSE (22.10 GRMS @ 1T @ GR 1724) IS APPLIED WITHOUT REGARD TO DIRECTION, AS A FORCE THROUGH THE ASSUMED CG TO DEVELOP THE LARGEST POSSIBLE OVERTURNING MOMENT BOLT TENSILE LOAD.



COMPONENT	GRID	LOAD DIRECTION	RESPONSE OF LARGE MASSES Q=7.1								
			X-RESPONSE			Y-RESPONSE			Z-RESPONSE		
			RMS	GRMS	Q	RMS	GRMS	Q	RMS	GRMS	Q
1831		X	4012	10.39378	1.0	1138	2.948187	0.3	1479	3.83161	0.4
		Y	1131	2.930052	0.3	1192	3.088083	0.3	1192	3.08808	0.3
		Z	1459	3.779793	0.4	1652	4.279793	0.4	5008	12.9741	1.3
1836		X	4004	10.37306	1.0	1093	2.831606	0.3	777	2.01295	0.2
		Y	1137	2.945596	0.3	1307	3.38601	0.3	1307	3.38601	0.3
		Z	1454	3.766839	0.4	1498	3.880829	0.4	4848	12.5596	1.2
1793		X	4166	10.79275	1.1	1139	2.950777	0.3	2116	5.48187	0.5
		Y	869	2.251295	0.2	1687	4.370466	0.4	1687	4.37047	0.4
		Z	1050	2.720207	0.3	1653	4.282383	0.4	6387	16.5466	1.6
1798		X	4159	10.77461	1.1	1093	2.831606	0.3	1207	3.12694	0.3
		Y	868	2.248705	0.2	1110	2.875648	0.3	1110	2.87565	0.3
		Z	1049	2.717617	0.3	1499	3.88342	0.4	5108	13.2332	1.3
1779		X	4196	10.87047	1.1	1139	2.950777	0.3	2095	5.42746	0.5
		Y	829	2.147668	0.2	1700	4.404145	0.4	1700	4.40415	0.4
		Z	980	2.53886	0.3	1654	4.284974	0.4	6551	16.9715	1.7
1784		X	4191	10.85751	1.1	1093	2.831606	0.3	1313	3.40155	0.3
		Y	828	2.145078	0.2	1057	2.738342	0.3	1057	2.73834	0.3
		Z	980	2.53886	0.3	1499	3.88342	0.4	5100	13.2124	1.3
1723		X	4363	11.30311	1.1	1142	2.958549	0.3	2420	6.26943	0.6
		Y	722	1.870466	0.2	1328	3.440415	0.3	1328	3.44041	0.3
		Z	735	1.904145	0.2	1661	4.303109	0.4	8147	21.1062	2.1
1728		X	4378	11.34197	1.1	1092	2.829016	0.3	2724	7.05699	0.7
		Y	727	1.88342	0.2	1072	2.777202	0.3	1072	2.7772	0.3
		Z	727	1.88342	0.2	1499	3.88342	0.4	6558	16.9896	1.7

COMPONENT	GRID	LOAD DIRECTION	X-RESPONSE			Y-RESPONSE			Z-RESPONSE		
			RMS	GRMS	Q	RMS	GRMS	Q	RMS	GRMS	Q
1577		X	4633	12.00259	1.2	1152	2.984456	0.3	2436	6.31088	0.6
		Y	1064	2.756477	0.3	1914	4.958549	0.5	1914	4.95855	0.5
		Z	1150	2.979275	0.3	1673	4.334197	0.4	5613	14.5415	1.4
1582		X	4621	11.9715	1.2	1082	2.803109	0.3	2180	5.64767	0.6
		Y	1073	2.779793	0.3	2500	6.476684	0.6	2500	6.47668	0.6
		Z	1132	2.932642	0.3	1520	3.937824	0.4	8141	21.0907	2.1
1500		X	4744	12.29016	1.2	1154	2.989637	0.3	2100	5.44041	0.5
		Y	1363	3.531088	0.3	2251	5.831606	0.6	2251	5.83161	0.6
		Z	1595	4.132124	0.4	1675	4.339378	0.4	4813	12.4689	1.2
1501		X	4751	12.30829	1.2	1082	2.803109	0.3	1582	4.09845	0.4
		Y	1374	3.559585	0.4	2186	5.663212	0.6	2186	5.66321	0.6
		Z	1620	4.196891	0.4	1520	3.937824	0.4	4667	12.0907	1.2
1724		X	4365	11.30829	1.1	1113	2.88342	0.3	2562	6.63731	0.7
		Y	722	1.870466	0.2	1512	3.917098	0.4	1512	3.9171	0.4
		Z	734	1.901554	0.2	1610	4.170984	0.4	8530	22.0984	2.2
1729		X	4379	11.34456	1.1	1129	2.92487	0.3	2003	5.18912	0.5
		Y	729	1.888601	0.2	710	1.839378	0.2	710	1.83938	0.2
		Z	726	1.880829	0.2	1522	3.943005	0.4	4922	12.7513	1.3
1785		X	4191	10.85751	1.1	1128	2.92228	0.3	927	2.40155	0.2
		Y	829	2.147668	0.2	811	2.101036	0.2	811	2.10104	0.2
		Z	983	2.546632	0.3	1520	3.937824	0.4	4604	11.9275	1.2
1780		X	4195	10.86788	1.1	1104	2.860104	0.3	1104	2.8601	0.3
		Y	829	2.147668	0.2	1701	4.406736	0.4	1701	4.40674	0.4
		Z	979	2.536269	0.3	1595	4.132124	0.4	6540	16.943	1.7

ASSUME IN-PLANE CG @ CENTER OF ATTACHMENT
BOLT PATTERN. HEIGHT OF CG ASSUMED AT 1.5 IN.

PER 1336610 EVALUATION OF LOWER SHELF

$$\frac{d_1}{\sum d_i^2} = .2780$$

$$V = 4(.3966)(3)(22.10) = 105.2 \text{ LB}$$

$$M_t = (1.5)(V) = 157.8 \text{ IN-LB}$$

TENSILE FORCE @ SCREW

$$F_{t2} = \frac{M_t d_3}{\sum d_i^2} = (157.8)(.2780) = 43.9 \text{ LB}$$

$$F_t = F_{t1} + F_{t2} = 26.3 + 43.9 = 70.2 \text{ LB}$$

TOTAL TENSILE LOAD

$$F_b = F_L + F_S \frac{J_{kb}}{J_{kb} + J_{km}} F_t$$

$$= 246 + (1.4)(1.0)(70.2) = 344 \text{ LB}$$

FOR NAS1352NØ4LL6 SCREW

$$F_{t4} = 966 \text{ LB}$$

$$MS = \frac{966}{344} - 1 = +1.8$$

∴ ALL 1331610 OSCILLATOR MOUNTING BOLTS
ARE ADEQUATE IN TENSION.

5.4.5 Lower Baseplate Stresses per Random Vibration Loads

The following pages contain a detailed analysis of lower baseplate stresses per random vibration loads.

TABLE 59 A1-EOS 1356405 LOWER BASEPLATE STRESSES - RANDOM VIBRATION LOADS							
STRESS CATEGORY	LOAD CASE	LOCATION	MATERIAL	3s STRESS PSI	F _{ty} /F _{tu} PSI	FS	MARGIN OF SAFETY
STRESSES UNDER LOWER CARD CAGE	RANDOM Z	EL 289	6061-T6	5755	35000	1.25	3.87
				5755	42000	1.4	4.21
STRESS CATEGORY	LOAD CASE	LOCATION	MATERIAL	3s STRESS PSI	F _{ty} /F _{tu} PSI	FS	MARGIN OF SAFETY
STRESSES UNDER PANEL ATTACHMENTS	RANDOM Y	LOWER FRONT PANEL	6061-T6	18594	35000	1.25	0.51
				18594	42000	1.4	0.61
	RANDOM Y	LOWER AFT PANEL	6061-T6	25654	35000	1.25	0.09
				25654	42000	1.4	0.17
	RANDOM Y	LOWER RIGHT PANEL	6061-T6	8737	35000	1.25	2.20
				8737	42000	1.4	2.43
STRESS CATEGORY	LOAD CASE	LOCATION	MATERIAL	3s STRESS PSI	F _{su} PSI	FS	MARGIN OF SAFETY
SHEAR STRESS IN LEFT PANEL FLANGE GROOVE	RANDOM Y	EL 3256	6061-T6	1023	27000	1.4	17.85

LOWER BASEPLATE (1356405)

1-4-96 Report 10381
Addendum 1

5.4.5.1 STRESSES IN THIN SHELL ELEMENTS UNDER CARD CAGE

PER RANDOM VIBRATION (9.97 GRMS) $w/Q=7.1$

REF NASTRAN MODEL

- 1) LOWER BASEPLATE GRIDS
- 2) LOWER CARD CAGE BASE GRIDS
- 3) LOWER BASEPLATE ENLARGEMENT
w/ LOWER CARD CAGE SILHOUETTE
w/ BASEPLATE GRIDS & SHELLS

METHOD - EVALUATE STRESSES AT SHELLS IN THE
BASEPLATE BELOW THE LOWER CARD CAGE
FOOTPRINT FOR 3 UNIDIRECTION
RANDOM VIBRATION CASES, X, Y, Z.

GRIDS CONNECTING LOWER BASEPLATE & CARD CAGE

GR 2928-2933

GR 119, 140, 161, 182, 203, 224

GR 114, 135, 156, 177, 198, 219

ELEMENT ON BASEPLATE EVALUATED

CQUAD4/	259-271
TRIAB	277-289
ELEMENTS	295-307
	313-325
	331-343
	349-361
	363-375
	3968-3974

REF 3 SPREAD SHEETS FOR X-LOAD, Y-LOAD,
Z-LOAD, RESPECTIVELY. MOST SEVERE CASE
AND CONDITION

Z-LOAD

ELEMENT 289

3T STRESS 5755 PSL

MATERIAL 6061-T6

$F_{ty} = 35000 \text{ PSL}$

$F_{tu} = 42000 \text{ PSL}$

1-8-96

FACTORS OF SAFETY

1.25 YIELD
1.4 ULTIMATE

MARGINS OF SAFETY

YIELD


$$MS = \frac{35000}{1.25 \times 5755} - 1 = + 3.8$$

ULTIMATE

$$MS = \frac{42000}{1.4 \times 5755} - 1 = + 4.2$$

∴ MAGNITUDES OF STRESSES IN THIN SHELLS OF LOWER BASEPLATE UNDER THE CARD CAGE ARE ACCEPTABLE FOR RANDOM VIBRATION "3σ" STRESSES

BOTTOM PLATE OF LOWER CARD CHARGE
GRIDS
GRIDS ON LOWER EP



LOWER BP CARDS

1-4-96

21 2019	18 17	16	15	14	13	12	11	10	9	8	7 6	5	4	3	2	1
82 4140	69 38	67	36	35	34	33	32	31	30	29	28 7	26	25	24	23	22
63 6261	60 59	58	57	56	55	54	53	52	51	50	49 18	47	46	45	44	43
84 8382	81 80	79	78	77	76	75	74	73	72	71	70 69	68	67	66	65	64
105 10403	102 101	100	99	98	97	96	95	94	93	92	91 90	89	88	87	86	85
126 12522928	123 122	121	120	119	118	117	116	115	114 113	112 11	110	109	108	107 10	106	105
145 452929	144 143	142	141	140	139	138	137	136	135 134	133 132	131	130	129	128	127	126
147																
168 16762930	165 164	163	162	161	160	159	158	157	156 155	154 153	152	151	150	149 14	148	147
189	188 185	184	183	182	181	180	179	178	177 176	175 174	173	172	171	170	169	168
210 209082932	207 206	205	204	203	202	201	200	199	198 197	196 195	194	193	192	191 19	190	189
231 230292933	228 227	226	225	224	223	222	221	220	219 218	217 216	215	214	213	212 21	211	210
252 25150	249 248	247	246	245	244	243	242	241	240 239	238 237	236	235	234	233 23	232	231
275 27473	272 271	270	269	268	267	266	265	264	263 262	261 260	259	258	257	256 25	255	254

LOWER BP GRID
CQUAD
CIRIA3



LOWER CC

105	104	103	102	101	100	99	98	97	96	95	94	93	92
271	270	269	268	267	266	265	264	263	262	261	260	259	
125	124	123	122	121	120	119	118	117	116	115	114	113	
289	288	287	286	285	284	283	282	281	280	279	278	277	
146	145	144	143	142	141	140	139	138	137	136	135	134	
307	306	305	304	303	302	301	300	299	298	297	296	295	
167	166	165	164	163	162	161	160	159	158	157	156	155	
325	324	323	322	321	320	319	318	317	316	315	314	313	
188	187	186	185	184	183	182	181	180	179	178	177	176	
343	342	341	340	339	338	337	336	335	334	333	332	331	
209	208	207	206	205	204	203	202	201	200	199	198	197	
361	360	359	358	357	356	355	354	353	352	351	350	349	
230	229	228	227	226	225	224	223	222	221	220	219	218	
251	250	249	248	247	246	245	244	243	242	241	240	239	
272	271	270	269	268	267	266	265	264	263	262	261	260	

LOWER BASEPLATE GRID


LOWER CARD CARDS
FOOTPRINT SILHOUETTE

TEMPZ


LOWER BASEPLATE SHELL ELEMENTS RANDOM VIBRATION RMS STRESSES Q=7.1			
Z - LOAD			
ELEMENT	1 SIGMA COMPONENT RMS STRESS (PSI)	3 SIGMA PRINCIPAL RMS STRESS (PSI)	1ST MODE FREQUENCY (HZ)
285(3)	156	963	403
285(5)	314		666
285(7)	33		436
285(10)	82	905	675
285(12)	295		672
285(14)	37		415
286(3)	106	855	533
286(5)	254		678
286(7)	75		344
286(10)	109	726	496
286(12)	236		673
286(14)	29		725
287(3)	43	327	638
287(5)	70		528
287(7)	51		308
287(10)	157	489	228
287(12)	59		432
287(14)	24		615
288(3)	389	1172	167
288(5)	234		179
288(7)	19		455
288(10)	153	561	219
288(12)	57		389
288(14)	66		302
289(3)	1901	5755	221
289(5)	766		243
289(7)	143		254
289(10)	1783	5353	221
289(12)	846		215
289(14)	40		518
295(3)	40	244	319
295(5)	56		247
295(7)	32		263
295(10)	17	146	505
295(12)	43		208
295(14)	13		406
Page 4			

LOWER BASEPLATE - LOCALIZED STRESSES UNDER
PANEL ATTACHMENTS

EVALUATED ARE THE THIN SECTIONS UNDER THE ATTACHMENTS OF THE LOWER FRONT, LOWER AFT, AND LOWER RIGHT PANELS, WHOSE CROSS SECTIONS ARE AS FOLLOWS.

LOWER FRONT PANEL ATTACHMENT TO LOWER BASEPLATE

CONSIDER TOP SECTION AS A FIXED END BEAM W/ CENTER LOAD.



PER FLANGE BENDING ANALYSIS OF THE LOWER FRONT PANEL LOWER FLANGE PER RANDOM VIBRATION, $Q=7.1$ THE MAXIMUM FORCE IN LBS/IN WAS DETERMINED FROM RANDOM Y LOAD AS

$$F_1 = 69.83 \text{ LB/IN} \quad \begin{array}{l} \text{"1 G" LOAD} \\ \text{"3 G" LOAD} \end{array}$$

$$= 209.5 \text{ LB/IN}$$

MAXIMUM BENDING MOMENT IS

$$M = \frac{F_1 l}{8} \quad \text{② ENDS OF BEAM & AT CENTER}$$

$$= \frac{(209.5)(.500)}{8} = 13.09 \text{ IN-LB/IN}$$

BENDING STRESS IN BEAM

$$\sigma = \frac{6M}{t^2} = \frac{6(13.09)}{(.075-.010)^2} = 18594 \text{ PSI}$$

APPLY $FS = 1.25$ YIELD, 1.4 ULTIMATE
ALLOWABLE, 6061-T6 ALUMINUM

$$F_{TY} = 35000 \text{ PSI}$$


$$F_{TU} = 42000 \text{ PSI}$$

$$MS = \frac{35000}{1.25(18594)} - 1 = +.51$$


$$MS = \frac{42000}{1.4(18594)} - 1 = +.61$$

∴ LOWER BASEPLATE "U-BEAM CAP" OK
UNDER LOWER FRONT PANEL

LOWER AFT PANEL ATTACHMENT TO LOWER BASEPLATE



CONSIDER TOP SECTION AS A FIXED END BEAM
WITH OFFSET LOAD.



PER FLANGE BENDING ANALYSIS OF THE LOWER AFT
PANEL LOWER FLANGE PER RANDOM VIBRATION, $Q=7.1$,
THE MAXIMUM FORCE IN LB/IN WAS DETERMINED
FROM RANDOM Y LOAD AS

$$F_1 = 238.8 \text{ LB/IN}$$

$$= 716.4 \text{ LB/IN}$$

"15" LOAD
"35" LOAD

MAXIMUM BENDING MOMENT IS FOUND FROM

Report 10381
Addendum 1

$$R_A = \frac{F_1 b^2}{l^3} (3a+b) = .97079 F_1 = 695.5 \text{ LB/IN}$$

$$R_B = \frac{F_1 a^2}{l^3} (3b+a) = .02921 F_1 = 20.9 \text{ LB/IN}$$

$$\begin{aligned} a &= .249 \\ b &= 2.187 \\ l &= 2.436 \end{aligned}$$

$$M = -\frac{F_1 ab^2}{l^2} + R_A x \quad \text{A to B}$$

$$= -\frac{F_1 ab^2}{l^2} + R_A x - F_1 (x-a) \quad \text{B to C}$$

MAXIMUM M @ END A (x=0)

$$M = -143.78 \text{ IN-LBS/IN}$$

BENDING STRESS (@ x=0)


$$\sigma = \frac{6M}{t^2} = \frac{6(143.78)}{(.075 \cdot .010)^2} = 204184 \text{ PSI}$$

YIELD MS

$$MS = \frac{35000}{1.25 \times 204184} - 1 = -.86$$

∴ CONSIDERABLY OVERSTRESSED

MODIFY THICKNESS TO $t = .200 - .010$ FOR .688 IN



BENDING STRESS $w/t = .200 - .010$ @ END A

$$\sigma = \frac{6M}{t^2} = \frac{6(143.78)}{(.200 - .010)^2} = 23897 \text{ PSI}$$

$$MS = \frac{35000}{1.25 \times 23897} - 1 = +.17$$

$$MS = \frac{42000}{1.4 \times 23897} - 1 = +.26$$

PRELIMINARY INDICATIONS SHOW ACCEPTABLE REDESIGN WITH $t = .200 - .010$ BELOW PANEL ATTACHMENT.

A FINITE ELEMENT MODEL IS CONSTRUCTED TO VERIFY THE HAND CALCULATED RESULTS

A 2.436 INCH WIDE PLATE (OF ARBITRARY LENGTH) IS CONSTRUCTED WITH ALL ENDS FIXED.

MODEL 1 IS A CONSTANT $t = .065$ LOADED .249 IN FROM END BY A 716.4 LB/IN VERTICAL LOAD. RESULT SHOULD AGREE WITH ORIGINAL HAND CALC.

MODEL	MAX MAJOR STRESS	MAX VON MISES STRESS
1	201999 PSI	178275 PSI

201999 PSI ~ HAND CALC 204184 PSI (1% ERROR)

MODEL 2 CONSIDERS THE RECESS TO $t = .053$ IN IN THE UPPER HALF OF THE MODEL FROM $x = .688$ TO 2.436 (SURFACE 1). RESULTS WITH SAME LOAD

MODEL	MAX MAJOR STRESS	MAX VON MISES STRESS
2	206879 PSI	182582 PSI

MODEL 3, THE REDESIGN, CONSIDERS THE $t = .053$ RECESS IN SURFACE 1 AND RAISES THE THICKNESS TO $t = .190$ FROM $x = 0$ TO $.688$. (SURFACES 2, 3, 5, 6) RESULTS WITH SAME LOAD.

MODEL	MAX MADE STRESS	MAX VON MISES STRESS
3	28781 psi	25400 psi


ADJUST MAX VON MISES STRESS BY 1% AND
APPLY FACTORS OF SAFETY

$$\sigma = (1.01)(25400) = 25654 \text{ psi}$$

$$MS = \frac{35000}{1.25 \times 25654} - 1 = +.09$$

$$MS = \frac{42000}{1.4 \times 25654} - 1 = +.17$$


∴ INCREASING t TO $.200 - .010$ BELOW
LOWER AFT PANEL SOLVES STRESS
PROBLEM.



SECTION B-B 12
6
SCALE : 2/1

REVISED LOWER BASEPLATE



Lower Baseplate @ Lower Aft Panel



Thickness Surface


.053 1
.065 4
.190 2, 3, 5, 6

FRINGE PLOT LC=1.7 RES=2.1(MAJOR) MSC/PATRAN R-1.4 P3/FEA 11-Jan-96 14:52:10



201999.	
187047.	
172095.	
157144.	
142192.	
127240.	
112288.	
97336.	
82385.	
67433.	
52481.	
37529.	
22578.	
7626.	
-7326.	major prin stress - top surf
-22278.	t=.065 constant

FRINGE PLOT LC=1.14 RES=2.1(VON-MISES) MSC/PATRAN R-1.4 P3/FEA 12-Jan-96 11:09:54





von Mises stress - top surf

t=.065

178275.
166391.
154507.
142623.
130739.
118855.
106971.
95087.
83203.
71319.
59435.
47551.
35667.
23783.
11899.
15.28


FRINGE PLOT LC=1.6 RES=2.1(MAJOR) MSC/PATRAN R-1.4 P3/FEA 11-Jan-96 14:48:18



206879.
191609.
176339.
161069.
145799.
130529.
115258.
99988.
84718.
69448.
54178.
38908.
23638.
8368.
-6903.
-22173.

major prin stress - top surf
t=.065 with .053 recess


FRINGE PLOT LC=1.13 RES=2.1(VON-MISES) MSC/PATRAN R-1.4 P3/FEA 12-Jan-96 11:08:49



von Mises stress - top surf
t=.065 w/ .053 recess

182582.
170411.
158240.
146069.
133898.
121726.
109555.
97384.
85213.
73042.
60871.
48700.
36529.
24358.
12187.
15.45


FRINGE PLOT LC=1.12 RES=2.1(MAJOR) MSC/PATRAN R-1.4 P3/FEA 12-Jan-96 10:56:03



major principal stress - top surf
t=.065 w/ .053 recess & .190 step

28781.
26741.
24702.
22662.
20623.
18583.
16544.
14504.
12464.
10425.
8385.
6346.
4306.
2267.
227.4
-1812.


FRINGE PLOT LC=1.12 RES=2.1(VON-MISES) MSC/PATRAN R-1.4 P3/FEA 12-Jan-96 10:54:57




25400.
23707.
22014.
20321.
18627.
16934.
15241.
13548.
11855.
10161.
8468.
6775.
5082.
3388.
1695.
1.867

LOWER RIGHT PANEL ATTACHMENT TO LOWER BASEPLATE

THIS CROSS SECTION IS SIMILAR TO THE REVISED DESIGN UNDER THE LOWER AFT PANEL, AT THE LOWER RIGHT PANEL



CONSIDER TOP SECTION AS A FIXED END BEAM WITH OFFSET LOAD



PER FLANGE BENDING ANALYSIS OF THE LOWER RIGHT PANEL LOWER FLANGE PER RANDOM VIBRATION, $Q \approx 7.1$, THE MAXIMUM FORCE IN LB/IN WAS DETERMINED FROM RANDOM Y LOAD AS.

$$F_1 = 105.9 \text{ LB/IN} \quad \text{"1G" LOAD}$$

$$= 317.6 \text{ LB/IN} \quad \text{"3G" LOAD}$$

MAXIMUM M

$$R_A = \frac{F_1 b^2}{l^3} (3a+b) = .998 F_1 = 317.0 \text{ LB/IN}$$

$$R_B = .6 \text{ LB/IN}$$

$$a = .188$$

$$b = 7.190$$

$$l = 7.378$$

$$M = -\frac{F_1 a b^2}{l^2} + R_A x \quad \text{A to B}$$

$$= -\frac{F_1 a b^2}{l^2} + R_A x - F_1 (x-a) \quad \text{B to C}$$

MAXIMUM M @ END A (x=0)

$$M = -56.71 \text{ IN-LB/IN}$$

BENDING STRESS (@ x=0)

$$\sigma = \frac{6M}{t^2} = \frac{6(56.71)}{(.200-.010)^2} = 9426 \text{ psi}$$

$$\text{YIELD MS} = \frac{35000}{1.25(9426)} - 1 = +2.0$$

VERIFY VIA FINITE ELEMENT MODEL, 7.378 IN WIDE
WITH ALLOYS FIXED, $t = .190$ AT LOAD, 317.6 LB/IN,
.065 FOR $.500-.438 = .062$ IN, THEN .053.

MODEL	MAX MAJOR STRESS	MAX VON MISES STRESS
1	9899 psi	8737 psi

PER FINITE ELEMENT MODEL VON MISES STRESS


$$MS = \frac{35000}{1.25 \times 8737} - 1 = +2.2$$

$$MS = \frac{42000}{1.4 \times 8737} - 1 = +2.4$$

∴ LOWER BASEPLATE CROSS SECTION OK
UNDER LOWER RIGHT PANEL.


Lower Baseplate
@ Lower Right Panel

Report 10381
Addendum 1



Thickness	Surface
.053	1
.075	2
.190	3, 4


FRINGE PLOT LC=1.15 RES=2.1(MAJOR) MSC/PATRAN R-1.4 P3/FEA 12-Jan-96 12:35:42



major prin stress - top surf t=.065 w/.053 recess & .190 step

9899.
9210.
8521.
7831.
7142.
6453.
5763.
5074.
4385.
3695.
3006.
2317.
1627.
938.0
248.7
-440.6

FRINGE PLOT LC=1.15 RES=2.1(MAJOR) MSC/PATRAN R-1.4 P3/FEA 12-Jan-96 12:36:37



9899.

9210.

8521.

7831.

7142.

6453.

5763.

5074.

4385.

3695.

3006.

2317.

1627.

938.0

248.7

-440.6

von Mises stress - top surf t=.065 w/.053 recess & .190 step

1-12-96


5.4.5.3

LOWER BASEPLATE - SHEAR STRESS @ LEFT PANEL FLANGE GROOVED CROSS SECTION

USING RANDOM VIBRATION RESULTS, Q#7.1, THE WORST CASE VERTICAL LB/INCH LOAD IS DERIVED FROM LEFT PANEL SHELL ELEMENTS NASTRAN MODEL DATA. AS SHOWN ON FOLLOWING PAGES

$$F = 127.9 \text{ LB/IN} \quad "3T" \text{ LOAD}$$

THE GROOVED SECTION AT THE LEFT PANEL FLANGE ON THE LOWER BASEPLATE (1356405 VIEW P) IS SHOWN IN THE SKETCH BELOW



RANDOM VIBRATION DATA FOR THE "3T" CONDITION IS USED IN THE EVALUATION ALONG WITH A FACTOR OF SAFETY, FS OF 1.4.

RANDOM VIBRATION RESULTS - LEFT PANEL

1T LOADS, Q=7.1

<u>RANDOM X</u>		
EL	3243	3256
Fx	5.90	16.50
Fy	23.56	33.13
Fxy	8.61	6.25
		LB/IN

<u>RANDOM Y</u>					
EL	3243	3253	3254	3255	3256
Fx	5.39	8.24	11.17	11.80	21.28
Fy	22.25	25.39	24.63	23.36	44.51
Fxy	4.54	4.23	6.21	7.35	5.39
					LB/IN

<u>RANDOM Z</u>		
EL	3243	3256
Fx	4.58	10.54
Fy	16.00	18.55
Fz	3.51	3.92
		LB/IN

CRITICAL LOAD CASE IS RANDOM Y, CRITICAL ELEMENT IS EL 3256, WHICH IS A SLIGHTLY SKEWED ELEMENT, AT $\theta = -7.80^\circ$. ROTATING -7.80° GIVES A FORCE Fy' OF

$$Fy' = 42.63 \text{ LB/IN} \quad 1T \text{ LOAD}$$

$$= 127.9 \text{ LB/IN} \quad 3T \text{ LOAD}$$

THIS FORCE IS REACTED IN SHEAR ACROSS THE MINIMUM SECTION OF THE LOWER BASEPLATE LEFT PANEL FLANGE GROOVE (SEE SKETCH). SHEAR STRESS WITH 1.4 FACTOR OF SAFETY APPLIED TO "3T" LOAD


$$\tau = \left(\frac{127.9}{.125} \right) \frac{\text{LB/IN}}{\text{IN}} = 1023 \text{ PSI}$$

MATERIAL, 6061-T6 ALUMINUM,

$$F_{su} = 27000 \text{ psi}$$

$$MS = \frac{27000}{1.4(1023)} - 1 = +17$$

∴ SHEAR STRESS IN GROOVED SECTION AT
LEFT PANEL FLANGE IS OK



GRID	X	Z
l 40	25.532	0
j 41	25.970	0
k 300	25.970	1.131
l 2352	25.125	1.131

$$\angle k_{lj} = \tan^{-1} \frac{1.131}{.438} = 68.83^\circ$$

$$\angle l_{jk} = \tan^{-1} \frac{1.131}{.845} = 53.24^\circ$$


$$\angle l_{jk} = \tan^{-1} \frac{1.131}{0} = 90^\circ$$

$$\angle l_{jk} = 180 - 90 - 68.83 = 21.17^\circ$$

$$\angle l_{jk} = 90 - 53.24 = 36.76^\circ$$



$$\angle k_{pj} = 180 - 21.17 - 36.76 = 122.07^\circ$$

$$\angle q_{pj} = 90 - 53.24 = 36.76^\circ$$



$$F_y' = \frac{F_x + F_y}{2} + \frac{F_x - F_y}{2} \cos(2(-7.80)) + F_{xy} \sin(2(-7.80))$$

EL 3243



	6210	X	Z
L	27	7.282	0
J	28	7.408	0
K	2369	8.100	1.131
L	990	7.282	1.131

$$\angle LJP \quad \tan^{-1} \frac{1.131}{.818} = 54.12^\circ$$


$$\angle LJP \quad \tan^{-1} \frac{1.131}{.326} = 73.92^\circ$$

$$\angle LJP = 90 - 54.12 = 35.88^\circ$$


$$\angle LJP = 90 - 73.92 = 16.08^\circ$$

$$\angle LJP = 180 - 35.88 - 16.08 = 128.04^\circ$$

$$XEL \text{ axis } \odot 16.08 + (54.12 + 73.92)/2 = 30.10^\circ$$



$$F_y' = \frac{F_x + F_y}{2} + \frac{F_x - F_y}{2} \cos(2(9.90^\circ)) + F_{xy} \sin(2(9.90^\circ))$$



$$\angle L_J Q \quad \tan^{-1} \frac{1.131}{1.511} = 36.82^\circ$$


$$\angle R_L J \quad \tan^{-1} \frac{1.131}{1.1245} = 45.17$$

$$\angle LQP = 90 - 45.17 = 44.83^\circ$$

$$\angle QPJ = 90 - 36.82 = 53.18^\circ$$



$$\angle JPQ = 180 - 44.83 - 53.18 = 81.98^\circ$$

$$X_{EL} \text{ axis } \odot 53.18 + (45.17 + 36.82)/2 = 94.18^\circ$$



$$F_y' = \frac{F_x + F_y}{2} + \frac{F_x - F_y}{2} \cos(2(-4.18)) + F_{xy} \sin(2(-4.18))$$

EL 3255



	Q210	X	Z
L	39	23.470	0
J	40	25.532	0
Jk	2352	25.125	1.131
L	2351	23.470	1.131

$$\angle JkLj \tan^{-1} \frac{1.131}{1.655} = 34.35^\circ$$

$$\angle LjJk \tan^{-1} \frac{1.131}{.407} = 70.21^\circ$$


$$\angle LjL \tan^{-1} \frac{1.131}{2.062} = 28.74^\circ$$

$$\angle Pqj = 180 - 90 - 28.74 = 61.26^\circ$$

$$\angle LqP = 180 - 90 - 34.35 = 55.65^\circ$$

$$\angle LqPj = 180 - 61.26 - 55.65 = 63.09^\circ$$

$$X_{EL} \text{ AXIS } \odot 61.26 + (34.35 + 28.74)/2 = 92.81^\circ$$



$$Fy' = \frac{Fx + Fy}{2} + \frac{Fx - Fy}{2} \cos(2(-2.81)) + Fxy \sin(2(-2.81)) =$$

3566	3567	3568	3569	3570	3571	3572	3573	3574	3575	3576	3577	3578
3579	3580	3581	3582	3583	3584	3585	3586	3587	3588	3589	3590	3591
3592	3593	3594	3595	3596	3597	3598	3599	3600	3601	3602	3603	3604
3605	3606	3607	3608	3609	3610	3611	3612	3613	3614	3615	3616	3617
3618	3619	3620	3621	3622	3623	3624	3625	3626	3627	3628	3629	3630
3631	3632	3633	3634	3635	3636	3637	3638	3639	3640	3641	3642	3643
3644	3645	3646	3647	3648	3649	3650	3651	3652	3653	3654	3655	3656
3657	3658	3659	3660	3661	3662	3663	3664	3665	3666	3667	3668	3669
3670	3671	3672	3673	3674	3675	3676	3677	3678	3679	3680	3681	3682
3683	3684	3685	3686	3687	3688	3689	3690	3691	3692	3693	3694	3695
3696	3697	3698	3699	3700	3701	3702	3703	3704	3705	3706	3707	3708
3709	3710	3711	3712	3713	3714	3715	3716	3717	3718	3719	3720	3721
3722	3723	3724	3725	3726	3727	3728	3729	3730	3731	3732	3733	3734
3735	3736	3737	3738	3739	3740	3741	3742	3743	3744	3745	3746	3747
3748	3749	3750	3751	3752	3753	3754	3755	3756	3757	3758	3759	3760
3761	3762	3763	3764	3765	3766	3767	3768	3769	3770	3771	3772	3773
3774	3775	3776	3777	3778	3779	3780	3781	3782	3783	3784	3785	3786
3787	3788	3789	3790	3791	3792	3793	3794	3795	3796	3797	3798	3799
3800	3801	3802	3803	3804	3805	3806	3807	3808	3809	3810	3811	3812
3813	3814	3815	3816	3817	3818	3819	3820	3821	3822	3823	3824	3825
3826	3827	3828	3829	3830	3831	3832	3833	3834	3835	3836	3837	3838
3839	3840	3841	3842	3843	3844	3845	3846	3847	3848	3849	3850	3851
3852	3853	3854	3855	3856	3857	3858	3859	3860	3861	3862	3863	3864
3865	3866	3867	3868	3869	3870	3871	3872	3873	3874	3875	3876	3877
3878	3879	3880	3881	3882	3883	3884	3885	3886	3887	3888	3889	3890
3891	3892	3893	3894	3895	3896	3897	3898	3899	3900	3901	3902	3903
3904	3905	3906	3907	3908	3909	3910	3911	3912	3913	3914	3915	3916
3917	3918	3919	3920	3921	3922	3923	3924	3925	3926	3927	3928	3929
3930	3931	3932	3933	3934	3935	3936	3937	3938	3939	3940	3941	3942
3943	3944	3945	3946	3947	3948	3949	3950	3951	3952	3953	3954	3955
3956	3957	3958	3959	3960	3961	3962	3963	3964	3965	3966	3967	3968
3969	3970	3971	3972	3973	3974	3975	3976	3977	3978	3979	3980	3981
3982	3983	3984	3985	3986	3987	3988	3989	3990	3991	3992	3993	3994
3995	3996	3997	3998	3999	4000	4001						

+

35X

上野大




Figure 1 AMSU A1 Axes And Parts Identification






Figure 2 AMSU A1 External Parts Identification

FIGURE 3
EOS AMSU-A1 FINITE ELEMENT MODEL



Time: 15:38:09
Date: 01/23/96
Eigenvalues
Translational
modal
Mode 1 : Frequency = 108.9
Max. Deformation =
4.337412E+01
@Node 63688

FIGURE 4 EOS AMSU-A1
1ST NON-RIGID BODY
MODESHAPE 109.0 HZ



Time: 15:40:59
Date: 01/23/96
Eigenvectors
Translational
modal
Mode 1 : Frequency = 100.9
Max. Deformation =
4.337412E+01
@Node 63688






FIGURE 4a EOS AMSU-A1
1ST NON-RIGID BODY
MODESHAPE 100.9 HZ
LOWER CARD CAGE

Time: 15:37:24
Date: 01/23/96
Eigenvalues
Translational
modal
Mode 2 : Frequency = 108.9
Max. Deformation =
4.287141E+01
QNode 63808

FIGURE 5 EOS AMSU-A1
2ND NON-RIGID BODY
MODESHAPE 109.0 HZ



Time: 15:34:59
Date: 01/23/96
Eigenvalues
Translational
modal
Mode 2 : Frequency = 108.9
Max. Deformation =
4.287141E+01
@Node 63808





FIGURE 5a EOS AMSU-A1
2ND NON-RIGID BODY
MODESHAPE 109.0 HZ
LOWER CARD CAGE


Time: 15:29:40
Date: 01/23/96
Eigenvectors
Translational
modal
Mode 3 : Frequency = 109.5
Max. Deformation =
3.212686E+01
@Node 63728

FIGURE 6 EOS AMSU-A1
3rd NON-RIGID BODY
MODESHAPE 109.6 HZ




Time: 15:33:05
Date: 01/23/96
Eigenvalues
Translational
modal
Mode 3 : Frequency = 109.5
Max. Deformation =
3.212686E+01
@Node 63728

FIGURE 6a EOS AMSU-A1
3rd NON-RIGID BODY
MODESHAPE 109.6 HZ
LOWER CARD CAGE



Time: 15:27:31
Date: 01/23/96
Eigenvectors
Translational
modal
Mode 4 : Frequency = 109.7
Max. Deformation =
3.191910E+01
@Node 63768

FIGURE 7 EOS AMSU-A1
4TH NON-RIGID BODY
MODESHAPE 109.7 HZ



Time: 15:13:59
Date: 01/23/96
Eigenvalues
Translational
modal
Mode 4 : Frequency = 109.7
Max. Deformation =
3.191910E+01
Node 63768






FIGURE 7a EOS AMSU-A1
4TH NON-RIGID BODY
MODESHAPE 109.7 HZ
LOWER CARD CAGE

Time: 15:43:44
Date: 01/23/96
Eigenvectors
Translational
modal
Mode 5 : Frequency = 116.2
Max. Deformation =
1.382261E+01
@Node 66848

FIGURE 8 EOS AMSU-A1
5TH NON-RIGID BODY
MODESHAPE 116.3 HZ



Time: 15:48:21

Date: 01/23/96

Eigenvalues

Translational

modal

Mode 6 : Frequency = 121.4

Max. Deformation =


4.700038E+01

@Node 34517

FIGURE 9 EOS AMSU-A1


6TH NON-RIGID BODY

MODESHAPE 121.4 HZ




Time: 15:54:18
Date: 01/23/96
Eigenvalues
Translational
modal
Mode 7 : Frequency = 122.1
Max. Deformation =
4.668579E+01
@Node 443

FIGURE 10 EOS AMSU-A1
7TH NON-RIGID BODY
MODESHAPE 122.2 HZ



Time: 15:56:47
Date: 01/23/96
Eigenvectors
Translational
modal
Mode 8 : Frequency = 122.3
Max. Deformation =
4.744259E+01
QNode 32017

FIGURE 11 EOS AMSU-A1
BTH NON-RIGID BODY
MODESHAPE 122.3 HZ



Figures 12 through 45 not re-evaluated in *Addendum 1*.

Appendix A

NASTRAN FINITE ELEMENT MODEL

NASTRAN Mathematical Validity Check

To demonstrate the mathematical soundness of the NASTRAN model, the model is subjected to the GSFC 422-11-12-01 Paragraph 11.1.4.i Deliverable Model Validity Check, where a rigid-body or stiffness-equilibrium check is performed. Using NASTRAN Solution 3, a DIAG 64 ALTER 126 DMAP is run. The NASTRAN Executive Control Data Deck consists of:

```
ID AMSU1,RANDOM
TIME 60
SOL 3
$
DIAG 64
$
COMPILE SOL3,SOUIN=MSCSOU
ALTER 126
VECPLOT, ,BGPDT,EQEXIN,CSTM,,,/RBGLOBAL/GRDPNT=0//4 $
VEC USET/V1/G/F/COMP' $
PARTN RBGLOBAL,V1/RBFF,,,0 $
TRNSP RBFF/RBFFT $
MPYAD KFF,RBFFT/KFFR/ $
MATGPR GPL,USET,SIL,KFFR/'F'///1.E-2 $
DIAGONAL KFF/KFFD/OPT='SQUARE'/POWER=-1. $
MPYAD KFFD,KFFR/KFFRN/ $
MATGPR GPL,USET,SIL,KFFRN/'F'///SMALL=1.E-5 $
ENDALTER
CEND
```

A NASTRAN correspondence on the rigid-body check describes the requirements of the test.

"The basic function of this check is to multiply through a cross product the free stiffness matrix by the model rigid body matrix. The matrix which results from this multiplication can be thought of as the internal forces which must be applied to the structure to overcome any model internal constraint to achieve the desired rigid body motion. This matrix is titled the KFFR matrix. The smaller the magnitude of the numbers in the matrix, the less internal constraint present in the model. The DMAP will print any values larger than 1.0E-2. In an attempt to evaluate the effect of any internal constraint, the KFFR matrix is divided by the diagonal stiffness term of each respective row. The resulting matrix is considered 'normalized' and is titled the KFFRN matrix. A satisfactory KFFRN matrix . . . will generally have terms less than 1.0E-5."

Thus terms of the KFFRN matrix need be less than 1.0E-5.

The NASTRAN EOS/AMSU-A1 finite element model has been checked and modified to conform to GSFC 422-11-12-01 Paragraph 11.1.4.i requirements. All terms of the KFFRN matrix are less than 1.0E-5. There were, however, modifications to the model required to reach satisfactory equilibrium. These corrections consisted of:

- (1) Using large field data transfer from PATRAN to NASTRAN. This eliminated truncation errors at several GRID cards and out-of-plane elements.
- (2) Modifying GRIDs slightly to insure all GRIDs of an element lie in a plane (i.e. Power Control Module and the Warmload Housings).
- (3) Constructing several massless, stiffless, CBAR elements in the Reflector Shrouds.

Upon making the above changes, the KFFRN matrix became null. A check of the 1st ten non-rigid-body modes before and after the model modifications demonstrated no significant change in natural frequencies or mode shapes. A comparison table of "before changes" and "after changes" follows.

Mode No.	Natural Frequency Before Changes	Natural Frequency After Changes
1	108.9 Hz	109.0 Hz
2	109.0	109.0
3	109.6	109.6
4	109.7	109.7
5	115.9	116.3
6	121.4	121.4
7	122.2	122.2
8	122.3	122.3
9	146.6	146.6
10	147.2	147.2

The NASTRAN finite element model of the EOS AMSU-A1 module is shown in its entirety in Figure 3 and again in Figure A1 in this appendix. Figure A2 is a section view of the model, showing the components modeled in the interior (i.e. shelves, card cages, warmload structures). Elements and grids are highlighted in the piece part models of Figures A3 through A58 that are combined to form the A1 module model. The following components are identified:

Component	Figures
Lower Baseplate	A3-A6
Upper Baseplate	A7-A10
Top Panel	A11-A13
Lower Shelf	A14-A16
Upper Shelf	A17-A19
Lower Aft Panel	A20-A22
Upper Aft Panel	A23-A25
Lower Front Panel	A26-A28
Upper Front Panel	A29-A31
Lower Motor Mount Panel	A32-A34
Upper Motor Mount Panel	A35-A37
Left Panel/Beam Support	A38-A39
Lower Right Panel	A40-A42
Upper Right Panel	A43-A45
Lower Right Front Support	A46
Upper Right Front Support	A47
Lower Left Shield	A48
Lower Right Shield	A49
Upper Left Shield	A50
Upper Right Shield	A51
Lower Card Cage Assembly	A52
Upper Card Cage Assembly	A53
Lower Reflector Assembly	A54
Upper Reflector Assembly	A55
Lower Warmload	StructureA56
Upper Warmload	StructureA57
Upper Aft Panel w/PCM	A58

Addendum 1 shows only the components modified from the June 1995 submittal. These are Figures A23-A25 (Upper Aft Panel), Figure A30 (Upper Front Panel Bars, Beams, and Masses), and new Figure A58 (Upper Aft Panel w/PCM).

FIGURE A1

EOS AMSU-A1 FINITE ELEMENT MODEL





FIGURE A2

EOS AMSU-A1 FINITE ELEMENT MODEL - SECTION



Figures A3 through A22 not re-evaluated in *Addendum 1*.

FIGURE A23
UPPER AFT PANEL






FIGURE A23A
UPPER AFT PANEL
QUAD, TRI








FIGURE A25

UPPER AFT PANEL

GRID



Figures A26 through A29 not re-evaluated in *Addendum 1*.



0796-8265



A-11

Figures A31 through A57 not re-evaluated in *Addendum 1*.

FIGURE A58
UPPER AFT PANEL W/PCM



REPORT DOCUMENTATION PAGE			Form Approved OMB No. 0704-0188	
Public reporting burden for this collection of information is estimated to average 1 hour per response, including the time for reviewing instructions, searching existing data sources, gathering and maintaining the data needed, and completing and reviewing the collection information. Send comments regarding this burden estimate or any other aspect of this collection of information, including suggestions for reducing this burden, to Washington Headquarters Services, Directorate for Information Operations and Reports, 1215 Jefferson Davis Highway, Suite 1204, Arlington, VA 22202-4302, and to the Office of Management and Budget, Paperwork Reduction Project (0704-0188), Washington, DC 20503.				
1. AGENCY USE ONLY (Leave blank)		2. REPORT DATE		3. REPORT TYPE AND DATES COVERED
4. TITLE AND SUBTITLE METSAT Advanced Microwave Sounding Unit-A2 (AMSU-A2), Stress Analysis Report, A1 Module			5. FUNDING NUMBERS NAS 5-32314	
6. AUTHOR(S) W. Ely				
7. PERFORMING ORGANIZATION NAME(S) AND ADDRESS(ES) Aerojet 1100 W. Hollyvale Azusa, CA 91702			8. PERFORMING ORGANIZATION REPORT NUMBER CDRL 113-A! 10381, Addendum 1 8 February 1996	
9. SPONSORING/MONITORING AGENCY NAME(S) AND ADDRESS(ES) NASA Goddard Space Flight Center Greenbelt, Maryland 20771			10. SPONSORING/MONITORING AGENCY REPORT NUMBER ---	
11. SUPPLEMENTARY NOTES ---				
12a. DISTRIBUTION/AVAILABILITY STATEMENT ---			12b. DISTRIBUTION CODE ---	
13. ABSTRACT (Maximum 200 words) This addendum supplements Report 10381, dated June 1995, to include a new and more refined finite element model.				
14. SUBJECT TERMS EOS Microwave System			15. NUMBER OF PAGES 325	
			16. PRICE CODE ---	
17. SECURITY CLASSIFICATION OF REPORT Unclassified	18. SECURITY CLASSIFICATION OF THIS PAGE Unclassified	19. SECURITY CLASSIFICATION OF ABSTRACT Unclassified	20. LIMITATION OF ABSTRACT SAR	



National Aeronautics and
Space Administration

Report Documentation Page

1. Report No. ---	2. Government Accession No. ---	3. Recipient's Catalog No. ---	
4. Title and Subtitle Integrated Advanced Microwave Sounding Unit -A2 (AMSU-A2), Stress Analysis Report, A1 Module		5. Report Date 8 February 1996	
7. Author(s) W. Ely		6. Performing Organization Code ---	
		8. Performing Organization Report No. 10381, Addendum 1	
9. Performing Organization Name and Address Aerojet 1100 W. Hollyvale Azusa, CA 91702		10. Work Unit No. ---	
12. Sponsoring Agency Name and Address NASA Goddard Space Flight Center Greenbelt, Maryland 20771		11. Contract or Grant No. NAS 5-32314	
		13. Type of Report and Period Covered Final	
		14. Sponsoring Agency Code ---	
15. Supplementary Notes ---			
16. ABSTRACT (Maximum 200 words) This addendum supplements Report 10381, dated June 1995, to include a new and more refined finite element model.			
17. Key Words (Suggested by Author(s)) EOS Microwave System		18. Distribution Statement Unclassified --- Unlimited	
19. Security Classif. (of this report) Unclassified	20. Security Classif. (of this page) Unclassified	21. No. of pages 325	22. Price ---

NASA FORM 1626 OCT 86

GENERAL INSTRUCTIONS FOR COMPLETING SF 298

The Report Documentation Page (RDP) is used in announcing and cataloging reports. It is important that this information be consistent with the rest of the report, particularly the cover and title page. Instructions for filing in each block of the form follow. It is important to stay within the lines to meet optical scanning requirements.

Block 1. Agency Use Only (Leave blank)

Block 2. Report Date. Full publication date including day, month, and year, if available (e.g., 1 Jan 88). Must cite at least the year.

Block 3. Type of Report and Dates Covered. State whether report is interim, final, etc. If applicable, enter inclusive report dates (e.g., 10 Jun 87 - 30 Jun 88).

Block 4. Title and Subtitle. A title is taken from the part of the report that provides the most meaningful and complete information. When a report is prepared in more than one volume, report the primary title, add volume number, and include subtitle for the specific volume. On classified documents enter the title classification in parentheses.

Block 5. Funding Numbers. To include contract and grant numbers; may include program element number(s), project number(s), tasks number(s), and work unit number(s). Use the following labels:

C	-	Contract	PR	-	Project
G	-	Grant	TA	-	Task
PE	-	Program Element	WU	-	Work Unit Accession No.

Block 6. Author(s). Name(s) of person(s) responsible for writing the report, performing the research, or credited with the content of the report. If editor or compiler, this should follow the name(s).

Block 7. Performing Organization Name(s) and Address(es). Self-explanatory.

Block 8. Performing Organization Report Number. Enter the unique alphanumeric report number(s) assigned by the organization performing the report.

Block 9. Sponsoring/Monitoring Agency Name(s) and Address(es). Self-explanatory.

Block 10. Sponsoring/Monitoring Agency Reports Number. (if known).

Block 11. Supplementary Notes. Enter information not included elsewhere such as: Prepared in cooperation with ...; Trans. of ...; To be published in ... When a report is revised, include a statement whether the new report supersedes or supplements the older report.

Block 12.a Distribution/Availability Statement. Denotes public availability or limitations. Cite any availability to the public. Enter additional limitations or special markings in all capitals (e.g., NOFORN, REL, ITAR).

DOD - See DoDD 5230.24 "Distribution Statement on Technical Documents"

DOE - See authorities.

NASA - See Handbook NHB 2200.2.

NTIS - Leave blank.

Block 12.b Distribution Code.

DOD - Leave blank.

DOE - Enter DOE distribution categories from the standard Distribution for Unclassified Scientific and Technical Reports.

NASA - Leave blank.

NTIS - Leave blank.

Block 13. Abstract. Include a brief (Maximum 200 words) factual summary of the most significant information contained in the report.

Block 14. Subject Terms. Keywords or phrases identifying major subjects in the report.

Block 15. Number of Pages. Enter the total number of pages.

Block 16. Price Code. Enter appropriate price code (NTIS only).

Block 17 - 19. Security Classifications. Self-explanatory. Enter U.S. Security Classification in accordance with U.S. Security Regulations (i.e., UNCLASSIFIED). If form contains classified information, stamp classification on the top and bottom of the page.

Block 20. Limitation of Abstract. This block must be completed to assign a limitation to the abstract. Enter either UL (unlimited) or SAR (same as report). An entry in this block is necessary if the abstract is to be limited. If blank, the abstract is assumed to be unlimited.

PREPARATION OF THE REPORT DOCUMENTATION PAGE

The last page of a report facing the third cover is the Report Documentation Page, RDP. Information presented on this page is used in announcing and cataloging reports as well as preparing the cover and title page. Thus, it is important that the information be correct. Instructions for filing in each block of the form are as follows:

Block 1. Report No. NASA report series number, if preassigned.

Block 2. Government Accession No. Leave blank.

Block 3. Recipient's Catalog No. Reserved for use by each report recipient.

Block 4. Title and Subtitle. Typed in caps and lower case with dash or period separating subtitle from title.

Block 5. Report Date. Approximate month and year the report will be published.

Block 6. Performing Organization Code. Leave blank.

Block 7. Authors. Provide full names exactly as they are to appear on the title page. If applicable, the word editor should follow a name.

Block 8. Performing Organization Report No. NASA installation report control number and, if desired, the non-NASA performing organization report control number.

Block 9. Performing Organization Name and Address. Provide affiliation (NASA program office, NASA installation, or contractor name) of authors.

Block 10. Work Unit No. Provide Research and Technology Objectives and Plants (RTOP) number.

Block 11. Contract or Grant No. Provide when applicable.

Block 12. Sponsoring Agency Name and Address. National Aeronautics and Space Administration, Washington, D.C. 20546-0001. If contractor report, add NASA installation or HQ program office.

Block 13. Type of Report and Period Covered. NASA formal report series; for Contractor Report also list type (interim, final) and period covered when applicable.

Block 14. Sponsoring Agency Code. Leave blank.

Block 15. Supplementary Notes. Information not included

elsewhere: affiliation of authors if additional space is required for Block 9, notice of work sponsored by another agency, monitor of contract, information about supplements (file, data tapes, etc.) meeting site and date for presented papers, journal to which an article has been submitted, note of a report made from a thesis, appendix by author other than shown in Block 7.

Block 16. Abstract. The abstract should be informative rather than descriptive and should state the objectives of the investigation, the methods employed (e.g., simulation, experiment, or remote sensing), the results obtained, and the conclusions reached.

Block 17. Key Words. Identifying words or phrases to be used in cataloging the report.

Block 18. Distribution Statement. Indicate whether report is available to public or not. If not to be controlled, use "Unclassified-Unlimited." If controlled availability is required, list the category approved on the Document Availability Authorization Form (see NHB 2200.2, Form FF427). Also specify subject category (see "Table of Contents" in a current issue of STAR) in which report is to be distributed.

Block 19. Security Classification (of the report). Self-explanatory.

Block 20. Security Classification (of this page). Self-explanatory.

Block 21. No. of Pages. Count front matter pages beginning with iii, text pages including internal blank pages, and the RDP, but not the title page or the back of the title page.

Block 22. Price Code. If Block 18 shows "Unclassified-Unlimited," provide the NTIS price code (see "NTIS Price Schedules" in a current issue of STAR) and at the bottom of the form add either "For sale by the National Technical Information Service, Springfield, VA 22161-2171" or "For sale by the Superintendent of Documents, U.S. Government Printing Office, Washington, D.C. 20402-0001," whichever is appropriate.

REPORT DOCUMENTATION PAGEForm Approved
OMB No. 0704-0188

Public reporting burden for this collection of information is estimated to average 1 hour per response, including the time for reviewing instructions, searching existing data sources, gathering and maintaining the data needed, and completing and reviewing the collection of information. Send comments regarding this burden estimate or any other aspect of this collection of information, including suggestions for reducing this burden, to Washington Headquarters Services, Directorate for Information Operations and Reports, 1215 Jefferson Davis Highway, Suite 1204, Arlington, VA 22202-4302, and to the Office of Management and Budget, Paperwork Reduction Project (0704-0188), Washington, DC 20503.

1. AGENCY USE ONLY (Leave blank)		2. REPORT DATE February 1996	3. REPORT TYPE AND DATES COVERED Contractor Report	
4. TITLE AND SUBTITLE METSAT Advanced Microwave Sounding Unit-A2 (AMSU-A2), Stress Analysis Report, A1 Module			5. FUNDING NUMBERS Code 481 Contract: NAS5-32314	
6. AUTHOR(S) PI: W. Ely				
7. PERFORMING ORGANIZATION NAME(S) AND ADDRESS(ES) Aerojet 1100 W. Hollyvale Azusa, CA 91702			8. PERFORMING ORGANIZATION REPORT NUMBER CDRL 113-A 10381, Addendum 1 February 1996	
9. SPONSORING/MONITORING AGENCY NAME(S) AND ADDRESS(ES) NASA Aeronautics and Space Administration Washington, D.C. 20546-0001			10. SPONSORING/MONITORING AGENCY REPORT NUMBER CR-203675	
11. SUPPLEMENTARY NOTES Technical Monitor: S. Krimchansky, Code 481				
12a. DISTRIBUTION/AVAILABILITY STATEMENT Unclassified-Unlimited Subject Category: 61 Report available from the NASA Center for AeroSpace Information, 800 Elkridge Landing Road, Linthicum Heights, MD 21090; (301) 621-0390.			12b. DISTRIBUTION CODE	
13. ABSTRACT (Maximum 200 words) This addendum supplements Report 10381, dated June 1995, to include a new and more refined finite element model.				
14. SUBJECT TERMS EOS, Microwave System, AMSU-A			15. NUMBER OF PAGES 325	
			16. PRICE CODE	
17. SECURITY CLASSIFICATION OF REPORT Unclassified	18. SECURITY CLASSIFICATION OF THIS PAGE Unclassified	19. SECURITY CLASSIFICATION OF ABSTRACT Unclassified	20. LIMITATION OF ABSTRACT Unlimited	